WATER SUPPLY

2015 JUN 11 AM 8:14

# MISSISSIPPI STATE DEPARTMENT OF HEALTH
## BUREAU OF PUBLIC WATER SUPPLY
### CCR CERTIFICATION
### CALENDAR YEAR 2014

City of Kosciusko
Public Water Supply Name

0040004
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH.** ***Please check all boxes that apply.***

Customers were informed of availability of CCR by: ***(Attach copy of publication, water bill or other)***

- ☐ Advertisement in local paper (attach copy of advertisement)
- ☐ On water bills (attach copy of bill)
- ☐ Email message (MUST Email the message to the address below)
- ☐ Other _____

Date(s) customers were informed: ___/___/___, ___/___/___, ___/___/___

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___/___/___

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ___/___/___

- ☐ As a URL (Provide URL _____)
- ☐ As an attachment
- ☐ As text within the body of the email message

CCR was published in local newspaper. ***(Attach copy of published CCR or proof of publication)***

Name of Newspaper: The Star-Herald

Date Published: 06 / 04 / 2015

CCR was posted in public places. ***(Attach list of locations)*** Date Posted: ___/___/___

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

_____

**CERTIFICATION**

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

David L. Clark

***Name/Title (President, Mayor, Owner, etc.)***

David L. Clark - General Manager

06/09/2015
***Date***

***Deliver or send via U.S. Postal Service:***
***Bureau of Public Water Supply***
***P.O. Box 1700***
***Jackson, MS 39215***

***May be faxed to:***
***(601)576-7800***

***May be emailed to:***
water.reports@msdh.ms.gov

gc

WATER SUPPLY
2015 JUN 11 AM 8: 14

# City of Kosciusko
## PWS # 40004
## 2014 DRINKING WATER QUALITY REPORT

**Is my water safe?**
We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

**Do I need to take special precautions?**
Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

**Where does my water come from?**
Our water comes from six (6) wells located in Kosciusko, Mississippi. Each of these wells draws water from the Meridian-Upper Wilcox Aquifer.

**Source water assessment and its availability**
This program was mandated by the Federal Safe Drinking Water Act of 1996, and requires states to develop and implement Source Water Assessment programs designed to notify public water systems and their customers regarding the susceptibility of their drinking water supplies to contamination. The Mississippi State Department of Health has completed our Source Water Assessment, and copies are available upon request. Please contact our office at 662-289-1141.

**Why are there contaminants in my drinking water?**
Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).
The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

**How can I get involved?**
We want our customers to be informed about their water utility. If you would like to learn more, please attend any of our regularly scheduled meetings. They are held at 5:30 P.M. on the first Monday after the second Tuesday of each month at the Kosciusko Water & Light Plant office at 204 West Jefferson Street in the City of Kosciusko, Mississippi.

**Other Information**
You may want additional information about your drinking water. You may contact either of our three (3) Certified Waterworks Operators or you may prefer to log on to the internet and obtain specific information about your water system and its compliance history at the following address: http://www.msdh.state.us/watersupply/index/htm. Information including current and past boil water notices, compliance and reporting violations and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" and "Flooding and Safe Drinking Water" may be obtained. We ask that all our customers help us protect our water resources, which are the heart of our community, our way of life, and our children's future. Please call or come by our office if you have any questions.

**Additional Information for Lead**
If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Kosciusko is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

## Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms. we have provided the definitions below the table.

| Contaminants | MCLG or MRDLG | MCL, TT, or MRDL | Your Water | Range Low | Range High | Sample Date | Violation | Typical Source |
|---|---|---|---|---|---|---|---|---|
| **Disinfectants & Disinfectant By-Products** | | | | | | | | |
| (There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants) | | | | | | | | |
| Haloacetic Acids (HAA5) (ppb) | NA | 60 | 12 | 6 | 12 | 2014 | No | By-product of drinking water chlorination |
| Chlorine (as Cl2) (ppm) | 4 | 4 | 1.02 | 1.00 | 1.10 | 2014 | No | Water additive used to control microbes |
| TTHMs [Total Trihalomethanes] (ppb) | NA | 80 | 21 | 4 | 21 | 2014 | No | By-product of drinking water disinfection |
| **Inorganic Contaminants** | | | | | | | | |
| Barium (ppm) | 2 | 2 | 0.0445 | 0.029 | 0.0445 | 2011 | No | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits |
| Fluoride (ppm) | 4 | 4 | .99 | 0.750 | 1.33 | 2014 | No | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories |
| Nitrate [measured as Nitrogen] (ppm) | 10 | 10 | 0.08 | 0.08 | 0.08 | 2014 | No | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits |
| Nitrite [measured as Nitrogen] (ppm) | 1 | 1 | 0.02 | 0.02 | 0.02 | 2014 | No | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits |
| Antimony (ppb) | 6 | 6 | 0.0005 | 0.0005 | 0.0005 | 2011 | No | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition. |
| Arsenic (ppb) | 0 | 10 | 0.0005 | 0.0005 | 0.0005 | 2011 | No | Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes |
| Beryllium (ppb) | 4 | 4 | 0.0005 | 0.0005 | 0.0005 | 2011 | No | Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries |
| Cadmium (ppb) | 5 | 5 | 0.0005 | 0.0005 | 0.0005 | 2011 | No | Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints |
| Chromium (ppb) | 100 | 100 | 0.0005 | 0.0005 | 0.0005 | 2011 | No | Discharge from steel and pulp mills; Erosion of natural deposits |
| Cyanide [as Free Cn] (ppb) | 200 | 200 | 0.015 | 0.015 | 0.015 | 2014 | No | Discharge from plastic and fertilizer factories; Discharge from steel/metal factories |
| Mercury [Inorganic] (ppb) | 2 | 2 | 0.0005 | 0.0005 | 0.0005 | 2011 | No | Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland |

| | | | | | | | | |
|---|---|---|---|---|---|---|---|---|
| Selenium (ppb) | 50 | 50 | 0.0025 | 0.0025 | 0.0025 | 2011 | No | Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines |
| Thallium (ppb) | 0.5 | 2 | 0.0005 | 0.0005 | 0.0005 | 2011 | No | Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories |

| Contaminants | MCLG | AL | Your Water | Sample Date | # Samples Exceeding AL | Exceeds AL | Typical Source |
|---|---|---|---|---|---|---|---|
| **Inorganic Contaminants** | | | | | | | |
| Copper - action level at consumer taps (ppm) | 1.3 | 1.3 | 0.19 | 2012 | 0 | No | Corrosion of household plumbing systems; Erosion of natural deposits |
| Lead - action level at consumer taps (ppb) | 0 | 15 | 3.3 | 2012 | 0 | No | Corrosion of household plumbing systems; Erosion of natural deposits |

**Unit Descriptions**

| Term | Definition |
|---|---|
| ppm | ppm: parts per million, or milligrams per liter (mg/L) |
| ppb | ppb: parts per billion, or micrograms per liter (µg/L) |
| NA | NA: not applicable |
| ND | ND: Not detected |
| NR | NR: Monitoring not required, but recommended. |

**Important Drinking Water Definitions**

| Term | Definition |
|---|---|
| MCLG | MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. |
| MCL | MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. |
| TT | TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water. |
| AL | AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow. |
| Variances and Exemptions | Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions. |
| MRDLG | MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| MRDL | MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. |
| MNR | MNR: Monitored Not Regulated |
| MPL | MPL: State Assigned Maximum Permissible Level |

**Fluoridation** – To comply with the *"Regulation Governing Fluoridation of Community Water Supplies"*, the CITY OF KOSCIUSKO is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that averages fluoride sample results were in the optimal range of 0.70-1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 91%.

**For more information please contact:**

Contact Name: Michael Adams
Address: 204 West Jefferson Street
Kosciusko, MS 39090
Phone: 662-289-1141
Fax: 662-289-7836
E-Mail: madams@tecinfo.net
Website: www.cityofkosciusko.com

Date: June 4, 2015

WATER SUPPLY

2015 JUN 11 AM 8: 14

To: Kosciusko Water & Light
PO Box 866
Kosciusko, MS 39090

For publication of described notice, copy of which is attached.

Ad Space **3x27.5** Times **1** and making **2** proofs, **$571.13**

Payment received from _____

(Clerk)
The Star-Herald
207 North Madison St.
Kosciusko, MS 39090

---

PROOF OF PUBLICATION

STATE OF MISSISSIPPI
COUNTY OF ATTALA

Personally came before me, the undersigned, a NOTARY PUBLIC in and for Attala County, Mississippi, the CLERK of The Star-Herald, a newspaper published in the City of Kosciusko, Attala County, in said state, who, being duly sworn deposes and says that The Star-Herald is a newspaper as defined and described in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amended Section 1858, of the Mississippi Code of 1942, and that the publication of a notice, of which the annexed is a copy, in the matter of **2014 Annual Drinking Water Quality Report,** has been published in said newspaper **1** times, to-wit:

On the **4th** day of **June, 2015**

STATE OF MISSISSIPPI
DAPHNE M DABBS
NOTARY PUBLIC
ID No. 69007
My Commission Expires
March 3, 2019
ATTALA COUNTY

(Clerk)

SWORN TO AND SUBSCRIBED before me, this 4th

day of June, 2015.

Daphne M. Dabbs
(Notary Public)

# City of Kosciusko

## PWS # 40004

## 2014 DRINKING WATER QUALITY REPORT

**Is my water safe?**

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

**Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

**Where does my water come from?**

Our water comes from six (6) wells located in Kosciusko, Mississippi. Each of these wells draws water from the Meridian-Upper Wilcox Aquifer.

**Source water assessment and its availability**

This program was mandated by the Federal Safe Drinking Water Act of 1996, and requires states to develop and implement Source Water Assessment programs designed to notify public water systems and their customers regarding the susceptibility of their drinking water supplies to contamination. The Mississippi State Department of Health has completed our Source Water Assessment, and copies are available upon request. Please contact our office at 662-289-1141.

**Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

**How can I get involved?**

We want our customers to be informed about their water utility. If you would like to learn more, please attend any of our regularly scheduled meetings. They are held at 5:30 P.M. on the first Monday after the second Tuesday of each month at the Kosciusko Water & Light Plant office at 204 West Jefferson Street in the City of Kosciusko, Mississippi.

**Other Information**

You may want additional information about your drinking water. You may contact either of our three (3) Certified Waterworks Operators or you may prefer to log on to the internet and obtain specific information about your water system and its compliance history at the following address: http://www.msdh.state.us/watersupply/index/htm. Information including current and past boil water notices, compliance and reporting violations and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" and "Flooding and

The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 91%.

**For more information please contact:**

Contact Name: Michael Adams
Address: 204 West Jefferson Street
Kosciusko, MS 39090
Phone: 662-289-1141
Fax: 662-289-7836
E-Mail: madams@tecinfo.net
Website: www.cityofkosciusko.com