

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION  
CALENDAR YEAR 2015

Lexie Water Association, Inc  
Public Water Supply Name

0740004

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other \_\_\_\_\_

Date(s) customers were informed: 05/24/2016 / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_\_\_ / /

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: \_\_\_\_\_ / /

- As a URL (Provide URL \_\_\_\_\_)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_\_\_ / /

CCR was posted in public places. *(Attach list of locations)*

Date Posted: \_\_\_\_\_ / /

CCR was posted on a publicly accessible internet site at the following address **(DIRECT URL REQUIRED)**:

www.lexiewater.com/ccr.html

**CERTIFICATION**

I hereby certify that the 2015 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

  
Name/Title (President, Mayor, Owner, etc.)

5-26-16  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601)576-7800

May be emailed to:

[water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**CCR Due to MSDH & Customers by July 1, 2016!**

2015 Annual Drinking Water Quality Report  
 Lexie Water Association, Inc.  
 PWS#: 0740004  
 April 2016

2016 MAY 27 AM 9:43

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from Miocene Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Lexie Water Association have received a lower ranking in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Cathy Van Dan at 601.814.0998. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on Tuesday, March 13, 2016 at 5:30 PM at the Lexie Water Office.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	---	--------------------	------	-----	--------------------------------

**Inorganic Contaminants**

10. Barium	N	2013*	.0569	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2013*	.5	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
17. Lead	N	2011/13*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

### Disinfection By-Products

Chlorine	N	2015	1.2	1.2 - 1.5	ppm	0	MRDL = 4	Water additive used to control microbes
----------	---	------	-----	-----------	-----	---	----------	---

### Unregulated Contaminants

Chromium	N	2015	.6	.495 - .6	UG/L		MRL 0.2	Naturally occurring element; used in making steel and other alloys
Chromium-6	N	2015	.56	.51 - .56	UG/L		MRL 0.03	Naturally occurring element; used in making steel and other alloys; chromium 3 or 6 forms are used for chrome plating, dyes and pigments, leather tanning and wood preservation
Cobalt	N	2015	2.2	No Range	UG/L		MRL 1	Naturally occurring element found in the earth's crust and at low concentrations in seawater, and in some surface and ground water; cobaltous chloride was formerly used in medicine and as a germicide
Manganese	N	2015	15	1.786- 15	UG/L			
Strontium	N	2015	28	24.693-28	UG/L		MRL 0.3	Naturally-occurring element; historically commercial used of strontium has been in the faceplate glass of cathode-ray tube televisions to block x-ray emissions

\* Most recent sample. No sample required for 2015.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Lexie Water Association works hard to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010022700	04/19	05/19

SERVICE ADDRESS  
92 LEHR CROSSING RD L2

CURRENT	METER READINGS		USED
	PREVIOUS		
269	266		3

CHARGE FOR SERVICES

WTR 22.50  
PAST DUE 20.79  
NET DUE >>> 43.29  
SAVE THIS >> 4.33  
GROSS DUE >> 47.62

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010029900	04/19	05/19

SERVICE ADDRESS  
97 TOM LEWIS RD

CURRENT	METER READINGS		USED
	PREVIOUS		
54	53		1

CHARGE FOR SERVICES

WTR 19.00  
NET DUE >>> 19.00  
SAVE THIS >> 1.90  
GROSS DUE >> 20.90

ACCOUNT NO.	SERVICE FROM	SERVICE TO
010036000	04/19	05/19

SERVICE ADDRESS  
85 ROCKY HILL RD

CURRENT	METER READINGS		USED
	PREVIOUS		
542	538		4

CHARGE FOR SERVICES

WTR 26.00  
NET DUE >>> 26.00  
SAVE THIS >> 2.60  
GROSS DUE >> 28.60

RETURN THIS STUB WITH PAYMENT TO:

LEXIE WATER ASSOCIATION  
P.O. BOX 167 · TYLERTOWN, MS 39667

PRESORTED  
FIRST-CLASS MAIL  
U.S. POSTAGE  
PAID  
PERMIT NO. 360  
TYLERTOWN, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/20/2016	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
43.29	4.33	47.62

LEXIE WATER CCR REPORT 2016  
[www.lexiewater.com/ccr.html](http://www.lexiewater.com/ccr.html)

RETURN SERVICE REQUESTED

010022700 /CONERLY GLENDA

92 LEHR CROSSING RD LOT 2  
TYLERTOWN MS 39667

RECEIVED - WATER SUPPLY  
2016 MAY 27 AM 9:43

RETURN THIS STUB WITH PAYMENT TO:

LEXIE WATER ASSOCIATION  
P.O. BOX 167 · TYLERTOWN, MS 39667

PRESORTED  
FIRST-CLASS MAIL  
U.S. POSTAGE  
PAID  
PERMIT NO. 360  
TYLERTOWN, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/20/2016	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
19.00	1.90	20.90

LEXIE WATER CCR REPORT 2016  
[www.lexiewater.com/ccr.html](http://www.lexiewater.com/ccr.html)

RETURN SERVICE REQUESTED

010029900 /WARREN RAYMOND

7066 HIGHWAY 98 E  
MCCOMB MS 39648

RETURN THIS STUB WITH PAYMENT TO:

LEXIE WATER ASSOCIATION  
P.O. BOX 167 · TYLERTOWN, MS 39667

PRESORTED  
FIRST-CLASS MAIL  
U.S. POSTAGE  
PAID  
PERMIT NO. 360  
TYLERTOWN, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/20/2016	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
26.00	2.60	28.60

LEXIE WATER CCR REPORT 2016  
[www.lexiewater.com/ccr.html](http://www.lexiewater.com/ccr.html)

RETURN SERVICE REQUESTED

010036000 /ROCKY HILL CHURCH

P O BOX 625  
TYLERTOWN MS 39667

2016 MAY 27 AM 9:43

Lexie Water

P O Box 167

Tylertown, MS 39667

Office: 601/876-5157

Cell: 601/814-0998

May 26, 2016

Dear Charles,

As of 2016 our CCR Reports will be published on our website using the URL address [lexiewater.com/ccr.html](http://lexiewater.com/ccr.html). We will notify our customers on the June billing cards. A copy will also be posted in office. Any customer can request a copy to be mailed to them.

Sincerely,

A handwritten signature in black ink, appearing to read "Cathy Van Dan". The signature is fluid and cursive, with a large initial "C" and a long, sweeping underline.

Cathy Van Dan

General Manager