

2016 MAY 26 AM 8:33

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2015

CITY OF RAYMOND
Public Water Supply Name

0250020

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
 On water bills (attach copy of bill)
 Email message (MUST Email the message to the address below)
 Other _____

Date(s) customers were informed: 05/13/2016 05/24/2016 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: 05/24/2016

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: ___ / ___ / ___

- As a URL (Provide URL _____)
 As an attachment
 As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: HINDS COUNTY GAZETTE

Date Published: 05/13/2016

CCR was posted in public places. *(Attach list of locations)*

Date Posted: ___ / ___ / ___

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2015 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Brenda A. Hulbert, CITY CLERK
Name/Title (President, Mayor, Owner, etc.)

05-25-16
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:

CCR Due to MSDH & Customers by July 1, 2016!

water.reports@msdh.ms.gov

2016 MAY 26 AM 8:33

2015 Annual Drinking Water Quality Report
City of Raymond
PWS#: 0250020
April 2016

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Cockfield Formation and Sparta Sand Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Raymond have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Brenda Hubbard at 601.857.8041. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:00 PM at the City Hall Boardroom.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2015	.0055	.0043 - .0055	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2015	4.4	2.5 - 4.4	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14. Copper	N	2012/14*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2015	.635	.535 - .635	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	5	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2015	13	1 - 33	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2015	18	1 - 50	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2015	1.5	.8 - 3	Mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2015.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The City of Raymond works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. This report will not be mailed out.

that would avoid these impacts, and (3) A Public Hearing will be held May 17 at 6449 W. Northside Drive, Bolton, Ms. 39015/6 and 05/13/16

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continuously improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Coastal Plain and State Sand Aquifers.

The annual water assessment has been completed for our public water system to determine the overall responsibility of its drinking water supply to selected potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Raymond have received lower to moderate susceptibility ratings to contamination.

If you have any questions about this report or concerning your water utility, please contact Brenda Hubbard at 801-837-8041. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Tuesday of each month at 6:00 PM at the City Hall Boardroom.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. The table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. All water drawn over the surface of land or underground, if unshielded, naturally occurring minerals and in some cases, radioactive materials, can pick up substances or contaminants from the presence of animals or from human activity, microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming, pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and natural organic chemicals, which are byproducts of industrial processes and petroleum production; and radon, which can get into wells and acidic systems, radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. As drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants, it's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In the table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal (MCLG)" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one ounce in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg/L) - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

Contaminant	Well/SPN	Date Collected	Level Detected	Range of Detects (µg/L or mg/L)	Unit of Detects Excluding IAC/ALC/L	Unit Measure (mg/L)	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants									
10. Barium	N	2015	0/550	0-43	ppm	um	2	3	Discharge of drinking water; discharge from natural deposits; erosion of natural deposits
13. Chromium	N	2015	4.4	2.0 - 4.4	ppb	ppb	100	100	Discharge from steel and alloy metal; erosion of natural deposits
14. Copper	N	2012/14*	3	0	ppm	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
10. Fluoride	N	2015	0/5	0.5 - 0/3	ppm	ppm	4	4	Erosion of natural deposits; water; surface water; erosion of natural deposits; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	3	0	ppb	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Disinfection By-Products									
61. HAAS	N	2015	13	1 - 33	ppb	ppb	0	80	By-product of drinking water disinfection
62. THM (Total Trihalomethanes)	N	2015	16	1 - 50	ppb	ppb	0	80	By-product of drinking water disinfection
63. Chloroform	N	2015	1.0	0 - 3	µg/L	µg/L	0	MRDL=4.4	Water Additive used to control microbes

* Most recent results. No sample required for 2015.
 As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected; however, the EPA has determined that your water is SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now routinely samples or any existing samples prior to the end of the compliance period.


If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/leadandtapwater>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 801-876-7828 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/MSDH guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The City of Raymond works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. This report will not be mailed out.

FRIDAY MAY 13, 2016

Herb Farm We
 Have you
 after being
 If so, the law firm of
 speaking with you in
 compensation. For a

 Attorney Advertising. Prior
 with local firms to states who
 (PNO) REC

AT&T
 To Place Your States
Classroom Training
MEDICAL BILLING SPECIALISTS NEEDED! Train at home for 30 weeks working with Medical Billing and Insurance Claims. Online training can get you ready! Call for FREE brochure! HS Diploma / GED and computer / internet needed. 1-877-269-0800.
Computers
COMPUTER PROBLEMS - viruses, lost data, hardware or software issues! Computer Cools, On-Site 24/7 Service, Friendly, Rapid Experts! Mice and PCs. Call for FREE diagnosis. 1-800-583-0945.
Employment-Trucking
DRIVER TRAINEES NOW BEING TRAINED AND HIRED for Azle Truck Lines. No OTR! Guaranteed Home Every Weekend! Local CDL Training, Earn \$55K - 160K! Call Today! 1-988-340-7366
E. TUCKER & SON, INC. Team drivers needed to run from S.E. to West Coast. Late model conventional tractors. Home weekly. Benefits package. Pearl, MS. 1-800-647-5494.
For Rent
1,300 Sq. Ft. Office Space For Lease North Jackson 601-981-3060

FREE FOOD PANTRY at 449 PM weekly. Medical Billing and Insurance Claims. Online training can get you ready! Call for FREE brochure! HS Diploma / GED and computer / internet needed. 1-877-269-0800.
MOBILE Ready to Bedroom, financing, rental - 60
AT&T \$12 per m at 449 PM weekly. Medical Billing and Insurance Claims. Online training can get you ready! Call for FREE brochure! HS Diploma / GED and computer / internet needed. 1-877-269-0800.
FAST Available Starting at Time
SAVE ON DLEST On satellite de up to \$31 NOW! 4 SWITCH 4 OH! Call HD/DVR \$19.99/m satellite Call
LUNG CA So Now A To A Sign 280-7193 Money DU

RAYMOND WATER DEPT.
P.O. BOX 10
RAYMOND, MS 39154
857-8416

SEE BACK FOR ADDITIONAL
INFORMATION
RETURN SERVICE REQUESTED

PRESORTED
FIRST CLASS MAIL
U.S. POSTAGE PAID
RAYMOND, MS
PERMIT NO. 7

CODE	METER READING		USAGE	AMOUNT
	PREVIOUS	PRESENT		
WA	266863	273019	6156	31.92

2015 CONSUMER CONFIDENCE REP
AVAILABLE AT CITY HALL AND
PUBLISHED IN HINDS CO GAZETTE

ACCOUNT STATUS	
ACTIVE	
ACCOUNT NUMBER	AMOUNT DUE
02-63345-00	31.92
DUE DATE	AFTER DUE DATE PAY THIS AMOUNT
6/20/2016	PD BY DRAFT
SERVICE FROM	SERVICE TO
4/18/2016	5/17/2016
SERVICE ADDRESS	
107 DOGWOOD LANE	

SERVICE FROM
4/18/2016
SERVICE TO
5/17/2016
AFTER DUE DATE PAY THIS AMOUNT
PD BY DRAFT

AMOUNT DUE	DUE DATE
31.92	6/20/2016
ACCOUNT STATUS	
ACTIVE	
ACCOUNT NUMBER	
02-63345-00	

PLEASE RETURN THIS
STUB WITH PAYMENT

SERVICE ADDRESS
107 DOGWOOD LANE

RECEIVED - WATER SUPPLY
2016 MAY 26 AM 8:33