

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY

2016 MAY 26 AM 8:34

CCR CERTIFICATION
CALENDAR YEAR 2015

Morgan City Water & Sewer
Public Water Supply Name

0420004

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 05/08/2016 / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / /

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: _____ / /

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Greenwood Commonwealth

Date Published: 05/08/2016

CCR was posted in public places. *(Attach list of locations)*

Date Posted: _____ / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2015 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Charles Branch
Name/Title (President, Mayor, Owner, etc.)

5-10-16
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:

CCR Due to MSDH & Customers by July 1, 2016!

water.reports@msdh.ms.gov

2015 Annual Drinking Water Quality Report
Morgan City Water & Sewer Association
PWS#: 0420004
April 2016

2016 MAY 26 AM 8:34

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from the Meridian Upper Wilcox Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The well for the Morgan City Water & Sewer Association has received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Carolyn C. Branch at 662-254-7162. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the annual meeting scheduled for the first Monday of February at 7:00 PM at the Leflore County Barn.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2012*	.007	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2012*	2	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14. Copper	N	2012/14*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2012*	.145	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

Chlorine	N	2015	.6	.51 – .75	ppm	0	MDRL = 4	Water additive used to control microbes
----------	---	------	----	-----------	-----	---	----------	---

* Most recent sample. No sample required for 2015.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Morgan City Water & Sewer Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Sunday, May 8, 2016

We're pleased to present to you this year's Annual Quality Water Report. This report is developed to inform you about the water that we provide to you every day. Our constant goal is to provide you with a safe and clean water supply. We are committed to ensuring the quality of your water. Our water source is from the Morgan City Water & Sewer Association.

The source water assessment has been completed for our public water system to determine the current susceptibility of the drinking water supply to naturally occurring sources of contamination. A report containing detailed information on how the water supply is protected from naturally occurring sources of contamination is available for viewing upon request. The well for the Morgan City Water & Sewer Association has passed a water quality monitoring program.

If you have any questions about this report or concerning your water utility, please contact Carolyn C. Smith at 802-284-7102. We are available to answer your questions from 7:00 AM to 5:00 PM at the Morgan City Water & Sewer Association.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table lists all of the constituents that were analyzed during the period of January 1st to December 31st, 2015. In cases where monitoring results are consistently above the Maximum Allowable Concentration (MAC) or where there are concerns about the presence of chemicals or pathogens, we will notify you. In some cases, we will also provide information on the presence of chemicals or pathogens that may be of concern to you. Some of the chemicals and pathogens that we monitor for are: disinfection byproducts, nitrates, nitrites, and volatile organic compounds. Some of the pathogens that we monitor for are: coliform bacteria, fecal coliform bacteria, and total coliform bacteria. We also monitor for a wide variety of other constituents, including trace metals, pesticides, herbicides, and pharmaceuticals. The source water assessment has been completed for our public water system to determine the current susceptibility of the drinking water supply to naturally occurring sources of contamination. A report containing detailed information on how the water supply is protected from naturally occurring sources of contamination is available for viewing upon request. The well for the Morgan City Water & Sewer Association has passed a water quality monitoring program.

In this table you will find the Maximum Allowable Concentration (MAC) for each constituent. It is important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

If you have any questions about this report or concerning your water utility, please contact Carolyn C. Smith at 802-284-7102. We are available to answer your questions from 7:00 AM to 5:00 PM at the Morgan City Water & Sewer Association.

Notes: (over) - the concentration of a contaminant which is exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The Maximum Allowable Concentration (MAC) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as is feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs do not enforce a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The goal of the drinking water disinfectant tables which there is no known or expected risk of health. MRDLGs do not enforce the benefits of the use of disinfectants to control microbial contaminants.

Contaminant	Volume, l/min	Date Collected	Level Detected	Units	MRDL	MRDLG	MAC	Daily Source of Contamination
TEST RESULTS								
Inorganic Contaminants								
10. Barium	N	2/22/15	307	ppm	2	2	2	Discharge of effluent, vehicle, erosion of natural resources, discharge from street and curb, discharge from storm drain, erosion of natural resources
13. Chromium	N	2/22/15	2	ppm	100	100	100	Discharge from street and curb, discharge from storm drain, erosion of natural resources
14. Copper	N	2/22/15	1	ppm	1.5	1.5	1.5	Corrosion of metal pipes, plumbing systems, erosion of natural resources, leaching from wood
16. Fluoride	N	2/22/15	143	ppm	4	4	4	Excess fluoride in water, excessive fluoride in water, excessive fluoride in water, excessive fluoride in water
17. Lead	N	2/22/15	1	ppb	5	5	5	Corrosion of metal pipes, plumbing systems, erosion of natural resources

Disinfection By-Products

Concentration	N	2015	0	51 - 75	ppm	0	MORL	1-1	Water, additives used in central treatment
---------------	---	------	---	---------	-----	---	------	-----	--

If you can see the table, the system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have not detected any violations and testing that some constituents have been detected however the EPA has determined that your water is SAFE in these levels.

We are pleased to provide you this report on the quality of your drinking water. If you have any questions about this report or concerning your water utility, please contact Carolyn C. Smith at 802-284-7102. We are available to answer your questions from 7:00 AM to 5:00 PM at the Morgan City Water & Sewer Association.

If you have any questions about this report or concerning your water utility, please contact Carolyn C. Smith at 802-284-7102. We are available to answer your questions from 7:00 AM to 5:00 PM at the Morgan City Water & Sewer Association.

Some sources of drinking water are naturally high in certain minerals. Other sources, such as geologic formations and man-made structures, may add minerals to the water. Some of these minerals, such as lead and copper, are naturally occurring in the water. The presence of certain minerals in the water may affect the taste of the water. Some people may be more sensitive to certain minerals than others. If you are concerned about the presence of minerals in your drinking water, you may wish to contact your water utility for more information. We are committed to ensuring the quality of your water. Our water source is from the Morgan City Water & Sewer Association.

The Morgan City Water & Sewer Association is committed to providing you with the highest quality water possible. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.