

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY

2016 JUN -9 AM 9:13

CCR CERTIFICATION
CALENDAR YEAR 2015Bear Creek Water Assn. Inc.
Public Water Supply Name0450002 & 0450021

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
 On water bills (attach copy of bill)
 Email message (MUST Email the message to the address below)
 Other _____

Date(s) customers were informed: ____ / ____ / ____ , ____ / ____ / ____

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ____ / ____ / ____

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: ____ / ____ / ____

- As a URL (Provide URL _____)
 As an attachment
 As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: ____ / ____ / ____

CCR was posted in public places. *(Attach list of locations)*

Date Posted: ____ / ____ / ____

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

<http://www.msrua.org/2015ccr/bearcreek.pdf>

CERTIFICATION

I hereby certify that the 2015 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Mark Wilk, GENERAL MANAGER
Name/Title (President, Mayor, Owner, etc.)

6/8/16

Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:

CCR Due to MSDH & Customers by July 1, 2016!

water.reports@msdh.ms.gov

2015 Annual Drinking Water Quality Report
Bear Creek Water Association, Inc.
PWS ID#:0450021 & 0450002
April 2016

2016 JUN -9 AM 9: 13

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Cockfield Formation, Sparta Sand Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Bear Creek Water Association have received lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Nolan Williamson at 601.856.5969. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held by the 10th of each month at 5:00 PM at 301 Distribution Dr., Madison, MS 39110.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID#: 0450021

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2015	.0189	.0025 - .0189	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2015	5.6	3.1 – 5.6	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2014/16	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2015	.698	.13 - .698	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2014/16	4	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2014*	23	8 - 23	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014*	28.8	8.76 – 28.8	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2015	1.20	.8 – 1.4	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2015.

** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l

PWS ID#: 0450002

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2015	.0034	.0017 - .0034	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2015	4.1	3.1 – 4.1	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2014/16	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2015	.67	.158 - .67	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2014/16	2	No Range	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2014*	20	6 - 20	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014*	28.3	9.31 – 27.97	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2015	1	.6 – 2.8	mg/l	0	MDRL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2015.*

*** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l.*

As you can see by the table, our system had no contaminate violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the BEAR CREEK W/A-WEST is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 82%.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the BEAR CREEK W/A -EAST is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 9. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 79%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Bear Creek Water Association works continuously to provide safe quality water to every tap. Bear Creek has received an excellent score with MS State Department of Health for capacity development. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.



PO BOX 107 • CANTON, MS 39046 • www.bcwaterms.org

RECEIVED - WATER SUPPLY CUSTOMER SERVICE DEPARTMENT

2016 JUN -9 AM 9:13 (601) 856-5969 option #1


7:00 AM - 5:00 PM MONDAY-FRIDAY

WHEN PAYING THIS BILL IN PERSON, BRING BOTH PORTIONS OF THIS BILL

13081 1 AV 0.373 P:13081 / T:47 / S1:1 / S2:0



Bear Creek Water Assn 1"
PO Box 107
Canton MS 39046-0107



BILLED TO BEAR CREEK WATER ASSN 1" SERVICE ADDRESS 301 DISTRIBUTION DR BILL DATE 05/25/16
ACCOUNT NO. 02222798 DUE DATE 06/20/16 DELINQUENT AFTER 06/20/16

Table with columns: METER NUMBER, READ DATE (PREVIOUS, PRESENT), BILLING DAYS, METER READINGS (PREVIOUS, PRESENT), USAGE. Row 1: 72047048, 04/12, 05/12, 30, 230900, 235500, 4600

PAST DUE BILLS ARE DUE NO LATER THAN THE 1ST OF EACH MONTH.

Table with columns: DESCRIPTION, AMOUNT. Rows: PREVIOUS BALANCE (DUE IMMEDIATELY) 0.00, PAYMENTS 0.00

CCR is available at http://www.msrwa.org/2015ccr/bearcreek.pdf YOU MAY REQUEST A HARD COPY BY CALLING 601-856-5969.

MESSAGE:

TOTAL AMOUNT DUE: 0.00
DUE DATE 06/20/16
AFTER DUE DATE PAY 0.00

PLEASE SEPARATE REMITTANCE STUB AT THIS PERFORATION AND RETURN WITH PAYMENT



PO BOX 107 • CANTON, MS 39046 • www.bcwaterms.org

CHECK HERE FOR BILLING ADDRESS / PHONE CHANGES AND COMPLETE REVERSE SIDE. (Note: Service addresses must be changed in office.)

BEAR CREEK WATER ASSN 1"
P O BOX 107
CANTON, MS 39046

REMITTANCE STUB

ACCOUNT NUMBER: 02222798

SERVICE ADDRESS: 301 DISTRIBUTION DR

AMOUNT DUE 0.00

DUE DATE: 06/20/16

AMOUNT ENCLOSED \$

Please make checks payable to: BEAR CREEK WATER ASSOCIATION



BEAR CREEK WATER ASSOCIATION
PO BOX 107
CANTON MS 39046-0107



0002372852



PO BOX 107 • CANTON, MS 39046 • www.bcwaterms.org

CUSTOMER SERVICE DEPARTMENT

(601) 856-5969 option #1


7:00 AM - 5:00 PM MONDAY-FRIDAY

WHEN PAYING THIS BILL IN PERSON,
BRING BOTH PORTIONS OF THIS BILL

8149 1 AV 0.373 P:8149 / T:30 / S1:1 / S2:0



Henry Starling
104 Chartres Dr
Madison MS 39110-7055



BILLED TO **HENRY STARLING** SERVICE ADDRESS **104 CHARTRES DR** BILL DATE **05/26/16**
 ACCOUNT NO. **16000060** DUE DATE **06/20/16** DELINQUENT AFTER **06/20/16**

METER NUMBER	READ DATE		BILLING DAYS	METER READINGS		USAGE
	PREVIOUS	PRESENT		PREVIOUS	PRESENT	
71280451	04/12	05/12	30	324600	330400	5800

DESCRIPTION	AMOUNT
PREVIOUS BALANCE	44.50
PAYMENTS	(44.50)
WATER	16.16
SEWER-CENTRAL	23.20
SW MCWWA	8.70

CCR is available at
<http://www.msrrwa.org/2015ccr/bearcreek.pdf>
 YOU MAY REQUEST A HARD COPY BY
 CALLING 601-856-5969.

MESSAGE:

TOTAL AMOUNT DUE: 48.06
DUE DATE 06/20/16
AFTER DUE DATE PAY 52.87

PLEASE SEPARATE REMITTANCE STUB AT THIS PERFORATION AND RETURN WITH PAYMENT



PO BOX 107 • CANTON, MS 39046 • www.bcwaterms.org

CHECK HERE FOR BILLING ADDRESS / PHONE CHANGES AND COMPLETE REVERSE SIDE.
 (Note: Service addresses must be changed in office.)

HENRY STARLING
 104 CHARTRES DRIVE
 MADISON, MS 39110

REMITTANCE STUB

ACCOUNT NUMBER: 16000060
 SERVICE ADDRESS: 104 CHARTRES DR

AMOUNT DUE **DRAFTEED**
 DUE DATE: **06/20/16**
 AMOUNT ENCLOSED: \$

Please make checks payable to: BEAR CREEK WATER ASSOCIATION



BEAR CREEK WATER ASSOCIATION
 PO BOX 107
 CANTON MS 39046-0107



0002386771



PO BOX 107 • CANTON, MS 39046 • www.bcwaterms.org

RECEIVED-WATER SUPPLY

2016 JUN -9 AM 9: 13

CUSTOMER SERVICE DEPARTMENT

(601) 856-5969 option #1


7:00 AM - 5:00 PM MONDAY-FRIDAY

WHEN PAYING THIS BILL IN PERSON, BRING BOTH PORTIONS OF THIS BILL

13971 1 AV 0.373 P:13971 / T:51 / S1:1 / S2:0



Tim / Christie Cooper
121 Brigade Ave
Canton MS 39046-8025



BILLED TO **TIM / CHRISTIE COOPER** SERVICE ADDRESS **121 BRIGADE AVE** BILL DATE **05/26/16**
 ACCOUNT NO. **18600055** DUE DATE **06/20/16** DELINQUENT AFTER **06/20/16**

METER NUMBER	READ DATE		BILLING DAYS	METER READINGS		USAGE
	PREVIOUS	PRESENT		PREVIOUS	PRESENT	
62899195	04/12	05/12	30	537500	547700	10200

DESCRIPTION	AMOUNT
PREVIOUS BALANCE	66.95
PAYMENTS	(66.95)
WATER	26.80
SEWER-CENTRAL	29.80
SW MCWWA	15.30

CCR is available at <http://www.msrrwa.org/2015ccr/bearcreek.pdf>
 YOU MAY REQUEST A HARD COPY BY CALLING 601-856-5969.

MESSAGE: TOTAL AMOUNT DUE: 71.90
 DUE DATE: 06/20/16
 AFTER DUE DATE PAY: 79.09

PLEASE SEPARATE REMITTANCE STUB AT THIS PERFORATION AND RETURN WITH PAYMENT



PO BOX 107 • CANTON, MS 39046 • www.bcwaterms.org

CHECK HERE FOR BILLING ADDRESS / PHONE CHANGES AND COMPLETE REVERSE SIDE.
(Note: Service addresses must be changed in office.)

TIM / CHRISTIE COOPER
121 BRIGADE AVE
CANTON, MS 39046

REMITTANCE STUB

ACCOUNT NUMBER: 18600055

SERVICE ADDRESS: 121 BRIGADE AVE

AMOUNT DUE **71.90**

DUE DATE: **06/20/16**

AMOUNT ENCLOSED \$

Please make checks payable to: BEAR CREEK WATER ASSOCIATION



BEAR CREEK WATER ASSOCIATION
PO BOX 107
CANTON MS 39046-0107



0002387328