

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2014

2016 JUN 13 AM 9:40

Mary Springs Water Assoc., Inc.
Public Water Supply Name

0030005

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: _____ / _____ / _____, _____ / _____ / _____, _____ / _____ / _____

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / _____ / _____

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: _____ / _____ / _____

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Southern Herald

Date Published: 06/02/16

CCR was posted in public places. *(Attach list of locations)*

Date Posted: _____ / _____ / _____

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Hal Holloway, asst Treasurer
Name/Title (President, Mayor, Owner, etc.)

6/10/16
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
water.reports@msdh.ms.gov

2015 Annual Drinking Water Quality Report **2016 JUN 14 AM 9: 05**
 Mary Springs Rural Water Association, Inc.
 PWS#: 0030005
 May 2016

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Miocene Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Mary Springs Rural Water Association have lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Gary Sterling at 601.657-0478. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of each month at 6:30 PM at the Gloster Public Library, 300 E. Main Street, Gloster, MS 39638.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	--------------------	------	-----	--------------------------------

Inorganic Contaminants

8. Arsenic	N	2014*	.6	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2014*	.0526	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	1.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2013*	.8	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2013*	3	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2015	.42	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection By-Products								
Chlorine	N	2015	1.2	1 – 1.3	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2015

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Mary Springs Rural Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Notice: This report will not be mailed out to each customer, however a copy may be obtained at our office.

2016 JUN 13 AM 9:40

PROOF OF PUBLICATION

STATE OF MISSISSIPPI

COUNTY OF AMITE

PERSONALLY CAME before me, the undersigned, a notary public in and for the state aforesaid, the

Quality Report
Company, Inc.

undersigned agent of THE SOUTHERN HERALD, a newspaper published in the Town of Liberty, Amite County, Mississippi, who, being duly sworn, deposes and says that THE SOUTHERN HERALD is a newspaper as defined and prescribed in Section 13-3-3, Mississippi Code of 1972, and that the publication of

inform you about the quality water and services we deliver to you every day. Our understand the efforts we make to continually improve the water treatment process

is from wells drawing from the Miocene Series Aquifers. The susceptibility of its drinking water supply to identify potential sources of contamination has been furnished to our public water system and is available for viewing upon examination.

calling at 601-657-0478. We want our valued customers to be informed about their rights on the second Monday of each month at 6:30 PM at the Gloster Public Library,

The table below lists all of the drinking water contaminants that we detected during 2015, the table reflects the most recent results. As water travels over the surface of the ground and can pick up substances or contaminants from the presence of animals or plants, treatment plants, septic systems, agricultural livestock operations, and wildlife; storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, agriculture, urban storm-water runoff, and residential uses; organic chemical refineries and petroleum production, and can also come from gas stations and septic systems. In order to ensure that tap water is safe to drink, the presence of these constituents does not necessarily indicate that the water poses a

to better understand these terms we've provided the following definitions: Maximum Contaminant Level (MCL) is the maximum level of a contaminant which a water system must follow.

Maximum Contaminant Level Goal (MCLG) is the maximum level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as

practicable and secondary to the MCLGs. MCLGs allow for a margin of safety by setting MCLs at a level below which there is no known or expected risk to health. MCLGs allow for a margin of safety by setting MCLs at a level below which there is no known or expected risk to health.

MRDLGs do not reflect the additional health margin provided by the disinfection process. There is convincing evidence that addition of a disinfectant is necessary for all public water systems.

For example, the MCL for lead is set at 0.01 milligrams per liter (one part per million) because of the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

The MCL for lead is based on the health effects of lead in drinking water. The MCL for lead is based on the health effects of lead in drinking water.

2015 ANNUAL DRINKING WATER QUALITY REPORT
MARY SPRINGS WATER ASSOCIATION, INC.
PWS ID#003C005
MAY 2016

of which the annexed is a copy, has been made in said paper 1 times consecutively, to-wit:


- On the 02 day of JUNE, 2016
- On the _____ day of _____, 2016
- On the _____ day of _____, 2016
- On the _____ day of _____, 2016

[Handwritten Signature]

Publisher

SWORN TO and subscribed before me, this

02 day of JUNE, 2016



Notary Public

My Commission Expires: MARCH 6, 2019

1,800 Words @ 12 ¢ ----- \$216.00
Making Proof of Publication --- 0.00

TOTAL ----- \$216.00

g water meets or exceeds all Federal and State requirements. We have learned ermined that your water IS SAFE at these levels.

of regular monitoring are an indicator of whether or not our drinking water meets is systems of any missing samples prior to the end of the compliance period.

and young children. Lead in drinking water is primarily from materials and comiding high quality drinking water, but cannot control the variety of materials used

ential for lead exposure by flushing your tap for 30 seconds to 2 minutes before a your water tested. Information on lead in drinking water testing methods and

LEGALS CONTINUED FROM PAGE 2

2014 Annual Drinking Water Quality Report
Mary Spring Rural Water Association, Inc.
PWS ID#: 0030005
May 2016

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Miocene Series Aquifers. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water supply and is available for viewing upon request. The wells for the Mary Springs Rural Water Association have lower susceptibility ranking to contamination. If you have any questions about this report or concerning your water utility, please contact Gary Sterling at 601-657-0478. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of each month at 6:30 PM at the Gloster Public Library, 300 E. Main Street, Gloster, MS 39638.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:
Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/L) - one part per million corresponds to one minute in two years or a single penny in \$10,000.
Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2014*	.6	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2014*	.0526	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	1.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2013*	.8	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2013*	3	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
19 Nitrate (as Nitrogen)	N	2014	.42	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection By-Products								
Chlorine	N	2015	1.2	1-1.8	mg/l	0	MDRL=4	Water additive used to control microbes

*Most recent sample. No sample required for 2015.

As you can see by the table, our system had no contaminate violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels. We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Mary Springs Rural Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Notice: This report will not be mailed out to each customer, however a copy may be obtained at our office.

OFFICE OF STATE AID ROAD CONSTRUCTION
MISSISSIPPI DEPARTMENT OF TRANSPORTATION
AND
AMITE COUNTY BOARD OF SUPERVISORS
SECTION 900

NOTICE TO CONTRACTORS:


Sealed bids will be received by the Board of Supervisors of Amite County, Mississippi at the Amite County

IN THE CHANCERY COURT OF AMITE COUNTY, MISSISSIPPI
IN THE MATTER OF THE ESTATE
OF JERRY ALTON DAVIS, DECEASED

RULE 81 SUMMONS BY PUBLICATION
THE STATE OF MISSISSIPPI
TO: Known and Unknown Heirs-at-Law Jerry Alton Davis, Known

NO.2016-0091

LIBERTY D STORE



WE WORK W YOUR DOCT
We follow doctor's c
the letter. Your pres
and your health dep
our reliable, accurate

CALL ON I
657-80.

SEE: Ronnie Blak
Matthew Bl
Registered Pharma
for all your
pharmaceutical ne

MAIN STREE
LIBERTY, M

IN THE CHANCERY CO
AMITE COUNTY, MISS
IN THE MATTER C
ESTATE OF MARY
BROWN DAVIS, DECEA
NO.21

RULE 81 SUMMONS
BY PUBLICATION

THE STATE OF MISSISSIPPI
TO: Known and Unknown
at-Law Mary Alice Brow
Known and Unknown I
Law of Mary Ann Davis I

You have been n
Defendant in the suit file
Court by Deborah
Taylor, Plaintiff(s) seeking
the Last Will and Testa
Mary Alice Brown Davis to
insolenn form and deter
heirs-at-law of Mary An
Hamilton. Defendants othe
ou in this action are Willia
Davis, Frederick Hamilt
Joshua Hamilton, Peyton H.
a minor, and Frederick H.
Sr.

You are summoned to
and defend against the cc
or petition filed against yo
action at 9:00 o'clock a
the 22nd day of July, 2016
courtroom of the Amite
Courthouse at Liberty, Miss
and in case of your fail
appear and defend adjudgm
be entered against you I
money or other things den
in the complaint captioned.

You are not required to
answer or other pleading t
may do so if you desire.

Issued under my hand s
seal of said Court, this 26th
May, 2016.

/s/ Deanne
JANA CAUSEY, Ch
Clerk of Amite County, Miss
(Seal)
Publish: June 2, 9, 16, 23, 2016

8. God won't ask abo
color of your skin. He'l
about the content of your
acter.

RECEIVED-WATER SUPPLY
2016 JUN 13 AM 9:40