

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY

2016 JUN 15 AM 8:56

CCR CERTIFICATION
CALENDAR YEAR 2015Lewisburg Water Association / Ingram Mills
Public Water Supply Name0170011 + 0170049

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
 On water bills (attach copy of bill)
 Email message (MUST Email the message to the address below)
 Other website Lewisburg Water Association.com

Date(s) customers were informed: 6/17/16, 6/1/16, 05/30/16

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ____ / ____ / ____

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: ____ / ____ / ____

- As a URL (Provide URL _____)
 As an attachment
 As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*Name of Newspaper: Desoto Times TribuneDate Published: 6/17/16CCR was posted in public places. *(Attach list of locations)*Date Posted: 6/1/16CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):http://Lewisburgwaterassociation.com/water-quality-report**CERTIFICATION**

I hereby certify that the 2015 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health/Bureau of Public Water Supply.

Yara Caldwell Office Manager
 Name/Title (President, Mayor, Owner, etc.)

6-10-16
 Date

Deliver or send via U.S. Postal Service:
 Bureau of Public Water Supply
 P.O. Box 1700
 Jackson, MS 39215

May be faxed to:
 (601)576-7800

May be emailed to:

water.reports@msdh.ms.gov

CCR Due to MSDH & Customers by July 1, 2016!

2016 MAY 18 PM 4: 22

2015 Annual Drinking Water Quality Report
 Lewisburg Water Association/Lewisburg-Ingram Mill North
 PWS#: 0170011 & 0170049
 April 2016

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand & Winona Tallahassie/Winona Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Lewisburg Water Association have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Barry Caldwell at 901.488.7161. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the annual meeting scheduled for Thursday November 10, 2016 at 6:00 PM at the Lewisburg Water Office located at 2787 HWY 305, Olive Branch.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID # 0170011		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

Inorganic Contaminants									
10. Barium	N	2014*	.0157	.0147 - .0157	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
13. Chromium	N	2014*	1.5	.7 - 1.5	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits	
14. Copper	N	2014/16	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
16. Fluoride	N	2014*	.981	.929 - .981	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
17. Lead	N	2014/16	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits	
19. Nitrate (as Nitrogen)	N	2015	.36	.35 - .36	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
Disinfection By-Products									
Chlorine	N	2015	1	1 - 1	mg/l	0	MDRL = 4	Water additive used to control microbes	

PWS ID # 0170049 TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCL G	MCL	Likely Source of Contamination	
Inorganic Contaminants									
10. Barium	N	2014*	.0091	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
14. Copper	N	2013/15	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
16. Fluoride	N	2014*	9.34	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
17. Lead	N	2013/16	12	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits	
19. Nitrate (as Nitrogen)	N	2015	.36	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
Disinfection By-Products									
81. HAA5	N	2014*	.9	No Range	ppb	0	60	By-Product of drinking water disinfection.	
82. TTHM [Total trihalomethanes]	N	2014*	2.96	No Range	ppb	0	80	By-product of drinking water chlorination.	
Chlorine	N	2015	1.1	1 - 1.09	mg/l	0	MDRL = 4	Water additive used to control microbes	

* Most recent sample. No sample required for 2015.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the LEWISBURG WATER ASSOCIATION is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 83%.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the LEWISBURG -INGRAMS MILL NORTH is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 92%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Lewisburg Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

AFFP

PN: Water Quality Report

Affidavit of Publ

DESOTO TIMES-TRIBUN

STATE OF MS }
COUNTY OF DESOTO }

IFIEDS

TUESDAY, JUNE 7, 2016 15

Diane Smith, being duly sworn,

That she is a Clerk of the DESO
newspaper of general circulatio
in Hernando, DeSoto County, N
copy of which is printed hereon,
newspaper on the following date

June 07, 2016

That said newspaper was regul
on those dates.

SIGNED:

Clerk

Subscribed to and sworn to me

KIMBERLY BEVINEAU, Notary,

My commission expires: Januar

00002349 00044362

Terry
Lewisburg Water Association
P.O. Box 1309
Olive Branch, MS 38654

2015 Annual Drinking Water Quality Report Lewisburg Water Association/Lewisburg-Ingram Mill North PWS#: 0170011 & 0170049 April 2016

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand & Winona Tallahassee/Winona Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Lewisburg Water Association have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Barry Caldwell at 901.488.7161. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the annual meeting scheduled for Thursday November 10, 2016 at 6:00 PM at the Lewisburg Water Office located at 2787 HWY 305, Olive Branch.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st - 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID # 0170011		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2014*	.0157	.0147 - .0157	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	1.5	.7 - 1.6	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2014/16	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014*	.981	.929 - .981	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2014/16	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2015	.36	.35 - .36	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection By-Products								
Chlorine	N	2015	1	1 - 1	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID # 0170049		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination

Kimberly B
 KIMBERLY BEVINEAU, Notary.

My commission expires: January

00002349 00044362

Terry
 Lewisburg Water Association
 P.O. Box 1309
 Olive Branch, MS 38654

evidence that addition of a disinfectant is necessary to control the risk of disease.
Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.
Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID # 0170011										TEST RESULTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/AQL	Unit Measurement	MCLG	MCL	Likely Source of Contamination					
Inorganic Contaminants													
10. Barium	N	2014*	.0157	.0147 - .0157	ppm		2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits				
13. Chromium	N	2014*	1.5	.7 - 1.5	ppb		100	100	Discharge from steel and pulp mills; erosion of natural deposits				
14. Copper	N	2014/16	.1	0	ppm		1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives				
16. Fluoride	N	2014*	.981	.929 - .981	ppm		4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories				
17. Lead	N	2014/16	2	0	ppb		0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits				
19. Nitrate (as Nitrogen)	N	2015	.36	.35 - .36	ppm		10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits				
Disinfection By-Products													
Chlorine	N	2015	1	1 - 1	mg/l		0	MDRL = 4	Water additive used to control microbes				

PWS ID # 0170049										TEST RESULTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/AQL	Unit Measurement	MCLG	MCL	Likely Source of Contamination					
Inorganic Contaminants													
10. Barium	N	2014*	.0091	No Range	ppm		2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits				
14. Copper	N	2013/15	.1	0	ppm		1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives				
16. Fluoride	N	2014*	9.34	No Range	ppm		4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories				
17. Lead	N	2013/16	.12	0	ppb		0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits				
19. Nitrate (as Nitrogen)	N	2015	.36	No Range	ppm		10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits				
Disinfection By-Products													
81. HAA5	N	2014*	.9	No Range	ppb		0	80	By-Product of drinking water disinfection				
82. TTHM [Total trihalomethanes]	N	2014*	2.96	No Range	ppb		0	80	By-product of drinking water chlorination				
Chlorine	N	2015	1.1	1 - 1.09	mg/l		0	MDRL = 4	Water additive used to control microbes				

* Most recent sample. No sample required for 2015.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7562 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the LEWISBURG WATER ASSOCIATION is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 83%.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the LEWISBURG -INGRAMS MILL NORTH is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 92%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Lewisburg Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

CCR will not be mailed out to all customers. You can pick-up a copy at the water office located at 2787 Hwy 305. Or you may contact the office at (662) 895-6022 to request that a copy be mailed to you.

RECEIVED-WATER SUPPLY
 2016 JUN 15 AM 8:57

AFFP

PN: Water Quality Report

2016 JUN 15 AM 8:57

Affidavit of Publication

DESOTO TIMES-TRIBUNE

STATE OF MS }
COUNTY OF DESOTO }

SS

LEWISBURG WATER QUALITY

Diane Smith, being duly sworn, says:

That she is a Clerk of the DESOTO TIMES-TRIBUNE, a newspaper of general circulation in said county, published in Hernando, DeSoto County, MS; that the publication, a copy of which is printed hereon, was published in the said newspaper on the following dates:

June 07, 2016

That said newspaper was regularly issued and circulated on those dates.

SIGNED:

Diane Smith
Clerk

Subscribed to and sworn to me this 7th day of June 2016.

Kimberly Bevineau
KIMBERLY BEVINEAU, Notary, DeSoto County, MS

My commission expires: January 18, 2020

00002349 00044362

Terry
Lewisburg Water Association
P.O. Box 1309
Olive Branch, MS 38654



2016 JUN 15 AM 8:57

LEWISBURG WATER
ASSOCIATION
P.O. BOX 1309
OLIVE BRANCH, MS 38654
662-895-6022

WATER BILL

PLEASE RETURN THIS TOP PORTION
WITH YOUR PAYMENT. WHEN PAYING
IN PERSON, PLEASE BRING BOTH PORTIONS
OF BILL WITH YOU.

ACCOUNT	
003431	
BILL DATE	DUE DATE
05/31/16	06/20/16
PAY BY DUE DATE	PAY AFTER DUE DATE
33.84	37.02

2015 Annual Drinking Water Quality Report is now available at the water office, online at lewisburgwaterassociation.com, or it will run in the DeSoto Times Tribune on June 7, 2016. Copies will not be mailed unless requested by calling (662) 895-6022.

MICHAEL CARROLL
10057 WOOLSEY RD
OLIVE BRANCH, MS 38654-

Copy of notice on bills.

CCR is displayed inside lobby of water office
and outside in bulletin board.