

MISSISSIPPI STATE DEPARTMENT OF HEALTH AM 10: 15  
BUREAU OF PUBLIC WATER SUPPLY

CCR CERTIFICATION  
CALENDAR YEAR 2015

Hub Water Association  
Public Water Supply Name

# 460008

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other \_\_\_\_\_

Date(s) customers were informed: 06/30/2016 / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_\_\_ / / N/A

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: \_\_\_\_\_ / / N/A

- As a URL (Provide URL \_\_\_\_\_)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)* N/A

Name of Newspaper: \_\_\_\_\_

Date Published: \_\_\_\_\_ / /

CCR was posted in public places. *(Attach list of locations)* Date Posted: \_\_\_\_\_ / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

http://www.msrgwa.org/2015ccr/hub.pdf

**CERTIFICATION**

I hereby certify that the 2015 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Lori Baker, Vice President  
Name/Title (President, Mayor, Owner, etc.)

6-30-16  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601)576-7800

May be emailed to:

water.reports@msdh.ms.gov

**CCR Due to MSDH & Customers by July 1, 2016!**

2014 Annual Drinking Water Quality Report  
 Hub Water Association  
 PWS#: 460008  
 June 2015

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Miocene Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Hub Water Association have received a lower to moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Ken Foster at 601.441.9284. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meetings scheduled for the first Saturday of May at 2:00 PM at the Hub Water Office, HWY 13 S.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2015. In cases where monitoring wasn't required in 2015 the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Microbiological Contaminants</b>								
1. Total Coliform Bacteria	Y	July	Positive	3	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment

## Radioactive Contaminants

5. Gross Alpha	N	2012*	4.1	1 - 4.1	pCi/L	0	15	Erosion of natural deposits
----------------	---	-------	-----	---------	-------	---	----	-----------------------------

## Inorganic Contaminants

10. Barium	N	2012*	.040	.004 - .040	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2012*	3.71	2 - 3.71	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2012*	.225	.175 - .225	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

## Disinfection By-Products

Chlorine	N	2015	1.2	.6 - 1.8	mg/l	0	MDRL = 4	Water additive used to control microbes
----------	---	------	-----	----------	------	---	----------	---

\* Most recent sample. No sample required for 2015.

### Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

We routinely monitor for the presence of drinking water contaminants. We took 3 samples for coliform bacteria during July 2015. Three of the samples showed the presence of coliform bacteria. The standard is that no more than 1 sample per month of our samples may do so. We did not find any bacteria in our subsequent testing and further testing shows that this problem has been solved.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Hub Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

16

ink mailing

8  
Stamps

=====

COLUMBIA  
815 MAIN ST  
COLUMBIA  
MS  
39429-9998  
2716770429  
06/29/2016 (800)275-8777 12:02 PM

=====

Product Description	Sale Qty	Final Price
US Flag Coil/100 (Unit Price:\$47.00)	1	\$47.00
Cust Permit Dep (Permit Type:Permit Imprint) (Permit Number:32) (Permit Acct Number:1573203) (Customer Name:HUB WATER ASSOCIATION) (Previous Balance:\$0.00)		\$331.82

Total \$378.82

Personl/Bus Check \$378.82

\*\*\*\*\*  
BRIGHTEN SOMEONE'S MAILBOX. Greeting cards available for purchase at select Post Offices.  
\*\*\*\*\*

Order stamps at [usps.com/shop](http://usps.com/shop) or call 1-800-Stamp24. Go to [usps.com/clicknship](http://usps.com/clicknship) to print shipping labels with postage. For other information call 1-800-ASK-USPS.

<b>USPS Use Only</b> To be completed in non-Postal/One/ sites	Weight of a Single Piece _____ pound		Are postage figures at left adjusted from mailer's entries? If yes, reason: <input type="checkbox"/> Yes <input type="checkbox"/> No		<b>USPS Use Only</b> To be completed in non-Postal/One/ sites
	Total Pieces	Total Weight	Round Stamp (Required) Payment Date		
	Total Postage				
	Presort Verification Performed? (if required) <input type="checkbox"/> Yes <input type="checkbox"/> No (Check one)		Date Mailer Notified	Contact	
	I CERTIFY that this mailing has been inspected for each item below if required: (1) eligibility for postage prices claimed; (2) proper preparation (and presort where required); (3) proper completion of postage statement; (4) payment of annual fee; and (5) sufficient funds on deposit (if required)		By (Initials)	Time AM PM	
USPS Employee's Signature		Print USPS Employee's Name			

**IMPORTANT NOTICE FOR PAST DUE ACCOUNTS:**

Past due accounts must be paid by the 10<sup>th</sup> of the month or will be disconnected. If your service is disconnected for nonpayment you must pay the following to have your service restored: **past and present amounts due, restoration fee of \$50 for first offense or \$100 for repeat offender** and you must bring your deposit up-to-date which is \$100 for home owner or \$150 for renter or owner of mobile home.

**Important information about your drinking water is available in the 2015 Consumer Confidence Report at:**

<http://www.msrrwa.org/2015ccr/hub.pdf>

**You may request a hard copy by checking this box**   
**or by calling our office at 601-736-0019**

**IMPORTANT NOTICE FOR PAST DUE ACCOUNTS:**

Past due accounts must be paid by the 10<sup>th</sup> of the month or will be disconnected. If your service is disconnected for nonpayment you must pay the following to have your service restored: **past and present amounts due, restoration fee of \$50 for first offense or \$100 for repeat offender** and you must bring your deposit up-to-date which is \$100 for home owner or \$150 for renter or owner of mobile home.

**Important information about your drinking water is available in the 2015 Consumer Confidence Report at:**

<http://www.msrrwa.org/2015ccr/hub.pdf>

**You may request a hard copy by checking this box**   
**or by calling our office at 601-736-0019**

**IMPORTANT NOTICE FOR PAST DUE ACCOUNTS:**

Past due accounts must be paid by the 10<sup>th</sup> of the month or will be disconnected. If your service is disconnected for nonpayment you must pay the following to have your service restored: **past and present amounts due, restoration fee of \$50 for first offense or \$100 for repeat offender** and you must bring your deposit up-to-date which is \$100 for home owner or \$150 for renter or owner of mobile home.

**Important information about your drinking water is available in the 2015 Consumer Confidence Report at:**

<http://www.msrrwa.org/2015ccr/hub.pdf>

**You may request a hard copy by checking this box**   
**or by calling our office at 601-736-0019**

**IMPORTANT NOTICE FOR PAST DUE ACCOUNTS:**

Past due accounts must be paid by the 10<sup>th</sup> of the month or will be disconnected. If your service is disconnected for nonpayment you must pay the following to have your service restored: **past and present amounts due, restoration fee of \$50 for first offense or \$100 for repeat offender** and you must bring your deposit up-to-date which is \$100 for home owner or \$150 for renter or owner of mobile home.

**Important information about your drinking water is available in the 2015 Consumer Confidence Report at:**

<http://www.msrrwa.org/2015ccr/hub.pdf>

**You may request a hard copy by checking this box**   
**or by calling our office at 601-736-0019**