

MISSISSIPPI STATE DEPARTMENT OF HEALTH 2016 JUN -2 AM 10: 50
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2015

Hide-A-Way Water System
Public Water Supply Name

SS 0013
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other Hide-A-Way Lake Estates (50 residential units) monthly newsletter (Bills and newsletters were mailed on 5/27/16)

Date(s) customers were informed: 5/27/2016, / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / _____ / _____

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: _____ / _____ / _____

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: _____ / _____ / _____

CCR was posted in public places. *(Attach list of locations)* Date Posted: 5/14/2016
4 copies available in office lobby of 5100 St. Lakeshore Drive Carrboro, MS 39426

CCR was posted on a publicly accessible internet site at the following address **(DIRECT URL REQUIRED)**:
http://www.haw.ms.com/F/CCR15.pdf

CERTIFICATION

I hereby certify that the 2015 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Bruce Dentler
Name/Title (President, Mayor, Owner, etc.)

5-30-16
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:

CCR Due to MSDH & Customers by July 1, 2016!

water.reports@msdh.ms.gov

2015 Drinking Water Quality Report

HIDE-A-WAY WATER SYSTEM

Jeff Robbins, Certified Water Operator
PWS ID #MS0550013 Pearl River County
510 E. LAKESHORE DR. CARRIERE, MS 39426
www.hawlms.com office@hawlms.net
601-798-1484

Is my water safe?

Last year, as in years past, your tap water met all U. S. Environmental Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water concerns. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Where does my water come from?

Our water comes from two (2) wells that draw ground water from the **Miocene Series Aquifer**.

Source water assessment and its availability:

Our source water assessment has been completed by the Mississippi State Department of Health. Copies will be made available upon request.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

How can I get involved?

Our board meets on the **second WEDNESDAY evening of every month. Meetings start at 6:30 p.m. at the Hide-A-Way Lake Club House.** We encourage all customers who have any concerns or questions to meet with us. Our association conducts its annual membership meeting on the third Saturday in July at 10:00 a.m. at the Hide-A-Way Lake Club House. This is a very important meeting in which all customers are encouraged to attend.

Other information:

You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address: <http://www.healthymms.com>. Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply may be obtained.

Water Quality Data Table

The following table lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA and the Mississippi State Department of Health requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data though representative of the water quality may be more than one year old.

Total Coliform

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present. All results showed all samples free of total coliform.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hide-A-Way Water System is responsible for providing high-quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601-576-7582 if you wish to have your water tested.

Terms and Abbreviations used in the Table

MCLG: *Maximum Contaminant Level Goal* - is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: *Maximum Contaminant Level* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: *Action Level* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ND: *Non-detect.*

TEST RESULTS

Contaminant	MCLG	MCL	Your Water	Sample Date	Violation Y/N	Likely Source of Contamination
Inorganic Contaminants						
Antimony (ppm) Well #2 Well #3	0.006 0.006	0.006 0.006	0.0005 0.0005	05/06/13 05/06/13	NO NO	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.
Arsenic (ppm) Well #2 Well #3	N/A	0.010 0.010	0.0005 0.0005	05/06/13 05/06/13	NO NO	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium (ppm) Well #2 Well #3	2 2	2 2	0.009 0.0065	05/06/13 05/06/13	NO NO	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits.
Beryllium (ppm) Well #2 Well #3	0.004 0.004	0.004 0.004	0.0005 0.0005	05/06/13 05/06/13	NO NO	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries.
Cadmium (ppm) Well #2 Well #3	0.005 0.005	0.005 0.005	0.0005 0.0005	05/06/13 05/06/13	NO NO	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints.
Chromium (ppm) Well #2 Well #3	0.1 0.1	0.1 0.1	0.0005 0.0005	05/06/13 05/06/13	NO NO	Discharge from steel and pulp mills; erosion of natural deposits.
Copper (mg/l)	1.3	AL= 1.3	0.1	01/01/12–12/31/14 (Triennial)	NO	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives. 12 samples collected.
Cyanide (ppm) Well #2 Well #3	0.2 0.2	.2 .2	0.015 0.015	06/15/15 06/15/15	NO NO	Discharge from steel/metal factories; discharge from plastic and fertilizer factories.
Fluoride (mg/l) Well #2 Well #3	4 4	4 4	0.235 0.203	05/06/13 05/06/13	NO NO	No fluoride is added to water system.
Haloacetic Acids (ppb) (HAA5) Well #2 and Well #3	N/A	60.0	13.0	08/26/13	NO	By-product of drinking water disinfection.
Lead (mg/l)	.015	AL = .015	0.001	01/01/12–12/31/14 (Triennial)	NO	Corrosion of household plumbing systems, erosion of natural deposits. 12 samples collected.
Mercury (inorganic) (ppm) Well #2 Well #3	0.002 0.002	0.002 0.002	0.0005 0.0005	05/06/13 05/06/13	NO NO	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland.
Nitrate (as Nitrogen) (ppm) Well #2 Well #3	10 10	10 10	0.08 0.08	04/20/15 04/20/15	NO NO	Runoff from fertilizer use; leaching from septic tanks, sewerage; erosion of natural deposits.
Nitrite (as Nitrogen) (ppm) Well #2 Well #3	1 1	1 1	0.02 0.02	04/20/15 04/20/15	NO NO	Runoff from fertilizer use; leaching from septic tanks, sewerage; erosion of natural deposits.
Selenium (ppm) Well #2 Well #3	0.05 0.05	0.05 0.05	0.0025 0.0025	05/06/13 05/06/13	NO NO	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
Thallium (ppm) Well #2 Well #3	0.0005 0.0005	0.002 0.002	0.0005 0.0005	05/06/13 05/06/13	NO NO	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories.
TTHM (Total trihalomethanes) (ppb) Well #2 and Well #3	N/A	80.0	22.50	08/26/13	NO	By-product of drinking water disinfection.
Disinfection By-Products						
Chlorine (mg/l)	4.0	4.0	1.00	01/01/15–12/31/15	NO	Water additive used to control microbes. MRDL range 0.50 MG/L to 1.50 MG/L.
Microbiological Contaminants	MCLG	MCL	Your Water	Sample Date	Violation Y/N	Likely Source of Contamination
# Total Coliform	0	>1	ND	Monthly	NO	Naturally present in the environment

Units Description: (ppm): parts per million, or milligrams per liter (mg/l), (ppb): parts per billion, or micrograms per liter (µg/l), (pCi/l): picocuries per liter (a measure of radioactivity), % of monthly positive samples: Percent of samples taken monthly that were positive

STATEMENT

HIDE-A-WAY LAKE CLUB, INC.
 P.O. BOX 1011
 PICAYUNE MS 39466

(601) 798-1484 Ext. 0000

Date:	5/25/2016
Account:	[REDACTED]

Amount Due: \$306.41

Due Date: 06/25/2016

Amount Paid: _____

Check Number: _____

Phone #: [REDACTED]

[REDACTED]
 [REDACTED]
CARRIERE MS 39426

^Please return this portion with your payment^

Document No.	Date	Code	Description	Amount	Balance
	4/25/2016	BBF		\$177.87	\$177.87
R-36588	5/5/2016	SLS	REST SALE	\$77.37	\$255.24
NT000000000180883	5/18/2016	PMT		(\$177.87)	\$77.37
[REDACTED] 5/25/2016M1	5/25/2016	SLS	847930-835950=11980 WATER	\$29.31	\$106.68
[REDACTED] 5/25/2016PF	5/25/2016	SLS	Sewage Processing Fee	\$1.00	\$107.68
[REDACTED] 5/25/2016S	5/25/2016	SLS	847930-835950=11980 SEWAGE	\$56.69	\$164.37
[REDACTED] BOAT-SLIP0000025	5/25/2016	SLS	BOAT SLIP RENTAL	\$25.00	\$189.37
[REDACTED] CAP-RSV000000162	5/25/2016	SLS	CAPITAL RESERVE	\$15.00	\$204.37
[REDACTED] GAR-FEE000000164	5/25/2016	SLS	GARBAGE FEE	\$10.65	\$215.02
[REDACTED] OP-FEE000000164	5/25/2016	SLS	OPERATIONAL FEE	\$56.39	\$271.41
[REDACTED] SEC-FEE000000164	5/25/2016	SLS	SECURITY FEE	\$5.00	\$276.41
O-15178	5/25/2016	SLS	BOAT DECALS	\$30.00	\$306.41

Amount Due: \$306.41

·2015 Drinking Water Quality Report (CCR 2015) is now available in the HAWL office, upon request, & online (<http://www.hawlms.com/f/CCR15.pdf>).

HIDE-A-WAY LAKE CLUB, INC.

Lot #: [REDACTED]

Date: **5/25/2016**

Current	1 - 30 Days	31 - 60 Days	61 and Over			
\$306.41	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00	\$0.00

Codes: SLS = Sales / Invoices FIN = Finance Charges CR = Credit Memos
 SCP = Scheduled Payments SVC = Service / Repairs RTN = Returns
 DR = Debit Memos WRN = Warranties PMT = Cash Receipts

CCR 2015
Put on web
on 5-4-2016

Water System - Internet Explorer
http://www.hawms.com/water-system.html

Hide-A-Way Lake Club, Inc.

Water System

- Home
- Messages/Join our Club
- Members
- Newsletters
- Restrooms
- Board of Directors
- Committees
- Announcements
- Visit HAWL Community
- Events
- Picket Albums
- Building Codes
- Social Clubs
- Hours of Operation
- Security Corner
- Contact Us
- HAWL Stomach Issues
- HAWL Staff
- Maps of HAWL
- HAWL Calendar of Events
- Memorial Tree Fund
- Forms
- Water System

Hide-A-Way Water System Customer Service Policies and Ordinances

- [2011 Drinking Water Quality Report \(CCR 11\)](#)
- [2012 Drinking Water Quality Report \(CCR 12\)](#)
- [2013 Drinking Water Quality Report \(CCR 13\) - corrected](#)
- [2014 Drinking Water Quality Report \(CCR 14\)](#)
- [2015 Drinking Water Quality Report \(CCR 15\)](#)

Hide-A-Way Lake Club, Inc. • 601-798-1484 • Fax 601-798-0604
P.O. Box 1011 • Picayune, MS 39466

http://www.hawms.com/CCR15.pdf - Internet Explorer
http://www.hawms.com/CCR15.pdf

2015 Drinking Water Quality Report

HIDE-A-WAY WATER SYSTEM

Jeff Robbins, Certified Water Operator
PWS ID #MS0550013 Pearl River County
510 E. LAKESHORE DR. CARRIERE, MS 39426
www.hawms.com office@hawms.net
601-798-1484

Is my water safe?

Last year, as in years past, your tap water met all U. S. Environmental Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections.



Hide-A-Way Lake Club, Inc.

[Home](#)

Water System

[Message from the GM](#)

[Bulletin](#)

[Hide-A-Way Water System Customer Service Policies and Ordinances](#)

[Newsletters](#)

[2011 Drinking Water Quality Report \(CCR 11\)](#)

[Restaurant](#)

[2012 Drinking Water Quality Report \(CCR 12\)](#)

[Board of Directors](#)

[2013 Drinking Water Quality Report \(CCR 13\) - corrected](#)

[Committees](#)

[2014 Drinking Water Quality Report \(CCR 14\)](#)

[Amenities](#)

[2015 Drinking Water Quality Report \(CCR 15\)](#)

[Video - HAWL
Community](#)

**Hide-A-Way Lake Club, Inc. * 601-798-1484 * Fax 601-798-0604
P.O. Box 1011 * Picayune, MS 39466**

[Events](#)

[Photo Albums](#)

[Building Codes](#)

[Social Clubs](#)

[Hours of Operation](#)

[Security Corner](#)

[Contact Us](#)

[HAWL Informational
Links](#)

[HAWL Staff](#)

[Maps of HAWL](#)

[HAWL Calendar of
Events](#)

[Memorial Tree Fund](#)

[Forms](#)

[Water System](#)

www.hawlms.com/f/CCR15.pdf


The screenshot shows an Internet Explorer browser window with the address bar displaying "http://www.hawlms.com/f/CCR15.pdf". The page content is a PDF report with the following text:

2015 Drinking Water Quality Report
HIDE-A-WAY WATER SYSTEM
Jeff Robbins, Certified Water Operator
PWS ID #MS0550013 Pearl River County
510 E. LAKESHORE DR. CARRIERE, MS 39426
www.hawlms.com office@hawlms.net
601-798-1484

Is my water safe?
Last year, as in years past, your tap water met all U. S. Environmental Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. We vigilantly safeguard our water supply and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?
Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These

The browser's taskbar at the bottom shows the Start button, several application icons, and the system tray with the time 3:52 PM and date 5/4/2016.



HIDE-A-WAY LAKE ECHOES

June 2016

Boat and Golf Cart Decals

As of June 1, 2016, gold decals are no longer valid. Please note, only golf carts that are members of Millbrook may use the HAWL golf gate. While on the lake, please be aware of all HAWL boating rules, including (but not limited to):

- Any boat in use without a current decal will be issued a security citation and must cease operation.
- When boating, always put safety first.
- All boat traffic must travel in a counter-clockwise direction on the open lake.
- All watercraft shall operate at idle speed in marked "No Wake" areas and within 100' adjacent to the shoreline in the open lake.
- There shall be at least two legal persons in any boat which is towing a water skier.
- Decals must be visible from each side of the boat.
- Glass containers are prohibited while on the lake.
- Don't litter; help keep HAWL beautiful.



Deck Party



August 13, 2016 7:00 pm - 10:00 pm

Ready to dance the night away?

Join us at Waters Edge for our summer Deck Party! Entertainment will be provided by the Dixie Soul Band. The cost to attend is only \$15 per person, which includes set-ups only. Call the HAWL Office at 601-798-1484 and reserve your spot today!

You Asked For It, You Got It!



Hide-A-Way Lake t-shirts are now on sale in the HAWL office. The proceeds from the sale of these t-shirts will be used to fund community events. T-shirts can be purchased at a cost of \$16 and are available in orange, gray, pink, and yellow, with sizes ranging from small to extra large. Please note, these t-shirts **can be** charged to the property owner's account. For more information, call the HAWL office at 601-798-1484.



FREE Snowball Day!



Be sure to stop by the lower level of the Lodge on Saturday, June 11th from 2:00 pm - 4:00 pm for a delicious snowball, which will be FREE!!!

Swimming Lessons



June 13th - June 24th Monday-Friday

8:00 am to 8:45 am	6 to 8 years of age
9:00 am to 9:45 am	Tots to 5 years of age
10:00 am to 10:45 am	9 years of age and older

Cost: \$100

*Class times could change due to participation level.
 *Children must be accompanied by a parent. Please call the office at 601-798-1484 for information and to sign up. (Lesson fees are non-refundable, as space is limited. Fees will be charged to the property owners' accounts. Non-Property Owners must pay in cash, which is due before the first day of class).

Father's Day Buffet



Sunday, June 19, 2016

11:30 am - 1:00 pm or 1:30 pm - 3:00 pm

The buffet will include:

Carved Roast Beef, Bronzed Catfish, Fried Chicken, Vegetables, Soup, Salad Bar, Desserts, and Much More!

The cost of the buffet is \$18.99 for adults, \$8.99 for children 12 and under, and FREE for children 4 and under. Please call the office at 601-798-1484 to make your reservations.

The 2015 Drinking Water Report

(CCR 2015) for HAWL's water system is now available. This report is on our website under the "Water System" tab and can be found at

<http://www.hawlms.com/f/CCR15.pdf>.

Copies are also available in the HAWL office.

Additionally, you may also call the office (601-798-1484) to request that a copy be mailed to you.

2016 JUN -2 AM 10:50

Channeled Applesnails

These snails have been in our lake for over 20 years. The problem with the snails is the ecological damage they can cause, which threatens the marine life of our lake. The first visible signs are usually the egg clusters (pictured on the right), which are bright pink clumps of 200-600 tiny eggs attached to a tree, stump, pilings, or other objects at the water line. If you see these egg clusters, please **scrape them off into the water** where they cannot hatch. This will help reduce the population.



It's summertime! And that means the Lakeview Library, which is located in the downstairs area of the Lodge, could use some more childrens books. If interested in donating any books, simply drop them off at the Lodge.

RECEIVED - WATER SUPPLY