

2016 JUL 14 PM 2:11

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2015

Tony of ISO/A
Public Water Supply Name

0270003

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: ___ / ___ / ___ , ___ / ___ / ___ , ___ / ___ / ___

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ / ___

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ___ / ___ / ___

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Belzoni Banner

Date Published: 06/22/16

CCR was posted in public places. *(Attach list of locations)* Date Posted: ___ / ___ / ___

CCR was posted on a publicly accessible internet site at the following address **(DIRECT URL REQUIRED)**: _____

CERTIFICATION

I hereby certify that the 2015 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Mayor Bobbie Miller (Signature)
Name/Title (President, Mayor, Owner, etc.)

6/30/16
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601) 576-7800

May be emailed to:

water.reports@msdh.ms.gov

CCR Due to MSDH & Customers by July 1, 2016!

02100003

Annual Water Quality Report

Year of Issue

2015 (2016)

Report Date

This report is designed to provide you with information on the quality of the water we deliver to you every day. Our current goal is to provide you with the highest quality of drinking water.

Water quality information may improve over time. For more information, contact the Town of Green City at 707-255-1234.

In the past year, your tap water met all U.S. Environmental Protection Agency (EPA) and state health standards. Local Water Vigilantly safeguards its water supplies and once again we report that our system has not violated a maximum contaminant level or any other water quality standard.

Where does the water come from?

Water source

How is the water treated?

How often are the water meters checked?

How often are the water meters checked?

How often are the water meters checked at the Town Hall every first Tuesday at 4:00p.m.

Water Quality Data Table

This table lists all of the drinking water contaminants that we detected during the calendar year of 2015. Contaminants in the water does not necessarily indicate that the water poses a health risk. For more information on this table is from testing done in the calendar year of 2015. This table requires us to monitor for certain contaminants less than once per year. Contaminants do not change frequently.

For more information please contact the Town of Green City

Contaminant (MCL)	0.0	0.25	0.50	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0	5.5	6.0	6.5	7.0	7.5	8.0	8.5	9.0	9.5	10.0
-------------------	-----	------	------	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	------

Copper, action level in consumer tap (ppm)

1.3

1.5

2.0

2.5

3.0

3.5

4.0

4.5

5.0

Lead, action level in consumer tap (ppb)

0.015

0.015

0.015

0.015

0.015

0.015

0.015

0.015

0.015

Barium

2ppm

2ppm

2ppm

2ppm

2ppm

2ppm

2ppm

2ppm

2ppm

Chromium

0.1ppm

0.1ppm

0.1ppm

0.1ppm

0.1ppm

0.1ppm

0.1ppm

0.1ppm

0.1ppm

Phosphate

4ppm

4ppm

4ppm

4ppm

4ppm

4ppm

4ppm

4ppm

4ppm

For more information please contact the Town of Green City

On 01-16-2016, the Mississippi State Department of Health cited the following violations:

1. The South Street Well is too close to the old abandon well and has not been properly sealed. The abandon well must be sealed to stop production of surface water, rain water etc.

Corrective Action

1. The well was properly sealed by MSDH to reduce contamination with surface water. The well was properly sealed after the deficiency will have been corrected. For more info call (601) 576-7311.

Parameter	Value	Standard	Exceeds Standard	Notes				
Chlorine (as Cl2)	0.30	1.10	0.60	0.3	1.10	2015	No	Water additive used to control microbes
TTHBs (Total Trihalomethanes)	4	4	0.4	0.4	0.4	2015	No	By-product of drinking water disinfection

Parameter	Value	Standard	Exceeds Standard	Notes			
Corrosion of household plumbing systems; Erosion of natural deposits	1.3	1.3	0.013	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Corrosion of household plumbing systems; Erosion of natural deposits	0	15	1	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Corrosion of household plumbing systems; Erosion of natural deposits	2ppm	0.0079ppm	0	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Corrosion of household plumbing systems; Erosion of natural deposits	0.1ppm	0.0005ppm	0	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Corrosion of household plumbing systems; Erosion of natural deposits	0ppm	0.139ppm	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Water Quality Data Table

The table below lists all of the drinking water contaminants that are detected during the year. Laboratory often leaded for the \$10 per sample. The table below lists all of the drinking water contaminants that are detected during the year. Laboratory often leaded for the \$10 per sample. The table below lists all of the drinking water contaminants that are detected during the year. Laboratory often leaded for the \$10 per sample.

Parameter	Value	Standard	Exceeds Standard	Notes				
Chlorine (as Cl2)	0.40	0.90	0.7	0.40	0.90	2015	No	Water additive used to control microbes
TTHBs (Total Trihalomethanes)	4ppb	4ppb	0	0	0	2015	No	By-product of drinking water disinfection

Parameter	Value	Standard	Exceeds Standard	Notes			
Corrosion of household plumbing systems; Erosion of natural deposits	0.1	1.3	0.1	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0.002	0.015	0.002	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Barium	2ppm	2ppm	0.0013ppm	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Chromium	0.1ppm	0.1ppm	0.0005ppm	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Fluoride	4ppm	4ppm	0.102ppm	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Water Quality Report

City of Madison

WQTR-001 02/20/01

Year 2000

This report is designed to inform you about the quality of your drinking water. Our consistent goal is to provide you with a safe and dependable supply of drinking water.

Each information very important section is called as all right possible. For favor tea case sampling for signature that provide feedback in information.

Each year, my system met all U.S. Environmental Protection Agency (EPA) and state health standards. Local officials regularly safeguard its water supplies and once again we report that our system has not violated a maximum contaminant level or any other water quality standard.

Where does my water come from?
Spain Sands Aquifer
Source water assessment and its availability
Yes, it will be at the local Town Hall
How can I get involved?
By attending your local meetings at the City Hall every first Tuesday at 4:00pm.

Water Quality Data Table

Below listed all of the drinking water contaminants that we detected during the calendar year of 2000. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Most of the data presented in this table is from testing done in the outdoor tap water. The EPA of the State requires us to monitor for certain contaminants less than once a year. The concentrations of these contaminants do not change frequently.

Water survey conducted on 01-08-2001, the Mississippi State Department of Health cited the following deficiency(9)
Major source of fecal contamination * The South Street Well is too close to the old abandoned well that may have not been properly sealed. The abandoned well must be sealed to stop infiltration of surface water, rain water etc.

CORRECTION ACTION

Abandoned well has been placed on a priority list by MSDH to receive assistance with sealing. The abandoned well has been properly sealed this deficiency will have been corrected. For more information call (601) 356-5518.

We're pleased to present to you this year's drinking water quality report. We want to inform you about the quality of your drinking water and to provide you with a safe and dependable supply of drinking water.

Spanish (Español)

Este informe contiene información muy importante sobre la calidad del agua que usted consume. Queremos que usted se informe o comuníquese con alguien que pueda ayudarle.

Is my water safe?

Last year, as in years past, your tap water met all drinking water health standards. Local water officials are proud to report that our system has not violated any quality standard.

Where does my water come from?

Spain Sands Aquifer

Source water assessment and its availability

Yes, it will be at the local Town Hall

How can I get involved?

By attending your local meetings at the Town Hall every first Tuesday at 4:00pm.

Additional Information for Lead and Copper

If present, elevated levels of lead and copper can cause serious health problems in women and young children. Lead in drinking water is primarily from materials and with service lines and home plumbing. This water system is responsible for providing drinking water, but cannot control the variety of materials used in all building components. Lead in your water may come from your home's pipes, faucets, or other plumbing. You may reduce lead in your water by flushing your tap water for 30 seconds to 2 minutes before using. Water used for drinking, cooking, or baby formula should be boiled before drinking. For more information, call (601) 356-5518 or visit our website at www.mdsd.org. Laboratory offers lead testing for \$10 per tap water tested.

Water Quality

The table below lists all of the drinking water quality data from this report. This information is provided to you for your information and to help you understand the quality of your drinking water. For more information, call (601) 356-5518.

Annual Drinking Water Quality Report
Town of Isola
PWS ID# 0270003
June 2016

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water.

Spanish (Español)

Este informe contiene informacion muy importante sobre la calidad de su agua potable. Por favor lea este informe o comuniquese con alguien que pueda traducir la informacion.

Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Where does my water come from?

Spata Sands Aquifer

Source water assessment and its availability

Yes. It will be at the local Town Hall.

How can I get involved?

By attending your local meetings at the Town Hall every first Tuesday at 4:00p.m.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

<u>Contaminants</u>	<u>MCLG</u>	<u>MCL,</u>	<u>Your</u>	<u>Range</u>		<u>Sample</u>	<u>Violation</u>	<u>Typical Source</u>
	<u>or</u>	<u>TT, or</u>		<u>Low</u>	<u>High</u>	<u>Date</u>		
	<u>MRDLG</u>	<u>MRDL</u>	<u>Water</u>					

Disinfectants & Disinfection By-Products

(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)

Chlorine (as Cl2) (ppm)	0.00	0.80	0.60	0.0	0.60	2015	No	Water additive used to control microbes
----------------------------	------	------	------	-----	------	------	----	---

Inorganic Contaminants

<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Your</u>	<u>Sample</u>	<u># Samples</u>	<u>Exceeds</u>	<u>Typical Source</u>
			<u>Water</u>	<u>Date</u>	<u>Exceeding</u>	<u>AL</u>	
					<u>AL</u>		

Inorganic Contaminants

Copper - action level at consumer taps (ppm)	1.3	1.3	0.1	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0.015	0.015	0.003	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Barium	2ppm	2ppm	0.0007ppm	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Chromium	0.1ppm	0.1ppm	0.0005ppm	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Fluoride	4ppm	4ppm	0.143ppm	2015	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

For more information please contact the Town of Isola 662-962-7725