

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY

2016 JUN 30 AM 9: 51

CCR CERTIFICATION  
CALENDAR YEAR 2015C&R Properties

Public Water Supply Name

0240172

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)

- Advertisement in local paper (attach copy of advertisement)  
 On water bills (attach copy of bill)  
 Email message (MUST Email the message to the address below)  
 Other Hand Direct Delivery

Date(s) customers were informed: 6/28/16 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: 6/28/16

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: / /

- As a URL (Provide URL \_\_\_\_\_)  
 As an attachment  
 As text within the body of the email message

CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: \_\_\_\_\_

Date Published: / /

CCR was posted in public places. (*Attach list of locations*)

Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):**CERTIFICATION**

I hereby certify that the 2015 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Tom Poo Manager  
 Name/Title (President, Mayor, Owner, etc.)

6/28/16  
 Date

Deliver or send via U.S. Postal Service:  
 Bureau of Public Water Supply  
 P.O. Box 1700  
 Jackson, MS 39215

May be faxed to:  
 (601)576-7800

May be emailed to:

CCR Due to MSDH & Customers by July 1, 2016!

water.reports@msdh.ms.gov

# 2015 C&R Properties Water Quality Report

## Is my water safe?

Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

## Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791). Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## Where does my water come from?

Coastal lowlands aquifer system

An aquifer is a saturated geologic layer that is porous and permeable enough to yield useable quantities of water to wells, springs, or surface water bodies. Most aquifers in the state are beds of sand and gravel.

## Source water assessment and its availability

The Mississippi Source Water Assessment Program (SWAP) is a result of the Federal Safe Drinking Water Act Amendments of 1996, which mandated all states to identify public water systems that may be susceptible to contamination and to adopt appropriate management measures that will enhance their protection. All testing is done by Mississippi Health Department. Copies of the testing results are readily available if needed.

For more information please call 228-392-1194 or visit <https://www.deq.state.ms.us/>

## Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

## How can I get involved?

For more information please call 228-392-1194 or visit <a href="https://www.cden.state.ms.us/">https://www.cden.state.ms.us/</a>									
Contaminants	MCLG	MCL, TT, or MRDLG	Your Water	Range		Sample Date	Violation	Typical Source	
	MRDLG	MRDL		Low	High				

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. C&R Properties is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. C&R Properties is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. No problems noted with lead. Most of the plumbing is pvc.

**Additional Information for Arsenic**

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems. While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

**Water Quality Data Table**

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG	MCL, TT, or MRDLG	Your Water	Range		Sample Date	Violation	Typical Source	
	MRDLG	MRDL		Low	High				
<b>Disinfectants &amp; Disinfection By-Products</b>									

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl <sub>2</sub> ) (ppm)	4	4	.9	.5	.9	2015	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	6	NA		2015	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	4	NA		2015	No	By-product of drinking water disinfection
<b>Inorganic Contaminants</b>								
Antimony (ppb)	6	6	.5	NA		2015	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	.798	NA		2015	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	.027	NA		2015	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	4	4	.5	NA		2015	No	Discharge from metal refineries and coal-burning factories; Discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	5	5	.5	NA		2015	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	.5	NA		2015	No	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (ppb)	200	200	15	NA		2015	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Fluoride (ppm)	4	4	.115	NA		2015	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury [Inorganic] (ppb)	2	2	.5	NA		2015	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Nitrate [measured as Nitrogen] (ppm)	10	10	.08	NA		2015	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	.02	NA		2015	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Selenium (ppb)	50	50	2.5	NA		2015	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Thallium (ppb)	.5	2	.5	NA		2015	No	Discharge from electronics, glass, and Leaching from ore-processing sites; drug factories
<b>Radioactive Contaminants</b>								
Radium (combined 226/228) (pCi/L)	0	5	.808	NA		2015	No	Erosion of natural deposits
Uranium (ug/L)	0	30	.067	NA		2015	No	Erosion of natural deposits
<b>Volatile Organic Contaminants</b>								
1,1,1-Trichloroethane (ppb)	200	200	.5	NA		2015	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	.5	NA		2015	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	.5	NA		2015	No	Discharge from industrial chemical factories
1,2,4-Trichlorobenzene (ppb)	70	70	.5	NA		2015	No	Discharge from textile-finishing factories
1,2-Dichloroethane (ppb)	0	5	.5	NA		2015	No	Discharge from industrial chemical factories
1,2-Dichloropropane (ppb)	0	5	.5	NA		2015	No	Discharge from industrial chemical factories
Benzene (ppb)	0	5	.5	NA		2015	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	0	5	.5	NA		2015	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	.5	NA		2015	No	Discharge from chemical and agricultural chemical factories
Dichloromethane (ppb)	0	5	.5	NA		2015	No	Discharge from pharmaceutical and chemical factories
Ethylbenzene (ppb)	700	700	.5	NA		2015	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	.5	NA		2015	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	0	5	.5	NA		2015	No	Discharge from factories and dry cleaners
Toluene (ppm)	1	1	.5	NA		2015	No	Discharge from petroleum factories
Xylenes (ppm)	10	10	.5	NA		2015	No	Discharge from petroleum factories; Discharge from chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	.5	NA		2015	No	Discharge from industrial chemical factories
o-Dichlorobenzene (ppb)	600	600	.5	NA		2015	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	.5	NA		2015	No	Discharge from industrial chemical factories

Contaminant	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Violation	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
trans-1,2-Dichloroethylene (ppb)	100	100	.5	NA	2015		No	Discharge from industrial chemical factories
<b>Inorganic Contaminants</b>								
Copper - action level at consumer taps (ppm)		1.3	1.3	0	2014	5	No	Corrosion of household plumbing systems; Erosion of natural deposits
<b>Inorganic Contaminants</b>								
Lead - action level at consumer taps (ppb)		0	15	4	2014	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

## Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Violation	Typical Source
Vinyl Chloride (ppb)	0	2	ND	No	Leaching from PVC piping; Discharge from plastics factories

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

<b>Important Drinking Water Definitions</b>	
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

**For more information please contact:**

Contact Name: Travis Paige  
Address: 6313 Seawinds Blvd.  
Biloxi, MS 39532  
Phone: 228-297-0207