2017 MAY 10 AM 11: 29

CERTIFICATION

Consumer Confidence Report (CCR)

Tiplersville Development Association, Inc. Public Water Supply Name S ID #s for all Community Water Systems included in this CCR The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply. Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other) Advertisement in local paper (attach copy of advertisement) ☐ On water bills (attach copy of bill) ☐ Email message (MUST Email the message to the address below) ☐ Other Date(s) customers were informed: ___/__/, ___/ / ____/ CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used Date Mailed/Distributed: / / CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / / ☐ As a URL (Provide URL _____ ☐ As an attachment ☐ As text within the body of the email message CCR was published in local newspaper. (Attach copy of published CCR or proof of publication) Name of Newspaper: Southern Sentine! Date Published: 5 / 3 / 17 Date Posted: 5 / 6 / 17 CCR was posted in public places. (Attach list of locations) CCR was posted on a publicly accessible internet site at the following address (DIRECT URL REQUIRED): I hereby certify that the Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)

ame/Title (President, Mayor, Owner, etc.)

MSDH, Bureau of Public Water Supply

P.O. Box 1700 Jackson, MS 39215 **Fax:** (601) 576 - 7800

Email: water.reports@msdh.ms.gov

CCR Deadline to MSDH & Customers by July 1, 2017!

2016 Annuel Drinking Water Quality Report
Tiplersville Development Association
PWS#:70010
April 2017.

. .

Vere pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goals to provide you with a safe and dependable supply of trinking water. We ge committed to providing you with incomplian to continuity fractions are formed to continuity fractions and to provide you with a safe and dependable supply of minking water. We ge committed to providing you with information because informed customers are our best allies. Our water secures. We ge committed to providing you with information because informed customers are our best allies. Our water sources. We ge committed to providing you with information because informed customers are our best allies. Our water source is from wells travity from the Goffses Sand Aquitar.

In source wester assessment has been completed for our public water system and the contraction on how the susceptibility of its drinking rater supply to identify population on the former source and the safe supply to identify provide your public water system and is available for review on provide your request. The wells for the lipinarylle Water Association hour reported moderale travidings in forms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Branda Shea at 882.229.8881. We want our alued outprovers to be informed about their water utility, if you want to learn more, please join us at any of our regularly scheduled healings. They are held on the first Monday of the month at 6,00 PM at the Providence Baptist Church.

Ve routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the kinking water contaminants that were detected furtify the pend of January. The December 31** 2216, in cases where monitoring real travity of your part of the pend of January and the December 31** 2216, in cases where monitoring as it required in 2016, the t

n this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've rovided the following definitions:

(ction Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system nust follow.

close Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Askimum Contaminant Level (MCL) - The "Maximum All@wed" (MCL) is the highest level of a contaminant that is allowed in drinking rater. "MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Askimum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no nown or expected risk to health. MCLGs allow for a margin of safety.

Askimum Residual Disinfectant Level (MRDL) — The highest level of a disinfectant allowed in drinking water. There is bonvincing vidence that addition of a disinfectant to necessary to control injectobili contaminants.

**Askimum Residual Disinfectant Level (Goal (MRDL)) — The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLOs do not explicit the benefits of the use of disinfectants to control interpolation contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in 10,000.

Parts per billion (opti) or Micrograms per liter a one bar per billion corresponds to one minute in 2,000 years, or a single penny in 110,000,000.

			·TEST RESU				Maria de la compansión de
Conteminent .	Violation Date Y/N • Collects	Level Detected	Bangs of Detects or # of Samples Exceeding MGL/ACL/MRDL	Unit MCI. Measure -ment	G MCL	Likely Source	of Contemination

10. Barium	N	2016	119	No Range	ppm	. 7 2		Discharge of drilling wastes; discharge from metal refineries; arcaion of natural deposits
13, Chromlum	N: .	2016. *	2	No Range	ppb	100	100	Discharge from steel and pulp mills: erosion of natural deposits
18. Fluoride	N •	2016	.13	No Range	pþm	, 4		Erosion of natural deposits; water additive which promotes strong- teeth; discharge from fertilizer and alumnum factories

Disinfection By-I	Product	• •:				
Chlorine , N ',	2016	.5,	.65	mqq 0	MRDL = 4	Water additive used to control microbes

is you'cen see by the table, our system had no violations. We're groud that your drinking water medis or exceeds all Federal and late requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA as determined that your water IS SAFE at these levels.

as determined that your water IS SAFE at these levels.

Ye are required to monitor your drinking water to specific constituents on a monthly basis. Results of regular monitoring are an idicator of whether or not our drinking water mests health standards. In an effort to ensure systems complete all monitoring squirements, MSDH now notifies systems of any missing samples prior to this end of the compliance period.

I present, elevated layels of lead cart cause-entrus heelth problems, especially for pregnant women and young children. Lead in which parties to primarily from meterials and components associated with service lines and home plumbling. Our water system is separable for providing high quality drisking water, but conflict optimit the ventry of metarias used in plumbing components. When our water has been stiting for several-hours, you can minimize the potential for lead exposure by flushing your lag for 30 seconds to 2 includes before using water for drinking or cooking, it you are pospered about lead in your water, you may his to have your water sated. Information by leader drinking water, testing methods, and atteps you can take to minimize exposure is available from the Safe brinking Water Hotting, or at http://www.gos.gov/se/sevstan/fets/. They hissales/pp/ State Department of Health Public Health Laboratory dress lead setting. Please contact \$01.576.7662 if you wish to have your water tested.

lignificant Deficiencies

ignificant Deficiencies *
Compliance Data Violations:
Anothering and Recording of Compliance Data Violations:
Juring is sanitary purvey conducted on 10/29/2015, the Mississippi, State Department of Health cited the following significant leficiency(e):
mproperly constructed Well (ex. not properly grouted)
20rective Accions MSDH is currently working with this system to return them to compliance since the expiration of the compliance leadline. We anticipate the system being returned to compliance by 9/50/2017.

Ull sources of dirikking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be thicrobes, horganic or organic chemicals and tradiscultive substances. All dirikking water, including bottled water, as reasonably be expected to contain at lefat shall amounts of some containings. The presence of contaminants does not so eccessful indicate that the water posses in each match with the proof september of some containings. The presence of contaminants does not so eccessful indicate that the water posses is neath inch. More september on short contaminants and potential expensions and the proof of th

John species may be more winerable to conteminants in stricking water than the general population. Immuno-compromised persons until as persons will cancer undergring characteristics, persons who have undergone organ transplants, people with HM/MDS or their immune system disorders once widerly, and infestic safe by endictations, these goes based seek stable should strikking water from their health care provideds: EPA/CDC guidelines on appropriate means to lessen the risk of infection by hypotenoricium and other riterabile contaminants are available from the Safe Drinking Water Holling 1.500.426.4761.

The Tiblersville Development Association, white around the clock to provide top quality water to every tap. We sak that all our sustomers help us protect our water sources which are the heart of our community, our way of

and a property of the second and the second second and the second second and the second secon

Copy of Consumer Confidence Report was

posted May le, 2017 at:

Tiplersville Post Office Tiplersville, Ms

Simply Southern Beauty Shop walnut, ms

Water bills are Collected at Simply Southern

Proof of Publication

The State of Mississippi Tippah County

Personally appeared before me a Notary Public in and
for said County and State, the undersigned

Tim Watson

who, after being duly sworn, deposes and says that he is the Publisher of the **SOUTHERN SENTINEL**, a newspaper published in the City of Ripley, in said County and State, and that the

LEGAL NOTICE

a true copy of which is hereto attached, was published for consecutive weeks in said newspaper as follows:

VOLUME	NO.	DATE
139	11	5/3/2017
in Ripley, Tippa	t said newspaper has be h County, Mississippi for ding the first insertion of I notice.	r more than one
Tinthe		
Tim Watson		
Sworn to and su	ubscribed before me this	s the
3 DAY	OF MAY 2017	

My Commission expires: 05/05/2017

Notary Public, Tippah County, Mississippi

Printer's Fee

FRECEIVED-WATER SUPPLY

2017 APR 25 PM 2: 18

2016 Annual Drinking Water Quality Report Tiplersville Development Association PWS#: 700010 April 2017

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Coffee Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Tiplersville Water Association have received moderate rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Brenda Shea at 662.223.6681. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the first Monday of the month at 6:00 PM at the Providence Baptist Church.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2016. In cases where monitoring wasn't required in 2016, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

				TEST RESU	JLTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

10. Barium	N	2016	.119	No Range	ppm		2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2016	1	No Range	ppb		100	100	Discharge from steel and pulp mills; erosion of natural deposits
16. Fluoride	N	2016	.13	No Range	ppm		4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Disinfectio	on By-]	Products	}						
Chlorine	N	2016	.5	.5 – .5	ppm	0	MRDL =		Nater additive used to control nicrobes

^{*} Most recent sample. No sample required for 2016.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

Significant Deficiencies

Monitoring and Reporting of Compliance Data Violations:

During a sanitary survey conducted on 10/29/2015, the Mississippi State Department of Health cited the following significant deficiency(s):

Improperly constructed well (ex: not properly grouted)

<u>Corrective Actions</u>: MSDH is currently working with this system to return them to compliance since the expiration of the compliance deadline. We anticipate the system being returned to compliance by 6/30/2017.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Tiplersville Development Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.