CERTIFICATION

Consumer Confidence R	leport (CCR)
Darlove-Murphy L	Nater Associ
Public Water Supply	Name
096005	
List PWS ID #s for all Community Water S	
The Federal Safe Drinking Water Act (SDWA) requires each Common Consumer Confidence Report (CCR) to its customers each year. Desystem, this CCR must be mailed or delivered to the customers, publish customers upon request. Make sure you follow the proper procedure mail a copy of the CCR and Certification to MSDH. Please check	all boxes that apply.
Customers were informed of availability of CCR by: (Attac	
☐ Advertisement in local paper (attach co	ppy of advertisement)
🔀 On water bills (attach copy of bill)	
☐ Email message (MUST Email the mess	sage to the address below)
☐ Other	
Date(s) customers were informed: 4 (2017), /	<u> </u>
CCR was distributed by U.S. Postal Service or other d	irect delivery. Must specify other direct delivery
methods used	
CCR was distributed by Email (MUST/Email MSDH a cor	by) Date Emailed: / /
As a URL (Provide URLnttp://ww	w.msrwa.org/2 <u>016ccr/darlovemurphy.pdf</u>
☐ As an attachment ;	
☐ As text within the body of the email me	essage
CCR was published in local newspaper. (Attach copy of put	blished CCR or proof of publication)
Name of Newspaper:	
Date Published://	
CCR was posted in public places. (Attach list of locations)	Date Posted: / /
CCR was posted on a publicly accessible internet site at the	following address ($\underline{\textbf{DIRECT URL REQUIRED}}$):
http://www.msrwa.org/2016ccr/d.	arlove murphy.pdf
hereby certify that the Consumer Confidence Report (CCR) has been the form and manner identified above and that I used distribution ment information included in this CCR is true and correct and is consistent with vater system officials by the Mississippi State Department of Health, Bures Name/Title (President, Mayor, Owner, etc.)	thous allowed by the SDWA. I turner certify that the hather water quality monitoring data provided to the public
Submission options (Select on	e method ONLY)
	Fax: (601) 576 - 7800
Mail: (U.S. Postal Service) MSDH, Bureau of Public Water Supply P.O. Box 1700	Email: water.reports@msdh.ms.gov
Jackson, MS 39215	EMMII: Marel Tehotra(minami marko A

CCR Deadline to MSDH & Customers by July 1, 2017!

2016 Annual Drinking Water Quality Report Darlove Murphy Water Association PWS#: 0760075 April 2017

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Darlove Murphy Water Association have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact David Koehn at 662.822.8601. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meeting scheduled for the first Monday of January at 6:00 PM at Leland.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2016. In cases where monitoring wasn't required in 2016, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

				TEST RESU	JLTS			
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MGL	Likely Source of Contamination
Inorganic	Contam	inants						
8. Arsenic	N	2016	1.2	No Range	ppb	n/a	10	Erosion of natural deposits; runc from orchards; runoff from glass and electronics production waste
10. Barium	N	2016	.0327	No Range	ppm	2	2	Discharge of drilling wastes;

13 May. 16. 20	17 v 4	; () () PMriaB	LACK BA	YOU WATER:	ppb	1	100	10	0 DisNo, 7060n steP. 4 pulp milis, erosion of natural deposits
14. Copper	N	2012/14*	.5	0	ppm		1.3	AL=1.	
16. Fluoride	N	2016	.342	No Range	ppm		4		4 Erosion of natural deposits, water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	2	О	ppb		0	AL=1	 Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2016	4.4	No Range	ppb		50	£	 Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfection	n By-		75	9 - 74	ppb	0	<u></u>	60	By-Product of drinking water disInfection.
82. TTHM [Total trihalomethanes]	N	2016	73	40.9 - 120	ppb	0		80	By-product of drinking water chlorination.
Chlorine	N.	2016	.9	.1 – 3	mg/l	0	MRI	DL = 4	Water additive used to control microbes

^{*} Most recent sample. No sample required for 2016.

Disinfection By-Products:

(82) Total Trihalomethanes (TTHMs). Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Our system exceeded the MCL for Disinfection Byproducts in 2016. The standard for Trihalomethanes (TTHM) is .080 mg/l. The standard for Haloacetic Acids (HAA5) is .060mg/l. We are working with the MSDH to evaluate the water supply and researching options to correct the problem.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children, Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Darlove Murphy Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

⁽⁸¹⁾ Haloacetic Acids (HAA5). Some people who drink water containing bromate in excess of the MCL over many years may have an increased risk of cancer

DARLOVE- MURPHY WATER ASSOC INC P.O. BOX 916 LELAND, MS 38756 METER READ 03/16/2017 04/21/2017 5000000 5005000 5000	First Class Mail U.S. Postage Paid LELAND, MS 38756 Permit #11
Prior Balance 42.34 Payment(s) -42.34 Water 49.27	DUE AMT. DUE ACCT. 05/15/2017 IF-LATE 49.27 NO. 19AV. 54.20 DATE TYPE
Total Due 49.27	sTR1429(4947 Residential 2601.TRIBBETT RD
DUE RETURN THIS STUB OF 15/15/2017 PAY 54.20 WITH PAYMENT:	ACCT AMT. NO. 600470 DUE 49.27
nttp://www.msrwa.org/zurtoccr/da	IDNEY WILLIAMS 601 TRIBBETT RD ELAND, MS 38756-9364

իկշկումսիյուրիումըիրովիիյիկիկիկիյուրդ