

RECEIVED-WATER SUPPLY
2017 JUL -5 AM 8:30

CERTIFICATION

Consumer Confidence Report (CCR)

COUNTRY HAVEN MOBILE HOME PARK

Public Water Supply Name

~~0170027~~ 0170027

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement) Desoto Times
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other posted in office lobby at Countryhaven

Date(s) customers were informed: 1 / 1 . 1 / 1 . 1 / 1

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: 1 / 1

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: 1 / 1

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Desoto Times

Date Published: 1 / 1

CCR was posted in public places. *(Attach list of locations)*

Date Posted: 06/29/2017

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Victoria Russell
Name/Title (President, Mayor, Owner, etc.)

6-27-17
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Fax: (601) 576 - 7800

Email: water.reports@msdh.ms.gov

CCR Deadline to MSDH & Customers by July 1, 2017!

WRITE FIRMLY WITH BALL POINT PEN ON HARD SURFACE TO MAKE ALL COPIES LEGIBLE

CUSTOMER USE ONLY

FROM: (PLEASE PRINT) PHONE ()
 Country Haven Mobile Home Park
 1121 Hwy 51 N. office
 North, N.S. 38651

PAYMENT BY ACCOUNT (if applicable)

DELIVERY OPTIONS (Customer Use Only)

SIGNATURE REQUIRED Note: The mailer must check the "Signature Required" box if the mailer: 1) Requires the addressee's signature; OR 2) Purchases additional insurance; OR 3) Purchases COD service; OR 4) Purchases Return Receipt service. If the box is not checked, the Postal Service will leave the item in the addressee's mail receptacle or other secure location without attempting to obtain the addressee's signature on delivery.

Delivery Options

- No Saturday Delivery (delivered next business day)
 - Sunday/Holiday Delivery Required (additional fee, where available*)
 - 10:30 AM Delivery Required (additional fee, where available*)
- *Refer to USPS.com® or local Post Office™ for availability.

TO: (PLEASE PRINT) PHONE ()
 Mobile Home Park
 P.O. Box 1100
 Jacksonville, FL 32215
 ZIP + 4® (U.S. ADDRESSES ONLY)
 32215

- For pickup or USPS Tracking™, visit USPS.com or call 800-222-1811.
- \$100.00 insurance included.



EL752854539US

EL752854539US



**PRIORITY
 ★ MAIL ★
 EXPRESS™**

ORIGIN (POSTAL SERVICE USE ONLY)

<input type="checkbox"/> 1-Day		<input type="checkbox"/> 2-Day		<input type="checkbox"/> Military		<input type="checkbox"/> DPO	
PO ZIP Code 38651	Scheduled Delivery Date (MM/DD/YY) 07/10/17	Postage \$ 23.75					
Date Accepted (MM/DD/YY) 6/30/17	Scheduled Delivery Time <input type="checkbox"/> 10:30 AM <input type="checkbox"/> 12 NOON	Insurance Fee \$	COD Fee \$				
Time Accepted 1:30 <input type="checkbox"/> AM <input type="checkbox"/> PM	10:30 AM Delivery Fee \$	Return Receipt Fee \$	Live Animal Transportation Fee \$				
Special Handling/Fragile \$	Sunday/Holiday Premium Fee \$	Total Postage & Fees \$ 23.75					
Weight lbs. ozs.	Acceptance Employee Initials [Signature]	Total Postage & Fees \$ 23.75					
DELIVERY (POSTAL SERVICE USE ONLY)							
Delivery Attempt (MM/DD/YY) 7-1	Time 4:35 <input type="checkbox"/> AM <input type="checkbox"/> PM	Employee Signature [Signature]					
Delivery Attempt (MM/DD/YY)	Time <input type="checkbox"/> AM <input type="checkbox"/> PM	Employee Signature					

LABEL 11-B, OCTOBER 2016

PSN 7690-02-000-9996

3-ADDRESSEE COPY

† Money Back Guarantee for U.S. destinations only.

Country Haven Mobile Home Park

1151 Hwy 51 N • Nesbit, MS 38651
PWSID# 0170027

Water Quality Report 2016

Prepared by:
Mitchell Technical Services, Inc
325 West McKnight Murfreesboro, TN 37129

IS MY WATER SAFE ?

Last year your tap water met all monitored U.S. Environmental Protection Agency (EPA) and state drinking water health standards. We vigilantly safeguard the water supply and we are proud to report that our system meets all monitored federal and state requirements.

REPORT AVAILABILITY

This report is not mailed to the residents; however, it is published annually in the local paper and is also posted in the central office on the bulletin board for review.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

WHERE DOES MY WATER COME FROM?

Our water comes from two wells over 200 feet deep, which draw ground water from the Sparta Sand Aquifer.

SOURCE WATER ASSESSMENT AND ITS AVAILABILITY.

Our source water assessment has been completed by the Mississippi State Department of Health. The results of the report are available at:
<http://landandwater.deq.ms.gov/swap/reports/report.aspx?id=0170027>

The susceptibility ranking of each of our wells was **Moderate**

WHY ARE THERE CONTAMINANTS IN MY DRINKING WATER?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

HOW CAN I GET INVOLVED?

We encourage all customers who have any concerns or questions to contact our office.

OTHER INFORMATION:

You may want additional information about your drinking water. You may contact our certified waterworks operator or you may prefer to log on to the Internet and obtain specific information about your system and its compliance history at the following address:

<http://www.msdh.state.us/watersupply/index.htm>

Information including current and past boil water notices, compliance and reporting violations, and other information pertaining to your water supply including "Why, When, and How to Boil Your Drinking Water" may be obtained.

Certified Operator:	Bryan Lane	Phone	(662) 562.5314
Operations Firm:	MTS, Inc.	Fax	(662) 562.5314
Emergency Contact :	(662) 429.9626		

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Important Drinking Water Information:
 ND: **Non-Detects:** Laboratory analysis indicates that the constituent is not present.

MCLG: **Maximum Contaminant Level Goal:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL: **Maximum Contaminant Level:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Units Description:

- NA: Not applicable
- NR: Not reported
- ppm: parts per million, or mg/L: milligrams per liter
- ppb: parts per billion, or µg/L: micrograms per liter
- ND: Not detected
- MNR: Monitoring not required, but recommended.

Nitrates

Contaminant Sample Date	MCL MCLG	Your Water Violation Y / N
Nitrate 03/21/2016	10 ppm	< 0.08 ppm N
Nitrite 03/21/2016	1 ppm	< 0.02 ppm N
Nitrate-Nitrite 03/21/2016	10 ppm	< 0.1 ppm N

Disinfectants & Disinfectant Byproducts

Contaminant Sample Date	MRDL RANGE	QTR AVG Violation Y/N
Maximum Residual Disinfectant Level (MRDL) January 2016 - December 2016	0.77 mg/L 1.93 mg/L	1.40 mg/L N

Lead & Copper-90th Percentile

Contaminant Sample Date	Action Level	Your Water Violation Y / N
Lead (90 th) 01/01/2015-12/31/2017	0.015 ppm	0.003 ppm N
Copper (90 th) 01/01/2015-12/31/2017	1.3 ppm	0.0 ppm N

During a sanitary survey conducted on June 6, 2011, the Mississippi State Department of Health cited the following significant deficiency(s):

Inadequate internal cleaning / maintenance of storage tanks.

Corrective Actions: MSDH is currently working with this system to return them to compliance since the expiration of the compliance deadline. It is anticipated we will be returned to compliance by June 30, 2017.

 Significant
 Deficiencies

JO

se
-op
uc
-sl

MISSISSIPPI

