

6/19/17

CERTIFICATION

Consumer Confidence Report (CCR)

Alcorn County Water Assn. Inc.
Public Water Supply Name

0020001

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 6/2/17, _____ / _____ / _____

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / _____ / _____

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: _____ / _____ / _____

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Daily Corinthian

Date Published: 6/2/17

CCR was posted in public places. *(Attach list of locations)* Date Posted: _____ / _____ / _____

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the **Consumer Confidence Report (CCR)** has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Bobby Stearns, Sec
Name/Title (President, Mayor, Owner, etc.)

6/13/17
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Fax: (601) 576 - 7800

Email: water.reports@msdh.ms.gov

CCR Deadline to MSDH & Customers by July 1, 2017!

STATE OF MISSISSIPPI,
COUNTY OF ALCORN

PERSONALLY CAME before me, the undersigned, a Notary Public in and for Alcorn County, Mississippi, the CLERK OF THE DAILY CORINTHIAN, a newspaper published in the City of Corinth, First Judicial District of Alcorn County, in said State, who being sworn, deposes and says that THE DAILY CORINTHIAN is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858, of the Mississippi Code of 1942, and that the publication of a notice, of which the annexed is a copy, in the manner of:

Quality on Tap Report

has been made in said paper 1 times consecutively, to-wit:

On the 2 day of June, 2017

On the _____ day of _____, 20____

On the _____ day of _____, 20____

On the _____ day of _____, 20____

On the _____ day of _____, 20____

On the _____ day of _____, 20____



SWORN TO and subscribed before me this 2 day of June, 2017

Sharon Terry Notary Public

Jeanine Alison Clerk

Corinth, Miss., _____, 20____

To THE DAILY CORINTHIAN, Dr.
(Name Newspaper)

TO PUBLISHING Quality on Tap Report

case of PWS ID 020001

_____ words space 4 x 10.5

1 times and making proof, \$ 355.80

RECEIVED OF _____

payment in full of the above amount.

_____, 20____

Mailed 7/21/17



ALCORN COUNTY WATER ASSOCIATION
P.O. BOX 1388
CORINTH, MS 38835-1388
(662) 286-5689

RETURN SERVICE REQUESTED

PRESORTED
FIRST CLASS MAIL
U.S. POSTAGE
PAID
CORINTH, MS
PERMIT NO. 402

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	414300	410900	3,400	23.00
Maintenance fee				1.00

Alcorn Co. Water Assn.

CUSTOMER		DUE DATE	
ROUTE	ACCOUNT	PAST DUE AFTER THIS DATE	
2	4071	8/5/17	
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT	
24.00		26.30	

MAIL THIS STUB WITH YOUR PAYMENT

FINAL56 CR:511

ACCOUNT # 4071 7/19/17

METER READ MONTH	DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
7	3	1	24.00	2.30	26.30

BYRD, CRAIG**FINAL**
552 HWY 45
CORINTH MS 38834

JUNE USAGE

Corrected Consumer Confidence Report available in the office

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is **two wells pumping from the Paleozoic aquifer.**

This consumer confidence report will not be mailed to our customers, but copies are available at our office at 116 S. Cass Street.

We are pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact David Lutz at 116 S. Cass Street or call 662-286-6669. We want our valued customers to be informed about their water quality. If you want to learn more, please attend any of our regularly scheduled meetings. They are held at our office on the second Tuesday of each month at 5:00 P.M.

Alcorn County Water Association, Inc routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2016. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level: the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water. **Maximum Contaminant Level:** The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal: The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL - Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Contaminant	Violation Y/N	Date Collected	Level Detected	TEST RESULTS		Unit Measurement	MC LG	MCL	Likely Source of contamination
				Range of Detects or # of Samples Exceeding MCL/ACL					
Microbiological Contaminants									
							0	Presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment
Radioactive Contaminants									
Disinfectants & Disinfection By-products									
Chlorine	N	2016	.80	60-1.00		ppm	4	4	Water additive used to control Microbes
Inorganic Contaminants									
10. Barium	N	2014	0.263	No range		Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
12. Cadmium	N	2014	.5	No Range		ppb	5	5	Corrosion of galvanized pipe; erosion of natural deposits; discharge from metal refineries; run-off from waste batteries and paints
13. Chromium	N	2014	1.1	No Range		ppb	100	100	Discharge from steel & pulp mills; erosion of natural deposits
14. Nitrate	N	2016	<.08	0		Ppm	10	10	Natural and man-made deposits
15. Nitrate	N	2016	<.02	0		Ppm	1	1	
16. Nitrate-Nitrite	N	2016	<.01	0		Ppm	10	10	
17. Copper	N	2014	0.1	0		ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits leaching from wood preservatives
18. Fluoride	N	2014	0.1	0		ppm	4	4	Erosion of natural deposits additive which promotes strong teeth discharge from fertilizer & aluminum factories
19. Lead	N	2014	3	0		ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
20. Selenium	N	2014	2.5	0		Ppb	50	50	Discharge from petroleum & metal refineries; erosion of natural deposits
Volatile Organic Contaminants									
73. TTHM	N	2014	1.64	No Range		ppb	0	100	By-product of drinking water chlorination
74. Haas5	N	2014	6	No Range		ppb	0	100	

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Alcorn County Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$20 per sample. Please contact 601-576-7662 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Your CCR will not be mailed to you; however, you may obtain a copy from the water office. Please call 662-286-6669 if you have any questions.