

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY
CCR CERTIFICATION
CALENDAR YEAR 2014

Poplar Springs Water Assn.
Public Water Supply Name

0070016 0070024
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: ___/___/___, ___/___/___, ___/___/___

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___/___/___

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ___/___/___

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Calhoun County Journal

Date Published: 4/29/2015

CCR was posted in public places. *(Attach list of locations)* Date Posted: ___/___/___

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Darlene Hardin Bookkeeper
Name/Title (President, Mayor, Owner, etc.)

5-6-15
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:
water.reports@msdh.ms.gov

2014 Annual Drinking Water Quality Report
 Poplar Springs Water Association
 PWS#: 070016 & 070024
 April 2015

2015 MAY -1 PM 2:08

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Gordo Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Poplar Springs Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Charles Mahan at 662.682.7747. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meeting scheduled for August 25, 2015 at 7:00 PM at the Vardaman Community Center.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID#0070016		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

Inorganic Contaminants								
8. Arsenic	N	2014	1.1	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2014	.2175	.1876 - .2175	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	6.8	5.3 - 6.8	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014	.201	.181 - .201	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14	4	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2014	.09	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
20. Nitrite (as Nitrogen)	N	2014	.03	No Range	ppm	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	2014	3.5	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

81. HAA5	N	2014	3	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2014	.60	.30 - 60	ppm	0	MDRL = 4	Water additive used to control microbes

PWS ID #0070024 TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2014	.9	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2014	0.218	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014	4.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014	.165	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14	1	0	ppb	0	AL=15	Corrosion of household plumbing

								systems, erosion of natural deposits
21. Selenium	N	2014	3.2	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfection By-Products								
81. HAA5	N	2014	2	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2014	.60	.3 - .8	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2014.

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Poplar Springs Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Poplar Springs Water Assn. Drinking Water Quality Report

2015 Annual Drinking Water Quality Report
 PWS ID #0070016
 APR 2016

This report is prepared to provide you with the results of the annual drinking water quality monitoring program. The report is designed to inform you about the quality of the water and to provide you with a clear and concise summary of the results. We are committed to providing you with the highest quality of water and to ensuring the safety of the water supply.

The source water assessment has been completed for our public water system to determine the overall feasibility of the drinking water supply to identify potential sources of contamination. A report containing detailed information on how the water quality monitoring program was implemented is available to the public upon request. The report for the Poplar Springs Water Association has been prepared for your information.

If you have any questions about this report or concerning your water quality, please contact Charles Mahan at 662-832-7147. We will be happy to assist you. This report is available to the public upon request.

The following table lists the results of the annual drinking water monitoring program for the period of January 1st to December 31st, 2015. The table lists the monitoring location, the date of the sample, the parameter measured, the result, and the Maximum Allowable Level (MAL) for each parameter. The MAL is the highest level of a contaminant that is allowed in drinking water. MALs are set to protect the public health and to ensure the safety of the water supply. The table also lists the Maximum Contaminant Level Goal (MCLG) and the Maximum Residual Disinfectant Level Goal (MRDLG) for each parameter. The MCLG is the level of a contaminant in drinking water below which there is no known or expected health risk. The MRDLG is the level of a disinfectant in drinking water below which there is no known or expected health risk.

In the table we indicate any violations and any other information you might not be familiar with. To help you better understand these items, we provided the following definitions:

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements when a water system is required.

Maximum Contaminant Level (MCL): The Maximum Allowable Level (MAL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set to protect the public health and to ensure the safety of the water supply.

Maximum Contaminant Level Goal (MCLG): The MCLG is the level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs are set to protect the public health and to ensure the safety of the water supply.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contamination.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a disinfectant below which there is no known or expected health risk. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Parts per million (ppm) or milligrams per liter (mg/L): one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or micrograms per liter (µg/L): one part per billion corresponds to one minute in 2,000 years or a single penny in \$200,000.

PWS ID #0070016 TEST RESULTS										
Contaminant	Location	Date Collected	Level Detected	Range of Levels of 3 or More Samples (MCLG)	Unit	MCL	MCLG	MRDL	MRDLG	Legal Basis of Enforcement
Inorganic Contaminants										
1. Arsenic	10	2015	1.3	0.0 Range	ppm	10	0.05	10	0.01	Excess of arsenic, lead, copper, iron, manganese, nitrate, nitrite, selenium, and uranium may cause adverse health effects. Excess of arsenic may also cause cancer.
2. Barium	10	2015	274	191 - 319	ppm	1	1	1	1	Excess of barium may cause adverse health effects.
3. Cadmium	10	2015	0.0	0.0 - 0.0	ppm	0.1	0.01	0.1	0.01	Excess of cadmium may cause adverse health effects.
4. Copper	10	2015	0.3	0.0 - 0.3	ppm	1.3	1.3	1.3	1.3	Excess of copper may cause adverse health effects.
5. Fluoride	10	2015	2.01	1.61 - 2.01	ppm	4	4	4	4	Excess of fluoride may cause adverse health effects.
6. Lead	10	2015	0	0	ppm	0	0	0	0	Excess of lead may cause adverse health effects.
7. Manganese	10	2015	0.0	No Range	ppm	15	15	15	15	Excess of manganese may cause adverse health effects.
8. Nitrate (as Nitrogen)	10	2015	0.0	No Range	ppm	1	1	1	1	Excess of nitrate may cause adverse health effects.
9. Nitrite	10	2015	0.0	No Range	ppm	0.1	0.1	0.1	0.1	Excess of nitrite may cause adverse health effects.
Disinfection By-Products										
10. Haloacetic Acids (HAA5)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAA5 may cause adverse health effects.
11. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
12. Haloketones (HKs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HKs may cause adverse health effects.
13. Halonitriles (HNs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HNs may cause adverse health effects.
14. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
15. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
16. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
17. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
18. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
19. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
20. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
21. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
22. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
23. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
24. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
25. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
26. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
27. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
28. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
29. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
30. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
31. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
32. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
33. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
34. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
35. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
36. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
37. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
38. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
39. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
40. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
41. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
42. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
43. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
44. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
45. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
46. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
47. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
48. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
49. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
50. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.

PWS ID #0070024 TEST RESULTS										
Contaminant	Location	Date Collected	Level Detected	Range of Levels of 3 or More Samples (MCLG)	Unit	MCL	MCLG	MRDL	MRDLG	Legal Basis of Enforcement
Inorganic Contaminants										
1. Arsenic	10	2015	0.0	No Range	ppm	10	0.05	10	0.01	Excess of arsenic, lead, copper, iron, manganese, nitrate, nitrite, selenium, and uranium may cause adverse health effects. Excess of arsenic may also cause cancer.
2. Barium	10	2015	0.0	No Range	ppm	1	1	1	1	Excess of barium may cause adverse health effects.
3. Cadmium	10	2015	0.0	No Range	ppm	0.1	0.01	0.1	0.01	Excess of cadmium may cause adverse health effects.
4. Copper	10	2015	0.0	No Range	ppm	1.3	1.3	1.3	1.3	Excess of copper may cause adverse health effects.
5. Fluoride	10	2015	0.0	No Range	ppm	4	4	4	4	Excess of fluoride may cause adverse health effects.
6. Lead	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of lead may cause adverse health effects.
7. Manganese	10	2015	0.0	No Range	ppm	15	15	15	15	Excess of manganese may cause adverse health effects.
8. Nitrate (as Nitrogen)	10	2015	0.0	No Range	ppm	1	1	1	1	Excess of nitrate may cause adverse health effects.
9. Nitrite	10	2015	0.0	No Range	ppm	0.1	0.1	0.1	0.1	Excess of nitrite may cause adverse health effects.
Disinfection By-Products										
10. Haloacetic Acids (HAA5)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAA5 may cause adverse health effects.
11. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
12. Haloketones (HKs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HKs may cause adverse health effects.
13. Halonitriles (HNs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HNs may cause adverse health effects.
14. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
15. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
16. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
17. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
18. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
19. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
20. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
21. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
22. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
23. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
24. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
25. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
26. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
27. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
28. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
29. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
30. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
31. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
32. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
33. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
34. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
35. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
36. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
37. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
38. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
39. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
40. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
41. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
42. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
43. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.
44. Haloacetaldehydes (HAAld)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HAAld may cause adverse health effects.
45. Haloacetonitriles (HANs)	10	2015	0.0	No Range	ppm	0	0	0	0	Excess of HANs may cause adverse health effects.