

MISSISSIPPI STATE DEPARTMENT OF HEALTH
BUREAU OF PUBLIC WATER SUPPLY

CCR CERTIFICATION
CALENDAR YEAR 2014

COMMUNITY WATER SUPPLY

2015 JUN 16 AM 8:13

NORTH LAUDERDALE WATER ASSOCIATION, INC.

Public Water Supply Name

380006

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- ☒ Advertisement in local paper (attach copy of advertisement)
☐ On water bills (attach copy of bill)
☐ Email message (MUST Email the message to the address below)
☒ Other ON LINE northlauderdalewater.com -ANNUAL MEETING 6-4-2015

Date(s) customers were informed: 06 / 03 / 2015 / 06 / 04 / 2015 /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / _____ / _____

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: _____ / _____ / _____

- ☐ As a URL (Provide URL _____)
☐ As an attachment
☐ As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: THE MERIDIAN STAR

Date Published: 06 / 03 / 2015

CCR was posted in public places. *(Attach list of locations)*


Date Posted: 06 / 03 / 2015

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

northlauderdalewater.com

CERTIFICATION

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.


Name/Title (President, Mayor, Owner, etc.)

12 JUNE 2015
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601) 576-7800

May be emailed to:
water.reports@msdh.ms.gov

gc

2014 Annual Drinking Water Quality Report

PWS ID# 380006

May 1st, 2015

The board and staff of the North Lauderdale Water Association present this year's Annual Water Quality Report for the period of January 1 to December 31, 2014. This report is designed to inform our members about the quality of the water and services we deliver. Our mission is to consistently provide our members with quality drinking water.

We are pleased to report that our water meets all federal and state requirements.

NLWA draws its water via 5 wells from the Lower Wilcox aquifer at depths between approximately 450 and 650 feet. The Mississippi State Department of Health has performed a source water assessment for each well and these can be viewed at the NLWA main office. The water supply for North Lauderdale Water Association received a lower to moderate ranking for susceptibility to contamination.

The North Lauderdale Water Association routinely monitors for contaminants and constituents in our drinking water according to Federal and State laws. This table below shows the results of our monitoring throughout calendar year 2014. In cases where monitoring wasn't required in 2014, the table reflects the most recent results. As water travels over land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. The presence of these constituents in small amounts does not necessarily pose a health risk.

WATER QUALITY TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Test Method	Range of Detects or # of Samples Exceeding (MCL)	Unit of Measurement	MCLG	MCL	Likely Source of Contamination	
Inorganic Contaminants									
8. Arsenic	N		0.6	None	ppb	n/a	50	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes	
10. Barium	N		0.06	None	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
13. Chromium	N		5.4	None	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits	
14. Copper	N	1/1/11 to 12/31/13*	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits	
16. Fluoride	N		0.598	None	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	
17. Lead	N	1/1/11 to 12/31/13*	1	None	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits	
Disinfectants & Disinfection By-Products									
Chlorine (as Cl ₂)	N	1/1/14 to 12/31/14	1.70	0.93 to 2.20	ppm	4	4	Water additive used to control microbes	
15. THM (Total trihalomethanes)	N		0.74	0 to 1.19	ppb	0	50	By-product of drinking water chlorination	
HAAs (Haloacetic Acids)	N		2	0 to 4	ppb	0	60	By-product of drinking water chlorination	

*No samples required in 2014

- Parts per million (ppm) or milligrams per liter (mg/L) - a unit equal to 0.0001% or 1 penny in \$10 thousand dollars.
- Parts per billion (ppb) or micrograms per liter (ug/L) - a unit equal to 1 penny in \$10 million dollars.
- Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers mandatory treatment or other actions by the water system.
- Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water.
- Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health.

Violations: NONE

Exceedances: NONE

Fluoridation: To comply with the "Regulation Governing Fluoridation of Community Water Supplies," NLWA is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7 - 1.3 ppm was 10. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7 - 1.3 ppm was 79%.

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. North Lauderdale Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

The Mississippi State Department of Health Public Health Laboratory offers lead and other contaminant testing. Please contact 601-576-7582 if you wish to have your water tested.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

If you have any questions about this report or concerning your NLWA water quality, please contact the water association manager, Josh Bennett, at 601-681-6157. We want our members to be informed about their water association. If you want to learn more, please review the documents posted on our web page at www.northlauderdalewater.com, join our Facebook page at www.facebook.com/northlauderdalewater, or attend any of our regularly scheduled board meetings. They are held on the second Thursday of each month at the North Lauderdale Water Association main office at 10 a.m.

Sincerely,

increase. Lexus SUV sales were also strong thanks in part to the new NX small SUV. But Toyota's car sales dropped 11 percent.

FCA's sales rose 4 percent to 202,227, the company's best May since 2006. Jeep sales rose 13 percent. Sales of FCA's best-seller, the Ram pickup, rose 8 percent, while sales of Ram's ProMaster van more than doubled.

Honda's sales rose 1 percent to 154,693 vehicles. Car sales were weak; Honda's best-seller, the Civic sedan, was down 4.5 percent. But sales of the Acura RDX SUV jumped 24 percent.

Nissan's sales were flat at 134,779. Sales of the recently redesigned Murano crossover were up 58 percent, and the Rogue small SUV also saw strong sales. But Nissan's car sales dropped 11 percent.

Hyundai's sales fell 10 percent to 63,610. Every Hyundai model except for the Elantra sedan saw sales declines.

Former Maryland man held at Guantanamo alleges CIA torture

MIAMI (AP) — A former Maryland resident imprisoned at Guantanamo was subjected to mistreatment while in CIA custody far in excess of what has previously been disclosed, including being hung from a wooden beam for three days and kept in total darkness for nearly a year, a legal organization that represents him said Wednesday.

Some details about the treatment of Majid Khan in the clandestine CIA detention center emerged in December when the Senate intelligence committee released a summary of a classified report critical of the agency's treatment of prisoners suspected of involvement with al-Qaida following the Sept. 11 terrorist attack.

But the Center for Constitutional Rights, a New York-based organization representing Khan, and others held at Guantanamo, said that the mistreatment was far more extensive and that it can be publicly released now for the first time because the government has

determined some details are no longer considered classified.

Khan, 35, is awaiting sentencing at the U.S. base in Cuba on charges that include conspiracy, murder and attempted murder for aiding al-Qaida. He pleaded guilty before a military commission in a deal that calls for a sentence of between 19 and 25 years, instead of life in prison, in exchange for cooperating in the prosecution of other cases.

Wells Dixon, his attorney, said Pentagon officials should reduce his sentence because of the mistreatment, which they would be permitted to do under the military commission legal system.

"He was tortured in ways that exceed even what was disclosed in the Senate report and that needs to be taken into account when he's sentenced," Dixon said.

The allegations of mistreatment, contained in years of previously classified notes taken by his lawyers, include being submerged in icy water during interrogations twice, in May and July 2003. A CIA spokesman said Tuesday that Khan was not one of the three prisoners subjected to the simulated drowning technique known as waterboarding.

Khan also told his lawyers that he was sexually assaulted, including with forced enemas, and hung on a wooden beam for days on end. He said he was also kept in total darkness, with only a bucket for a toilet, for nearly a year in 2003, beaten and held in a cell with bugs that bit him.

Records indicate Khan had already agreed to answer questions before the treatment, Dixon said. "The torture in addition to being inherently unlawful was gratuitous."



Does Your Copier

Print, Scan, Copy, Fax, Email, and Perform Document Management?

If You Answered No Give me a Call

(601) 693-COPY



Don Lucas




Raft Race June 6, 2105 benefiting & supporting Alzheimer's and Wounded Warrior Project

2015 JUN 16 AM 8:13


STATE OF MISSISSIPPI
COUNTY OF LAUDERDALE }
CITY OF MERIDIAN

I, Angela N Stuart Clerk of The Meridian Star, a newspaper published daily at Meridian, Mississippi, do solemnly swear that a copy of this notice, as per clipping attached, was published once a week for 1 weeks in the regular and entire issue of said newspaper, and not in any supplement thereof, to-wit:

in the issue dated June 3 2015, and in the issue dated _____, 20____, and in the issue dated _____, 20____, and in the issue dated _____, 20____.



Angela N Stuart Clerk
Sworn to and subscribed before me, this the 11 day of June, 2015
[Signature]
Notary Public



North Lauderdale Water Association

9709 Mount Carmel Road (PO Box 143)

Bailey, Mississippi 39320

601-681-6157

www.northlauderdalewater.com

facebook.com/northlauderdalewater

Customers informed by note on June's water bill
CCR available in office

2015 JUN 16 AM 8:13

KEEP THIS PORTION FOR YOUR RECORDS:

ACCOUNT NO.		MEMBER NO.
030034000		
PROPERTY ADDRESS		
3557A GORDON WHITE ROAD		
FROM	TO	DUE DATE
04/30	05/29	06/17/15
PREV READ	CURR READ	GAL USED
28050	45000	16950
SERVICES & FEES DESCRIPTION		AMOUNT
WATER		129.39
IRIS		.50
PAYMENT DUE IF PAID ON TIME:		129.89
PAYMENT DUE IF PAID LATE:		142.88
LOCK-OFF DATE:		07/17/15

RETURN THIS STUB WITH PAYMENT TO:

NORTH LAUDERDALE WATER ASSN

9709 Mt Carmel Rd, PO Box 143

Bailey MS 39320

601-681-6157

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
BAILEY, MS 39320
PERMIT #3

ACCOUNT NO.	MEMBER #	LATE PAYMENT	LOCK DATE
030034000		142.88	07/17/15
PAST DUE	CURR BILL	TOTAL DUE	by DUE DATE
0.00	129.89	129.89	06/17/15
NOTE:			
2014 CCR AVAILABLE IN OFFICE			
RETURN SERVICE REQUESTED			
MARK THOMPSON			
3557A GORDON WHITE RD			
BAILEY MS 39320			

2015 JUN 16 AM 8:13