

MISSISSIPPI STATE DEPARTMENT OF HEALTH  
BUREAU OF PUBLIC WATER SUPPLY  
CCR CERTIFICATION  
CALENDAR YEAR 2014

City of Waynesboro  
Public Water Supply Name

0770003  
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other \_\_\_\_\_

Date(s) customers were informed: 7 May 2015 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used Advertised in the local news paper

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /

- As a URL (Provide URL \_\_\_\_\_)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Wayne County News

Date Published: 7 May 2015

CCR was posted in public places. *(Attach list of locations)* Date Posted: / /

CCR was posted on a publicly accessible internet site at the following address **(DIRECT URL REQUIRED)**:

**CERTIFICATION**

I hereby certify that the 2014 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

[Signature]  
Name/Title (President, Mayor, Owner, etc.)

5-18-15  
Date

Deliver or send via U.S. Postal Service:  
Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

May be faxed to:  
(601) 576-7800

May be emailed to:  
[water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

pop/10

**Action Level** - The concentration of a contaminant which, if exceeded, triggers treatment or other actions which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set to protect public health using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that additional disinfectant is necessary to control microbial contamination.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Parts per million (ppm) or Micrograms per liter (µg/L)** - one part per million corresponds to one minute in ten years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**TEST RESULTS**

Contaminant	Units	Date Collected	Level Detected	Range of Results (MCL/MCLG)	Set Maximum	MCL	MCLG	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
9. Arsenic	ppb	2014	2.2	No Range	ppb	10	10	Leach from natural deposits; runoff from glass and electronics production wastes
10. Barium	ppm	2014	0.168	No Range	ppm	2	2	Discharge of drilling wastes; discharge from steel refineries; runoff of natural deposits
13. Cadmium	ppb	2014	15.7	No Range	ppb	100	100	Discharge from steel and pulp mills; runoff of natural deposits
14. Copper	ppm	2011/13	1	0	ppm	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
18. Fluoride	ppm	2014	0.79	No Range	ppm	4	4	Runoff of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	ppb	2011/13	4	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
21. Selenium	ppb	2014	8.6	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
<b>Disinfection By-Products</b>								
B1. HAA5	ppm	2014	0.2	0 - 20	ppm	0	0	By-product of drinking water disinfection
B2. THM4 (Total trihalomethanes)	ppm	2014	15.04	0 - 15.04	ppm	0	0	By-product of drinking water disinfection
Chlorine	ppm	2014	1.2	0 - 2.0	ppm	0	MRDL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2014.  
 \*\* Fluoride level is routinely adjusted to the MS State Dept. of Health's recommended level of 0.7 - 1.3 ppm.  
 Distribution by Product:  
 (B2) Total Trihalomethanes (THM4) - Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

We routinely monitor for the presence of drinking water contaminants. Testing results we received show that our system exceeded the standard, or maximum contaminant level (MCL), for Disinfection Byproducts in the first three quarters of 2014. The standard for Trihalomethanes (THM4) was 0.20 ppm.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from lead pipes and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on how to drink water testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/leadandtapwater>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.778.7592 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the City of Wagnersboro is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7 - 1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7 - 1.3 ppm was 81%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more susceptible to contaminants in drinking water than the general population. Immune-compromised persons, such as persons with cancer, undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The City of Wagnersboro works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water resources, which are the heart of our community, our way of life and our children's future.

# AFFIDAVIT

WAYNE COUNTY NEWS  
PO BOX 509  
WAYNESBORO, MS 39367

DATE: 6/7/2015

CITY OF WAYNESBORO  
714 WAYNE ST  
WAYNESBORO, MS 39367

NO.	P.O. NO

2014 ANNUAL DRINKING WATER QUALITY REPORT

\$277.05

*Paul Keane*

Being

sworn, says that he is Publisher of the Wayne County News, which publishes a weekly newspaper in the County of Wayne, State of Mississippi; and the attached notice appeared in the issue(s) of the Wayne County News.

Publish Dates	Volume	No.
MAY 07, 2015	125	19



Sworn to and subscribed before me on this 7th day of May, 2015

*Doris Keane*

Notary Public  
My Commission Expires 10-14-15

WE APPRECIATE YOUR BUSINESS  
FOR BILLING INQUIRES-CALL (601-735-4341)