

Thursday, June 25, 2015

The Conservative

NTY
tive
CDA

dedicated
terally built
am from north-
the award-
that it is now.
re are several
s who get
go on to
on. Thank you,
gizing talent
em on their
ing their
reams.

Several new
CDA board
embers were
ected. Mrs.
race Voothees
id Mr. Lemon
unningham are
tiring from the
ard. They will
tough acts to
llow, and we
nk both of
service. Mrs.
me and Mr.
will be filling
ancies.
exton
lured to the
guise of giv-
ion about the
; surprised to
; was the
laque for the
le and her
he county and

of us, the paper
a "little
; 150 years
da and the
s a wonderful
mor of its
ou can keep up
for the special
n a year's sub-
cool is that?
ues nicely into
o stay hydrat-
d and shaded.
a good week.

ess

of Attala
o. Also, sym-
the family of
i, who was
way Cemetery
He used to
ospel singings
this area.

The commu-
ity turned out

2014 Annual Drinking Water Quality Report

Town of Vaiden
PWS ID# 0080009
June 2015

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about from where your water comes, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information, because informed customers are our best allies. Our water source is groundwater. Our wells draw from the Wilcox Aquifer.

A Source Water Assessment has been completed for our public water system to determine the overall susceptibility of the drinking water supply and

to identify potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water supply and is available upon request. The wells for The Town of Vaiden have received moderate susceptibility rankings.

If you have any questions about this report or concerning your water, please contact Mayor Melvin Hawthorne at 662.464.8884. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held at 7 P.M. on the first Monday of each month at Town Hall.

We routinely monitor for over 150 contaminants in your drinking water according to Federal and

State laws. The table below lists all the drinking water contaminants that we detected in the last round of sampling for the particular contaminant group. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, (2014). As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. All drinking water, including bottled water may be reasonably expected to contain at least small amounts of some constituents. The presence of contaminants does not necessarily indicate that water poses a health risk

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/L) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/L) - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Inorganic Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low High	MCLG	MCL	Likely Source of Contamination
Barium (ppm)	2014	N	0.0448	0.0408 - 0.0448	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride (ppm)	2014	N	0.907	0.904 - 0.907	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from aluminum and fertilizer factories

Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water	# of sites found above the AL	MCLG	MCL	Likely Source of Contamination
Copper (ppm) (90 th percentile)	2014	0.1	0	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (ppb) (90 th percentile)	2014	1	0	0	AL=1.5	Corrosion of household plumbing systems; erosion of natural deposits

Disinfectants and Disinfection Byproducts Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range of detects	MCLG/MCL	Likely Source of Contamination
Chlorine (ppm)	2014	N	0.50	0.50-0.60	0 / MRDL =4	Water additive used to control microbes

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any samples prior to the end of the monitoring

water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested.

601.576.7582 if you wish to have your water tested.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by

organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological