

CALENDAR YEAR 2014 CONSUMER CONFIDENCE REPORT
CERTIFICATION REPORT

2015 MAY 15 AM 8:50

TALLAHALA WATER ASSOCIATION
PWS ID # ('s): 0310001, 0310016 & 0310019

MS
2-15-15
MS

The Federal Safe Drinking Water Act requires each *community* public water system to develop and distribute a consumer confidence report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.

Please Answer the Following Questions Regarding the Consumer Confidence Report

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill, or other)*

-
- Advertisement in local paper
- On water bills
- Other _____

Date customers were informed: _____

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Date mailed/distributed: _____

CCR was published in local newspaper. *(Attach copy of published CCR and proof of publication)*

Name of Newspaper: The Laurel Leader Call
Date Published: 4-30-15

CCR was posted in public places. *(Attach list of locations)*

Date posted: _____

CCR was posted on a publicly accessible internet site at the address: www: _____

CERTIFICATION:

I hereby certify that a Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

Mark Lee, Mgr
Name/Title (President, Mayer, Owner, etc.)

5-12-15
Date

This Consumer Confidence Report (CCR) was completed by MS Cross Connection, LLC with information provided by the above Public Water System and is certified only to be as true & correct as the information provided.

Susao Boyett
Signature

4-13-15
Date

Mail completed form along with a copy of your CCR Report(s) before JULY 1, 2015 to:

**MS State Department of Health
Division of Public Water Supply
P O Box 1700
Jackson, MS 39215
Phone: 601-576-7518**

Annual Drinking Water Quality Report
Tallahala Water Association
PWS ID #0310001, 0310016 & 0310019
April, 2015

2015 MAY 15 AM 8:50

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of 12 wells that draw from the Sparta and Upper Wilcox Aquifers.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination.. The water supply for Tallahala Water Association received lower and moderate susceptibility rankings to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mack Lee or Sam Heard at 601-764-2655. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at the Tallahala Water Association office at 5:00 p.m. Our Annual Meeting will be held on September 14, 2015 at the Jasper County Courthouse in Bay Springs at 7:30 p.m.

Tallahala Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2014. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TALLAHALA WATER ASSOCIATION-ANTIOCH PWS ID# 0310001

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2012*	0.038	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	7/1/14 to 12/31/14	0.5	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2012*	0.2	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	7/1/14 to 12/31/14	7	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	1/1/14 to 12/31/14	1.70	1.00 to 2.50	ppm	4	4	Water additive used to control microbes
73. TTHM [Total Tri-halomethanes]	N	2012*	10.63	No Range	ppb	0	80	By-product of drinking water chlorination

* Most recent sample results available

TALLAHALA WATER ASSOCIATION-GARLANDSVILLE PWS # 0310016

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
5. Alpha emitters	N		0.6	No Range	PCi/l	0	15	Erosion of natural deposits
6. Combined radium	N		0.7	No Range	PCi/l	0	5	Erosion of natural deposits
Inorganic Contaminants								
10. Barium	N	2012*	0.049	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2012*	0.54	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/12 to 12/31/14	0.2	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	1/1/12 to 12/31/14	4	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	1/1/14 to 12/31/14	1.70	1.00 to 2.50	ppm	4	4	Water additive used to control microbes
73. TTHM [Total tri-halomethanes]	N	2012*	1.30	None	ppb	0	80	By-product of drinking water chlorination
HAA5	N	2012*	3.0	None	ppb	0	60	By-product of drinking water chlorination

* Most recent sample results available

TALLAHALA WATER ASSOCIATION-TED CLEAR PWS ID# 0310019

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N		.0096	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N		5.4	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/12 to 12/31/14	0.3	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	1/1/12 tp 12/31/14	2	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	1/1/14 to 12/31/14	1.80	1.00 to 2.40	ppm	4	4	Water additive used to control microbes
73. TTHM [Total tri-halomethanes]	N	2012*	8.02	No Range	ppb	0	80	By-product of drinking water chlorination
HAA5	N	2012*	8.0	No Range	ppb	0	60	By-product of drinking water chlorination

* Most recent sample result available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Tallahala Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested..

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the paper will not be mailed. Please call our office if you would like a copy or have any questions.

RECEIVED - WATER SUPPLY
2015 MAY 15 AM 8:51

**PROOF OF PUBLICATION
THE STATE OF MISSISSIPPI
COUNTY OF JONES
1st & 2nd Judicial District**

PERSONALLY appeared before me, the undersigned notary public in and for Jones County, Mississippi, Melissa Carter, the Legal/Classifieds Manager of The Laurel Leader-Call, a Newspaper as defined and prescribed in, Section 13-3-31 of the Mississippi Code 1972, as amended, who, being duly sworn, states that the notice, a true copy of which is hereto attached, appeared in the issues of said newspaper as follows:

On the 30th day of April 2015

On the _____ day of _____ 2015

On the _____ day of _____ 2015

On the _____ day of _____ 2015

Melissa Carter
Affiant

Sworn to and subscribed before me on this 30th day of April, A.D., 2015.

[Signature]
Notary Public



FIRST-CLASS MAIL
PRESORTED
US POSTAGE PAID
ZIP CODE 39422
PERMIT # 47

Billed ~~04/30/15~~ portion with payment.

YOU OWE 72.00 by 05/15/15
After 05/15/15 pay 79.20

RECEIVED - WATER SUPPLY
2015 MAY 15 AM 8:50
Acct# 011254000 456 CR 29
Return Service Requested
ROSE MARIE GREEN
456 COUNTY ROAD 29
BAY SPRINGS MS 39422-4606

Deliver payment to:

TALLAHALA WATER ASSOC.
PO BOX 354
BAY SPRINGS, MS 39422
601-764-2655

This institution is an equal opportunity provider and employer

Previous Balance: 0.00
RESIDENTIAL USED: 11400
PREV: 580010 PRES: 591410
72.00

YOU OWE 72.00 by 05/15/15

Last Pmt \$72.95 04/15/15 After 05/15/15 pay 79.20
ROSE MARIE GREEN
Svc: 03/15-04/15/15 (31 days) Acct# 011254000
456 CR 29

A copy of the Annual CCR report can be picked up at the Tallahala Water office.

[Signature]



FOR THE RECORD

 Jessica Lynn, 34 DUI first offense, careless driving (JCSO)	 Jody Ray Blakeney, 38 DUI first offense, careless driving (JCSO)	 Meagan Ireland, 19 Aggravated assault, no driver's license, contempt of court (JCSO)	 Willie E. Collins Jr., 29 Possession of controlled substance, contempt of court (LPO)	 Windell Drake, 54 Disturbing the peace (JCSO)	 George Evans, 53 DUI-first offense, careless driving (LPO)	 Darin Maurice Husband, 32 Possession of methamphetamine (JCSO)	 Jerry F. Martin, 34 Possession of marijuana first offense (LPO)
 Leagr D. Moore, 37 Possession of controlled substance with intent to distribute (LPO)	 Willie Leon Moore, 52 Federal violation, shoplifting-second offense (LPO)	 Shawn Anton Moore, 37 Possession of controlled substance with intent to distribute (LPO)	 Donnie Lee Horwood, 25 Sexual battery (JCSO)	 Joseph Donald Pope, 38 Embezzlement (JCSO)	 Kamara R. Powe, 31 Possession of controlled substance with intent to distribute (LPO)	 Justin L. Tillman, 23 Public drunkenness (LPO)	 Tracy L. Daniels-Shaw, 38 Possession of marijuana first offense, possession of methamphetamine, possession of paraphernalia, possession of controlled substance, probation violation (JCSO)
 Michelle Marie Traylor, 34 Possession of controlled substance (LPO)	 Jose Angel Vars, 38 Domestic violence (LPO)	 Deborah Ann Williams, 58 False reporting of a crime (JCSO)	 Brandon Joe Yates, 28 Possession of controlled substance (LPO)	This is a list of suspects who were arrested by local law enforcement officials for serious offenses over the past few days: JCSO: Jones County Sheriff's Department; LPO: Laurel Police Department; EPD: Ellsville Police Department; SPD: Sandersville Police Department; MDC&C: Miss. Department of Corrections; MHP: Miss. Highway Patrol			

Bond revoked for suspected drug-dealer

Moore was already out on bond from a May 2014 arrest on charges of a felon being in possession of a firearm.

Duo in SUV stop
Two men were in the Jones County Adult Detention Center on weapon and fleeing charges.

Rafael Tillery, 45, was being held on a \$10,000 bond on the weapons possession by a felon charge, and Darryn Keyes, 18, was held on \$15,000 for felony fleeing in a motor vehicle that stemmed from an incident Saturday.

Laurel police officer John

Passing on shoulder causes 3-car crash



Asper County women suffered minor injuries after three vehicles were involved in a crash on Interstate 95 on Tuesday morning. Jessica Bailey, 34, of the Blue Ridge Community had just merged onto I-95

Annual Drinking Water Quality Report
Tallahalla Water Association
PWS ID #0310001, 0310016 & 0310019
April 2015

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water supply consists of 12 wells that draw from the Spaw and Upper Wilcox Aquifers.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Tallahalla Water Association received lower and moderate susceptibility rankings to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Mack Lee or Stan Heard at 601-764-2655. We want your valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at the Tallahalla Water Association office at 5:00 p.m. Our Annual Meeting will be held on September 14, 2015 at the Jasper County Courthouse in Bay Springs at 7:30 p.m.

Tallahalla Water Association routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2014. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be naturally expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these substances does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TALLAHALLA WATER ASSOCIATION-ANTIDCH PWS ID# 0310001

TEST RESULTS

Contaminant	Violation Y/N	Concentration	Limit	Unit	Range of Results	Use	MCLG	MCL	Liability	Level of Contamination
Inorganic Contaminants										
14. Boron	M	5012	0.50	mg/L	None	ppm	1	1	1	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits
16. Copper	M	131416	0.3	mg/L	None	ppm	1.3	AL=1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
18. Fluoride	M	3021	0.3	mg/L	No Range	ppm	4	4	4	Enrichment of natural deposits; water which contains high levels of fluoride from fertilizer and chemical factories
11. Lead	N	11014	1	ppm	None	ppm	0	AL=15	0	Corrosion of household plumbing systems; erosion of natural deposits
Disinfectants & Disinfection By-Products										
Chlorine (as Cl ₂)	M	11014	1.50	mg/L	1.00 to 2.50	ppm	4	4	4	Water additive used to control microbes
11. THM4 (Total THM)	M	2012	1.00	mg/L	None	ppm	0	0	0	By-product of drinking water chlorination

TALLAHALLA WATER ASSOCIATION-GARLANDVILLE PWS # 0310016

TEST RESULTS

Contaminant	Violation Y/N	Concentration	Limit	Unit	Range of Results	Use	MCLG	MCL	Liability	Level of Contamination
Radioactive Contaminants										
3. Alpha radon	M	11014	4.0	mg/L	No Range	PCV1	0	0	0	Emission of natural deposits
8. Uranium	M	11014	0.3	mg/L	No Range	PCV1	0	0	0	Emission of natural deposits
Inorganic Contaminants										
10. Boron	N	2012	0.50	mg/L	No Range	ppm	1	1	1	Discharge of drilling waste; discharge from metal refineries; erosion of natural deposits
13. Chloride	M	2012	0.50	mg/L	No Range	ppm	100	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	M	11013	0.3	mg/L	None	ppm	1.3	AL=1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
11. Lead	N	11012	1	ppm	None	ppm	0	AL=15	0	Corrosion of household plumbing systems; erosion of natural deposits
Disinfectants & Disinfection By-Products										
Chlorine (as Cl ₂)	M	11014	1.50	mg/L	1.00 to 2.50	ppm	4	4	4	Water additive used to control microbes
11. THM4 (Total THM)	M	2012	1.00	mg/L	None	ppm	0	0	0	By-product of drinking water chlorination
HAAS	M	2012	1.0	mg/L	None	ppm	0	0	0	By-product of drinking water chlorination
Disinfectants & Disinfection By-Products										
Chlorine (as Cl ₂)	M	11014	1.50	mg/L	1.00 to 2.50	ppm	4	4	4	Water additive used to control microbes
11. THM4 (Total THM)	M	2012	0.01	mg/L	No Range	ppm	0	0	0	By-product of drinking water chlorination
HAAS	M	2012	0.0	mg/L	No Range	ppm	0	0	0	By-product of drinking water chlorination