

Mississippi Dept. of Health

Certification Form ✓

CWS name: Lumbard Utility District

PWS I.D. no: 0140009

The community water system named above hereby confirms that its consumer confidence report has been distributed to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the primacy agency.

Certified by:

Name Edna L. R.

Title President

Phone # 662-902-2466 Date 6/30/15

***You are not required by EPA rules to report the following information, but you may want to provide it to your state. Check all items that apply. ***

CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:

Hand delivered

___ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods as recommended by the primacy agency:

___ posting the CCR on the Internet at www. _____

___ mailing the CCR to postal patrons within the service area. (attach zip codes used)

___ advertising availability of the CCR in news media (attach copy of announcement)

___ publication of CCR in local newspaper (attach copy)

___ posting the CCR in public places (attach a list of locations)

___ delivery of multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers

___ delivery to community organizations (attach a list)

___ (for systems serving at least 100,000 persons) Posted CCR on a publicly-accessible Internet site at the address: www. _____

___ Delivered CCR to other agencies as required by the primacy agency (attach a list)

2015 JUL -1 PM 3: 24

Lu-Rand Utility District
PWS ID#0140009
2014 Consumer Confidence Report

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, & how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, & infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium & other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

The Lu-Rand Utility District water source consists of two wells that draw from the Meridian-Upper Wilcox Aquifer.

Where does my water come from?

The Lu-Rand Utility District water source consists of two wells that draw from the Meridian-Upper Wilcox Aquifer.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants & potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water & bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, & wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals &, in some cases, radioactive material, & can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses & bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, & wildlife; inorganic contaminants, such as salts & metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil & gas production, mining, or farming; pesticides & herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, & residential uses; organic Chemical Contaminants, including synthetic & volatile organic chemicals, which are by-products of industrial processes & petroleum production, & can also come from gas stations, urban storm water runoff, & septic systems; & radioactive contaminants, which can be naturally occurring or be the result of oil & gas production & mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food & Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

If you have any questions about this report or concerning your water utility, please contact Lisa Liles at (662)902-1526. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Thursday at 6:00 PM at the Evelyn Mullens residence at 8925 Hwy. 49 South.

Description of Water Treatment Process

Your water is treated in a "treatment train" (a series of processes applied in a sequence) that includes coagulation, flocculation, sedimentation, filtration, & disinfection. Coagulation removes dirt & other particles suspended in the source water by adding chemicals (coagulants) to form tiny sticky particles called "floc," which attract the dirt particles. Flocculation (the formation of larger flocs from smaller flocs) is achieved using gentle, constant mixing. The heavy particles settle naturally out of the water in a sedimentation basin. The clear water then moves to the filtration process where the water passes through sand, gravel, charcoal or other filters that remove even smaller particles. A small amount of chlorine or other disinfection method is used to kill bacteria & other microorganisms (viruses, cysts, etc.) that may be in the water before water is stored & distributed to homes & businesses in the community.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost & no-cost ways to conserve water. Small changes can make a big difference -- try one today & soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair & shaving & save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, & can save you up to 750 gallons a month.
- Run your clothes washer & dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets & faucets. Faucet washers are inexpensive & take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank & wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it & during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Cross Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations & insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, & if needed, survey your connection & assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women & young children. Lead in drinking water is primarily from materials & components associated with service lines & home plumbing. Lu-Rand Utility District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, & steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, & in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water & have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms & abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

	MCLG or	MCL, TT, or	Your	Range	Sample		
--	------------	----------------	------	-------	--------	--	--

<u>Contaminants</u>	<u>MRDLG</u>	<u>MRDL</u>	<u>Water</u>	<u>Low</u>	<u>High</u>	<u>Date</u>	<u>Violation</u>	<u>Typical Source</u>
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	0.9	0.17	1.6	2014	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	13	6	14	2014	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	40.39	21.6	40.39	2014	No	By-product of drinking water disinfection

Inorganic Contaminants								
Arsenic (ppb)	0	10	2.5	1.8	2.5	2014	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.0241	0.0238	0.0241	2014	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	100	100	4.4	1.8	44	2014	No	Discharge from steel & pulp mills; Erosion of natural deposits
Fluoride (ppm)	4	4	0.564	0.442	0.564	2014	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer & aluminum factories
Selenium (ppb)	50	50	10	7.2	10	2014	No	Discharge from petroleum & metal refineries; Erosion of natural deposits; Discharge from mines

<u>Contaminants</u>	<u>MCLG</u>	<u>AL</u>	<u>Your Water</u>	<u>Sample Date</u>	<u># Samples Exceeding AL</u>	<u>Exceeds AL</u>	<u>Typical Source</u>
Inorganic Contaminants							
Lead - action level at consumer taps (ppb)	0	15	0.003	2014	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Copper - action level at consumer taps (ppm)	1.3	1.3	0.3	2014	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

<u>Contaminants</u>	<u>MCLG or MRDLG</u>	<u>MCL or MRDL</u>	<u>Your Water</u>	<u>Violation</u>	<u>Typical Source</u>
Nitrite [measured as Nitrogen] (ppm)	1	1	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrate [measured as Nitrogen] (ppm)	10	10	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	ND	No	Discharge from plastic & fertilizer factories; Discharge from steel/metal factories
Uranium (ug/L)	0	30	ND	No	Erosion of natural deposits

Radium (combined 226/228) (pCi/L)	0	5	ND	No	Erosion of natural deposits
Alpha emitters (pCi/L)	0	15	ND	No	Erosion of natural deposits
Unit Descriptions					
Term	Definition				
ug/L	ug/L : Number of micrograms of substance in one liter of water				
ppm	ppm: parts per million, or milligrams per liter (mg/L)				
ppb	ppb: parts per billion, or micrograms per liter (µg/L)				
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)				
NA	NA: not applicable				
ND	ND: Not detected				
NR	NR: Monitoring not required, but recommended.				
Important Drinking Water Definitions					
Term	Definition				
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.				
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.				
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.				
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.				
Variances & Exemptions	Variances & Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.				
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.				
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.				
MNR	MNR: Monitored Not Regulated				
MPL	MPL: State Assigned Maximum Permissible Level				
For more information please contact:					

Contact Name: Eddie Bright
Address: POB 265, Clarksdale, MS 38614
Phone: 662-902-2466

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost & no-cost ways to conserve water. Small changes can make a big difference – try one today & soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair & shaving & save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, & can save you up to 750 gallons a month.
- Run your clothes washer & dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets & faucets. Faucet washers are inexpensive & take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank & wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it & during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Cross Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations & insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, & if needed, survey your connection & assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women & young children. Lead in drinking water is primarily from materials & components associated with service lines & home plumbing. Lu-Rand Utility District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, & steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, & in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water & have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms & abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

	MCLG or	MCL, TT, or	Your	Range	Sample		
--	------------	----------------	------	-------	--------	--	--

Contaminants	MRDLG	MRDL	Water	Low	High	Date	Violation	Typical Source
Disinfectants & Disinfectant By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	0.9	0.17	1.6	2014	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	13	6	14	2014	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	40.39	21.6	40.39	2014	No	By-product of drinking water disinfection
Inorganic Contaminants								
Arsenic (ppb)	0	10	2.5	1.8	2.5	2014	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.0241	0.0238	0.0241	2014	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	100	100	4.4	1.8	44	2014	No	Discharge from steel & pulp mills; Erosion of natural deposits
Fluoride (ppm)	4	4	0.564	0.442	0.564	2014	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer & aluminum factories
Selenium (ppb)	50	50	10	7.2	10	2014	No	Discharge from petroleum & metal refineries; Erosion of natural deposits; Discharge from mines
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Lead - action level at consumer taps (ppb)	0	15	0.003	2014	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Copper - action level at consumer taps (ppm)	1.3	1.3	0.3	2014	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL or MRDL	Your Water	Violation	Typical Source
Nitrite [measured as Nitrogen] (ppm)	1	1	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrate [measured as Nitrogen] (ppm)	10	10	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Cyanide [as Free Cn] (ppb)	200	200	ND	No	Discharge from plastic & fertilizer factories; Discharge from steel/metal factories
Uranium (ug/L)	0	30	ND	No	Erosion of natural deposits

Radium (combined 226/228) (pCi/L)	0	5	ND	No	Erosion of natural deposits
Alpha emitters (pCi/L)	0	15	ND	No	Erosion of natural deposits

Unit Descriptions

Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances & Exemptions	Variances & Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Eddle Bright
Address: POB 265, Clarksdale, MS 38614
Phone: 662-902-2466