

MISSISSIPPI STATE DEPARTMENT OF HEALTH: 58
BUREAU OF PUBLIC WATER SUPPLY

CCR CERTIFICATION
CALENDAR YEAR 2015

Kossuth Water Association, Inc.
Public Water Supply Name

0020007, 0020008, 0020004

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 06/09/2016 / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ / ___

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: ___ / ___ / ___

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Daily Corinthian

Date Published: 06/09/2016

CCR was posted in public places. *(Attach list of locations)*

Date Posted: ___ / ___ / ___

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the 2015 Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply.

[Signature]
Name/Title (President, Mayor, Owner, etc.)

6-14-16
Date

Deliver or send via U.S. Postal Service:
Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

May be faxed to:
(601)576-7800

May be emailed to:

CCR Due to MSDH & Customers by July 1, 2016!

water.reports@msdh.ms.gov

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Coffee Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Kossuth Water have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Aaron C. Henry at 662-287-4310. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Monday of each month at 6:00 PM at the water office.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID# 0020007		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria	Y	July 2015	Positive	3	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment

2016 JUN 16 PM 1:58

Radioactive Contaminants									
5. Gross Alpha	N	2013*	1	.6 - 1				15	Erosion of natural deposits
Inorganic Contaminants									
8. Arsenic	N	2014*	.7	No Range	ppb	n/a		10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2014*	.2167	.1741 - .2167	ppm	2		2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	4.4	3.4 - 4.4	ppb	100		100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14*	.1	0	ppm	1.3	AL=1.3		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014*	.106	No Range	ppm	4		4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	2	0	ppb	0	AL=15		Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2014*	2.9	No Range	ppb	50		50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfection By-Products									
82. TTHM [Total trihalomethanes]	N	2014*	1.01	No Range	ppb	0		80	By-product of drinking water chlorination.
Chlorine	N	2015	1.3	1 - 1.5	mg/l	0	MDRL = 4		Water additive used to control microbes

PWS ID# 0020008		TEST RESULTS							
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination	
Radioactive Contaminants									
5. Gross Alpha	N	2013*	.4	No Range	pCi/L	0		15	Erosion of natural deposits
Inorganic Contaminants									
10. Barium	N	2014*	.136	No Range	ppm	2	2		Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	2.5	No Range	ppb	100	100		Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14*	.2	0	ppm	1.3	AL=1.3		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2012/14*	3	0	ppb	0	AL=15		Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products									
Chlorine	N	2015	1.2	.8- 1.4	mg/l	0	MDRL = 4		Water additive used to control microbes

2016 JUN 16 PM 1:58

* *Most recent sample. No sample required for 2015.*

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

We routinely monitor for the presence of drinking water contaminants. In July 2015 on System 20004, which 20007 now serves we took 11 samples for coliform bacteria. Three of those samples showed the presence of coliform bacteria. After resampling a couple of time we did not find any bacteria in our subsequent testing and further testing shows that this problem has been resolved.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Kossuth Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

2015 Annual Drinking Water Quality Report
 Kossuth Water
 PWS#: 0020007 & 0020008
 May 2016

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Coffee Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Kossuth Water have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Aaron C. Henry at 662-287-4310. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Monday of each month at 6:00 PM at the water office.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2015. In cases where monitoring wasn't required in 2015, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID# 0020007		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Microbiological Contaminants								
1. Total Coliform Bacteria	Y	July 2015	Positive	3	NA	0	presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment

Radioactive Contaminants									
5. Gross Alpha	N	2013*	1	.6 - 1	pCi/L	0		15	Erosion of natural deposits
Inorganic Contaminants									
8. Arsenic	N	2014*	.7	No Range	ppb	n/a		10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2014*	.2167	.1741 - .2167	ppm	2		2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	4.4	3.4 - 4.4	ppb	100		100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14*	.1	0	ppm	1.3	AL=1.3		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2014*	.106	No Range	ppm	4		4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	2	0	ppb	0	AL=15		Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2014*	2.9	No Range	ppb	50		50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Disinfection By-Products									
82. TTHM [Total trihalomethanes]	N	2014*	1.01	No Range	ppb	0		80	By-product of drinking water chlorination.
Chlorine	N	2015	1.3	1 - 1.5	mg/l	0	MDRL = 4		Water additive used to control microbes

PWS ID# 0020008 TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL		Likely Source of Contamination
Radioactive Contaminants									
5. Gross Alpha	N	2013*	.4	No Range	pCi/L	0		15	Erosion of natural deposits
Inorganic Contaminants									
10. Barium	N	2014*	.136	No Range	ppm	2		2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	2.5	No Range	ppb	100		100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2012/14*	.2	0	ppm	1.3	AL=1.3		Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2012/14*	3	0	ppb	0	AL=15		Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products									
Chlorine	N	2015	1.2	.8- 1.4	mg/l	0	MDRL = 4		Water additive used to control microbes

** Most recent sample. No sample required for 2015.*

Microbiological Contaminants:

(1) Total Coliform. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

We routinely monitor for the presence of drinking water contaminants. In July 2015 on System 20004, which 20007 now serves we took 11 samples for coliform bacteria. Three of those samples showed the presence of coliform bacteria. After resampling a couple of time we did not find any bacteria in our subsequent testing and further testing shows that this problem has been resolved.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy; persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Kossuth Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of your drinking water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Coffey Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Kosuth Water have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Aaron C. Henry at 782-8331. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Monday of each month at 9:00 PM at the water office.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2015. If any were not required in 2015, the table reflects the most recent results. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity. Microbial contaminants, such as viruses and bacteria, that may come from septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and grease, pesticides and herbicides, which may come from a variety of sources such as agriculture, urban runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand the terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. This level is set to ensure that disinfection is sufficient to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or one penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years or one penny in \$10,000,000.

PWS ID# 0020007		TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Collected	Range of Detects or # of Samples Exceeding MCL/AQL	Unit Measurement	MCLG	MCL	Likely to Exceed	Source of Contamination	Notes	
Microbiological Contaminants											
1. Total Coliform Bacteria	Y	July 2015	Positive	3	NA	0	presence of coliform bacteria in monthly samples	1	usually present in the environment		
Radioactive Contaminants											
5. Gross Alpha	N	2015*	1	0-1	pCi/L	0		5	emanation of natural radionuclides		
Inorganic Contaminants											
3. Arsenic	N	2014*	0.7	No Range	ppb	na	10	10	Erosion of naturally occurring arsenic from glacial till from pipes and other production wastes		
10. Barium	N	2014*	2187	1741 - 2157	ppm	2	2	2	Discharge from industrial refineries, electrical generation, and other sources		
13. Chromium	N	2014*	4.4	3.4 - 4.4	ppb	100	100	100	Discharge from industrial refineries and pulp mills, and other sources		
14. Copper	N	2012/14*	1	0	ppm	1.3	AL=1.3	1.3	Corrosion of household plumbing system, erosion of natural deposits from wood preservatives		
16. Fluoride	N	2014*	1.00	No Range	ppm	4	4	4	Erosion of naturally occurring water soluble fluorides from natural deposits		
17. Lead	N	2012/14*	2	0	ppb	0	AL=15	15	Corrosion of household plumbing system, erosion of natural deposits		
21. Selenium	N	2014*	3.9	No Range	ppb	50	50	50	Discharge from industrial refineries and other sources, erosion of natural deposits		
Disinfection By-Products											
82. THM (Total Trihalomethanes)	N	2014*	1.01	No Range	ppb	0	80	80	By-product of chlorination		
Chlorine	N	2015	1.3	1 - 1.6	mg/l	0	MDRL=4	4	Water source used for disinfection		

Sample ID	Date	Location	Parameter	Result	Unit	Standard	Notes
111	8/11/15	Well 1	Lead	0.0	ppm	1.3	AL=1.3
112	8/11/15	Well 2	Lead	0.0	ppm	1.3	AL=1.3
113	8/11/15	Well 3	Lead	0.0	ppm	1.3	AL=1.3
114	8/11/15	Well 4	Lead	0.0	ppm	1.3	AL=1.3
115	8/11/15	Well 5	Lead	0.0	ppm	1.3	AL=1.3

Drinking Water System

We routinely monitor for the presence of drinking water contaminants. In July 2015, on System 20004, which 20007 new services we took 11 samples for coliform bacteria. Three of those samples showed the presence of coliform bacteria. After re-sampling a couple of times we did not find any bacteria in our subsequent testing and further testing shows that the problem has been resolved.

As you can see by the table, our system had no violations. After a period that your drinking water, piping or cesspits all federal and state requirements. We have learned through our monitoring and testing that some consumers have been notified however the EPA has determined that your water is safe. It does not.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Based on regular monitoring and an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems compliance we monitoring requirements. ASHRAE now modifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to reduce exposure is available from the State Drinking Water Hotline or at <http://www.epa.gov/leadinwater>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7522 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Infants and young children, pregnant women, the elderly, and people with compromised immune systems, such as persons with cancer, undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some kidney, and infants can be particularly at risk from contaminants. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the State Drinking Water Hotline, 1-800-426-4791.

The Kossuth Water Association works around the clock to provide you quality water to every tap. We ask that all of our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

STATE OF MISSISSIPPI,
COUNTY OF ALCORN

PERSONALLY CAME before me, the undersigned, a Notary Public in and for Alcorn County, Mississippi, the CLERK of THE DAILY CORINTHIAN, a newspaper published in the City of Corinth, First Judicial District of Alcorn County, in said State, who being sworn, deposes and says that THE DAILY CORINTHIAN is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1833, of the Mississippi Code of 1942, and that the publication of a notice, of which the annexed is a copy, in the manner of:

Water Quality Report

has been made in said paper 1 times consecutively, to-wit:

On the 9 day of June, 2016

On the _____ day of _____, 20____



SWORN TO and subscribed before me this

9 day of June, 2016

Sharon Terry
Notary Public

Jeanie Ellison
Clerk

Corinth, Miss., _____, 20____

To THE DAILY CORINTHIAN, Dr.
(Name Newspaper)

TO PUBLISHING Water Quality Report

case of _____

4 X 18

words-space

1 times and making proof, \$ 607.80

RECEIVED OF _____

payment in full of the above amount.

_____, 20____

Handwritten notes and stamps including "words-space", "4 X 18", "6-15-16", "69157", and a circled amount "\$1607.80".

PROOF OF PUBLICATION

The State of Mississippi,
County of Smith

PERSONALLY CAME before me, the undersigned a
Notary Public in and for SMITH COUNTY,
MISSISSIPPI the OFFICE CLERK of the SMITH
COUNTY REFORMER, a newspaper published in the
Town of Raleigh, Smith County, in said State, who being
duly sworn, deposes and says that the SMITH COUNTY
REFORMER is a newspaper as defined and prescribed in
§ 13-3-31 of the Mississippi Code 1972 Annotated and
that the publication of a notice, of which the annexed is a
copy, in the matter of

Lorena Lemon Burns Water Association- Water
Report

has been made in said paper 1 times consecutively,
to-wit:

On the 18 day of May 2016

On the day of 2016

On the day of 20 16

On the day of 2016

Felicia Earnest
OFFICE CLERK

SWORN to and subscribed before me, this the

STATE OF MISSISSIPPI
NOTARY PUBLIC
ID # 107639
ANGELA M. BROWN
Commission Expires 01/12/2018
NOTARY PUBLIC
JASPER COUNTY

Words

Cost



Woods
of Raleigh
home. The
least.

Meeting

Secretary,
Treasurer,
orian, Mary
mentarian,
being to
the floor,
officers was
ved.

Meeting will
tion of offi-
kins, imme-
of MFWC
Meeting will
Luncheon
ryone was
g an inter-
hy favorite,
re with the

I to have a
June 16, at
por prize, a
filled with
n by Cindy

adjourned
arris.

Lee Martin,
ter, Saman-

whose idea
duating as-
d a "wax-
elementary
where most
in students.
ho enjoyed
more or the

It has done a lot in
the community for me to now
all of my year. In places the
grass looks like hay. I was
able to move on Wednesday
morning and it looks much
better now.

The singing at Mober Springs
last Saturday evening featur-
ing "Calm Assurance" was very
enjoyable and being here was
time well spent. I of Arnder
helped the group sing a song
and he did a great job. If you
ever get a chance to hear the
group, I believe you will really
enjoy them. The reason for the
singing was to go to school.

Sunday Morning our ser-
vices included Mother's Day
and Baccalaureate. Our
seniors were Anna Sartor
and Evan Webb. Just is the
daughter of Melissa and Randy
Sartor. She was a Mississippi
Scholar, and received an ACT
Scholarship to C.C. Evan
Webb is the son of Lisa and
Chris Webb. Evan was a Miss-
issippi Scholar with scholar-
ship offers from MESA and
JJC. These two scholars are
to be commended for their
achievements and I wish the
best for them in the future.

Bro. Steve Davis led our
Bible study at Mober Springs
on Monday night. He did a
great job.

Steve Johnson is in in-
tensive care now with a se-
vere lung infection. Would
you please check in on your
prayers.

Visitors at Unity Methodist
Church on Mother's Day were
Carroll and Elaine Harkins'
daughter, Carrie, and her hus-
band, Kerry Atwood and their
daughters, Katie and Kelsey
and her friend.

Joey Hingston and Lona,
Sam and Lily attended with
Ridger and Bend in Hingston.

It was nice to see them hon-
oring their mother and grand-
mothers.

Johnny and Carly Barr
had a busy weekend in week
supporting their granddaugh-
ter Emily Webb. They went to
Madison for the Lady Tartars'

YA
Sul
Yal
aid
G
lei
Ap
Ut
oy
pri
the
wi
ho
Cj
the
co
lec
Al
lec
At
Hi
mi
of
xi
th
R
bu
gr
re
ar
By
U
gr
M
Y
m
be
wi
al
en