

2017 MAY -1 AM 9:09

CERTIFICATION

Consumer Confidence Report (CCR)

Good Hope Water Association

Public Water Supply Name

0330004

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill) 4-28-2017
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 4/28/2017 / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / /

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: _____ / /

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: _____ / /

CCR was posted in public places. *(Attach list of locations)*

Date Posted: 4/21/2017

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

http://msrwa.org/2016CCR/goodhope.pdf

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Thomas Amick
Name/Title (President, Mayor, Owner, etc.)

4-28-17
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Fax: (601) 576 - 7800

Email: water.reports@msdh.ms.gov

CCR Deadline to MSDH & Customers by July 1, 2017!

2016 Annual Drinking Water Quality Report
 Good Hope Water Association
 PWS#: 0330004
 April 2017

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Miocene Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Good Hope Water Association have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Sidney T. Fails at 601-943-6619. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the annual meeting to be held June 22, 2017 at 7:00 PM at the Bassfield City Hall.

The Good Hope Water Association routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2016. In cases where monitoring wasn't required in 2016, the table reflects the most recent results. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

| TEST RESULTS | | | | | | | | |
|----------------------------------|---------------|----------------|----------------|--|------------------|------|----------|---|
| Contaminant | Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL | Likely Source of Contamination |
| Inorganic Contaminants | | | | | | | | |
| 10. Barium | N | 2015* | .017 | No Range | ppm | 2 | 2 | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits |
| 19. Nitrate (as Nitrogen) | N | 2016 | .62 | No Range | ppm | 10 | 10 | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits |
| Disinfection By-Products | | | | | | | | |
| 82. TTHM [Total trihalomethanes] | N | 2014* | 1 | No Range | ppb | 0 | 80 | By-product of drinking water chlorination. |
| Chlorine | N | 2016 | 1 | .50 – 1.5 | mg/l | 0 | MDRL = 4 | Water additive used to control microbes |

** Most recent sample. No sample required for 2016.*

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Good Hope Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.



GOOD HOPE WATER ASSOCIATION
 P.O. BOX 177
 45 HAWKINS AVENUE
 BASSFIELD, MISSISSIPPI 39421
 (601) 943-6619
 CALL BEFORE YOU DIG. 811

RETURN SERVICE REQUESTED

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 BASSFIELD MS
 PERMIT NO. 03

| TYPE OF SERVICE | METER READING | | USED | CHARGES |
|-----------------|---------------|----------|-------|---------|
| | PRESENT | PREVIOUS | | |
| Water | 249000 | 248000 | 1,000 | 22.00 |

| CUSTOMER | | PAY GROSS AMOUNT AFTER THIS DATE |
|-----------------------|---------|-------------------------------------|
| ROUTE | ACCOUNT | |
| 2 | 336 | 5/20/17 |
| NET AMOUNT TO BE PAID | | GROSS AMOUNT TO BE PAID |
| 22.00 | | 27.00 |

MAIL THIS STUB WITH YOUR PAYMENT

2

| Service From 3/27/2017 TO 4/25/2017 | | | ACCOUNT 336 | 4/27/17 | |
|-------------------------------------|-----|-------|------------------------|----------------------------|-----------------|
| METER READ MONTH | DAY | CLASS | TOTAL DUE UPON RECEIPT | LATE CHARGE AFTER DUE DATE | PAST DUE AMOUNT |
| 4 | 25 | 1 | 22.00 | 5.00 | 27.00 |

FAILS VICKIE
 5934 N. WILLIAMSBURG RD
 BASSFIELD MS 39421

The Consumer Confidence Report (CCR) for 2016 is available for review at <http://www.msrwa.org/2016ccr/goodhope.pdf>
 Members can request a copy to be sent by mail by calling the office at 601-943-6619 or view the CCR at the GH office.

Good Hope Water Association
Public Posting Place :

1) Good Hope Water Payment Office
45 Hawkins Ave
Bassfield, MS 39421

2) Town of Bassfield
City Hall Office
Bassfield, MS 39421