

2017 JUN -8 AM 8:43

CERTIFICATION

Consumer Confidence Report (CCR)
Nesbit Water Assn.

Public Water Supply Name

070014

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: ____ / ____ / ____ , ____ / ____ / ____ , ____ / ____ / ____

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ____ / ____ / ____

CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: ____ / ____ / ____

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Desoto Times Tribune

Date Published: 6/1/17

CCR was posted in public places. *(Attach list of locations)* Date Posted: ____ / ____ / ____

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Richard S. Sullivan Office Mng.
Name/Title (President, Mayor, Owner, etc.)

6/6/17
Date

Submission options *(Select one method ONLY)*

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Fax: (601) 576 - 7800

Email: water.reports@msdh.ms.gov

CCR Deadline to MSDH & Customers by July 1, 2017!

ganization's mission and progress on its develop- ment between Hernando- north Mississippi. "This is going to be a big education plus, not be returned to the wild remain and become a means of educating and appropriate wildlife.

AFFP

PN: Water Quality Report

Affidavit of Publication

DESOTO TIMES-TRIBUNE

STATE OF MS }
COUNTY OF DESOTO } SS

NESBIT WATER ASSOC.
JUNE 1, 2017

Diane Smith, being duly sworn, says:

That she is a Clerk of the DESOTO TIMES-TRIBUNE, a newspaper of general circulation in said county, published in Hernando, DeSoto County, MS; that the publication, a copy of which is printed hereon, was published in the said newspaper on the following dates:

June 01, 2017

That said newspaper was regularly issued and circulated on those dates.

SIGNED:

Diane Smith

Clerk

Subscribed to and sworn to me this 1st day of June 2017.


Kimberly Bevineau

KIMBERLY BEVINEAU, Notary, DeSoto County, MS

My commission expires: January 18, 2020

00003184 00052015

Rochelle
Nesbit Water Association
P O Box 35
999 Dean Road
Nesbit, MS 38651



Audit of Publication

O TIMES-TRIBUNE
(OF DESOTO) SS

being duly sworn, says:

I am a Clerk of the DESOTO TIMES-TRIBUNE of general circulation in said county of Desoto County, MS; that the publication is printed hereon, was published on the following dates:

2017

I, *James Smith*, a newspaper was regularly issued and published.

and sworn to me this 1st day of

Shelly Beville
Shelly Beville, Notary, Desoto County

Commission expires: January 18, 2020

84 00052015

Water Association
an Road
MS 38651

Water Quality Report is prepared to present to you the yearly Annual Quality Water Report. This report is designed to inform you about the quality of water and services provided to you by Nesbit Water Association, Inc. Our overall goal is to provide you with a safe and dependable supply of drinking water. We want you to be confident in the quality of the water you receive. We are committed to providing you with the highest quality water possible. We are committed to providing you with the highest quality water possible. We are committed to providing you with the highest quality water possible.

If you have any questions about this report or concerning your water utility, please contact Nesbit Water Association at 662-428-6800. We want our customers to be satisfied with their water utility. If you want to learn more, please contact any of our regularly scheduled meetings. They are held on the 1st Thursday of the month at 6:00 PM at 801 Pleasant Hill Rd, Nesbit, MS 38651.

The most commonly used method for determining water quality is by testing water samples. This is done by taking water samples from various locations throughout the system and testing them for various contaminants. The most common contaminants are lead, copper, iron, manganese, and nitrate. Other contaminants include bacteria, viruses, and pesticides. The results of the testing are used to determine if the water is safe to drink.

In this table you will find every item and substance you might not be familiar with. To help you better understand these items we've provided the following descriptions:
Ascorbic Acid - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Maximum Contaminant Level Goal (MCLG) - The "Maximum Allowable" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLGs are set at a level that is deemed to be safe. MCLGs are based on the latest scientific knowledge of the health effects of the contaminant. MCLGs are not enforceable because they are based on a theoretical population that is not likely to be exposed to the contaminant for a significant portion of their lives.

TEST RESULTS

Contaminant	Unit	Value	MCLG	MCL	Sample Source or Collection Method
INORGANIC CONSTITUENTS					
10. Arsenic	ppm	0.01	0.01	0.01	1
11. Barium	ppm	10	10	10	1
12. Cadmium	ppm	0.001	0.001	0.001	1
13. Chloride	ppm	100	100	100	1
14. Copper	ppm	1.3	1.3	1.3	1
15. Fluoride	ppm	0.7	0.7	0.7	1
16. Lead	ppb	0	0	0	1
17. Manganese	ppm	0.05	0.05	0.05	1
18. Nitrate (as nitrogen)	ppm	10	10	10	1
19. Selenium	ppm	0.01	0.01	0.01	1
20. Silver	ppm	0.01	0.01	0.01	1
21. Sulfate	ppm	100	100	100	1
22. Total Dissolved Solids	ppm	100	100	100	1
23. Total Hardness	ppm	100	100	100	1
24. Total Suspended Solids	ppm	10	10	10	1
25. Zinc	ppm	0.3	0.3	0.3	1
Disinfection By-Products					
26. Bromoform	ppb	0	0	0	1
27. Chloroform	ppb	0	0	0	1
28. Dichloroacetic Acid	ppb	0	0	0	1
29. Haloacetic Acids (HAA5)	ppb	0	0	0	1
30. Haloacetonitriles	ppb	0	0	0	1
31. Haloketones	ppb	0	0	0	1
32. Halonitriles	ppb	0	0	0	1
33. Haloacetaldehydes	ppb	0	0	0	1
34. Haloacetonitriles	ppb	0	0	0	1
35. Haloacetylaldehydes	ppb	0	0	0	1
36. Haloacetylaldehydes	ppb	0	0	0	1
37. Haloacetylaldehydes	ppb	0	0	0	1
38. Haloacetylaldehydes	ppb	0	0	0	1
39. Haloacetylaldehydes	ppb	0	0	0	1
40. Haloacetylaldehydes	ppb	0	0	0	1
41. Haloacetylaldehydes	ppb	0	0	0	1
42. Haloacetylaldehydes	ppb	0	0	0	1
43. Haloacetylaldehydes	ppb	0	0	0	1
44. Haloacetylaldehydes	ppb	0	0	0	1
45. Haloacetylaldehydes	ppb	0	0	0	1
46. Haloacetylaldehydes	ppb	0	0	0	1
47. Haloacetylaldehydes	ppb	0	0	0	1
48. Haloacetylaldehydes	ppb	0	0	0	1
49. Haloacetylaldehydes	ppb	0	0	0	1
50. Haloacetylaldehydes	ppb	0	0	0	1

* A fact sheet is available for this contaminant. For more information, please contact the U.S. Environmental Protection Agency at 1-800-424-9333. ** This table is intended to provide information only and is not a substitute for a full water quality report. For more information, please contact the U.S. Environmental Protection Agency at 1-800-424-9333.

RECEIVED-WATER SUPPLY
 2016 Annual Drinking Water Quality Report
 Nesbit Water Association, Inc.
 PWS#: 0170014
 May 2017

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Rochelle Sullivan at 662.429.8800. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Thursday of the month at 4:00 PM at 901 Pleasant Hill Rd, Nesbit, MS 38651.

Our water source is from wells drawing from the Sparta Sand Aquifer. We also purchase water from the City of Southaven. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Nesbit Water Association, Inc. have received moderate susceptibility rankings to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2016. In cases where monitoring wasn't required in 2016, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID # 0170014		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2014*	.0184	.181 - .184	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2012/14*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

16. Fluoride**	N	2014*	.966	.956-- .999	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2012/14*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2016	.41	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2014*	5	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2014*	3.39	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2016	1.2	1 – 1.3	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2016.

** Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.7 - 1.3 mg/l.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the NESBIT WATER ASSOCIATION is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year that average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 100%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Nesbit Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.