

2017 JUN -1 AM 8:19

# CERTIFICATION

## Consumer Confidence Report (CCR)

Linn County Rural WPA Pleasant Ridge  
Public Water Supply Name

0430003

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other \_\_\_\_\_

Date(s) customers were informed: 5/17/17, 1/1/17, 5/25/17

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: 1/1/17

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: 1/1/17

- As a URL (Provide URL \_\_\_\_\_)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Cape Girardeau Courier - The Daily Leader

Date Published: 5/17/17 5-25/17

CCR was posted in public places. *(Attach list of locations)*

Date Posted: 5/25/17

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

in the Office

### CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Jenny Capil  
Name/Title (President, Mayor, Owner, etc.)

5/25/17  
Date

### Submission options (Select one method ONLY)

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Fax:** (601) 576 - 7800

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**CCR Deadline to MSDH & Customers by July 1, 2017!**

**QUALITY ON TAP CCR'S REPORT  
LINCOLN RURAL WATER ASSOCIATION  
Pleasant Ridge  
PWS ID# 430003**

**June 13, 2017**

Lincoln Rural Water is pleased to present to you, this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two wells pumping from the Miocene Aquifer.

We are pleased to report that our drinking water meets all federal and state requirements. The following reports show our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact **our office at 1536 Monticello Street, Brookhaven, MS 39602, 601-833-6449**. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on **the 3<sup>rd</sup> Tuesday of each month at the above location at 7:00 P.M. and our annual meeting is held on the 2nd Monday of March at the Lincoln County Courthouse at 7:00 P.M.**

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detail information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for Lincoln Rural Water have received a moderate and lower ranking in terms of susceptibility to contamination.

**Lincoln Rural Water Association** routinely monitors for many constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, **2016**. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. . More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal (MCLG) is the level of a contaminant in drinking water below which there is no know or expected risk to health. MCLGs allow for a margin of safety.

**Addition information for Lead**

If present elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. ABC Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about leak in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/sagewater/lead>. The Mississippi State Department of Health Laboratory offers lead testing for \$20.00 per sample. Please contact 601.576.7582 if you wish to have your water tested.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential source of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the LINCOLN RURAL ASSOCIATION have received lower rankings in terms of susceptibility to contamination.

## Test Results

#0430003 Pleasant Ridge

Contaminants	MCLG	MCL,	Your	Range		Sample	Violation	Typical Source
	or	TT, or		Low	High			
	MRDLG	MRDL	Water			Date		
<b>Disinfectants &amp; Disinfection By-Products</b>								
Chlorine (as Cl <sub>2</sub> ) (ppm)	4	4	1.20	.90	1.50	2016	No	Water additive used to control microbes
<b>Inorganic Contaminants</b>								
Nitrate [measured as Nitrogen]	10	10	.26	NA		2016	No	Runoff from fertilizer use; Leaching from septic tanks, Sewage; Erosion of natural deposits
Nitrite [Measured as Nitrogen]	10	10	0.18	NA		2015	No	Runoff from fertilizer use; Leaching from septic tanks. Sewage; Erosion of natural deposits
Arsenic (ppb)	0	10	.0006	NA		2016	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Fluoride (ppm)	4	4	0.135	NA		2016	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Barium (ppm)	2	2	.0476	N/A		2016	No	Discharge of drilling wastes Discharge from metal refineries Of natural deposits
Chromium (ppb)	100	100	.0011	NA		2014	No	Discharge from steel and pulp Mills. Erosion of natural deposit
<b>Inorganic Contaminants</b>								
	MCLG	AL	Your Sample	#Samples		Exceed	Typical Source	
			Water	Date	Exceeding AI	AI		
Copper - action level at consumer taps (ppm)	1.3	1.3	0.1	2014	1	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (PPB)	0	3ppb	15ppb	2014	2	No	Corrosion of household plumbing systems; Erosion of natural deposits	

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have

ACCOUNT NO.	SERVICE FROM	SERVICE TO
041070000	04/06	05/04
SERVICE ADDRESS		
2189 TAMPA TRAIL N/W		
CURRENT	METER READINGS	
	PREVIOUS	USED
1676	1659	17

RETURN THIS STUB WITH PAYMENT TO:  
**LINCOLN RURAL WATER ASSN**  
 P O DRAWER 712  
 BROOKHAVEN, MS 39602

PRESORTED  
 FIRST-CLASS MAIL  
 U.S. POSTAGE  
 PAID  
 PERMIT NO. 104

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
15.00	06/12/2017	15.00
NET AMOUNT	SAVE THIS	GROSS AMOUNT
15.00	.00	15.00


**CCR'S AVAILABLE AT OFFICE! LOC OFF FOR 2 MONTHS 06/19/2017!**

RETURN SERVICE REQUESTED

041070000  
 RAMONA SMITH



2189 TAMPA TRL NW  
 WESSON MS 39191-9649



WTR 15.00  
 NET DUE >>> 15.00  
 SAVE THIS >>  
 GROSS DUE >> 15.00

CHARGE FOR SERVICES