

2017 JUN 22 AM 9: 00

CERTIFICATION

Consumer Confidence Report (CCR)

Coles Community Water Association, Inc.

Public Water Supply Name

003001 0030001

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper (attach copy of advertisement)

On water bills (attach copy of bill)

Email message (MUST Email the message to the address below)

Other _____

Date(s) customers were informed: 5/29/17 / / , / /

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / /

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: _____ / /

As a URL (Provide URL _____)

As an attachment

As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Wilk-Amite Record, LLC

Date Published: 6/9/17

CCR was posted in public places. *(Attach list of locations)*

Date Posted: _____ / /

CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Merit Arnold

Name/Title (President, Mayor, Owner, etc.)

6-12-2017

Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Fax: (601) 576 - 7800

Email: water.reports@msdh.ms.gov

CCR Deadline to MSDH & Customers by July 1, 2017!

PROOF OF PUBLICATION

WILK-AMITE RECORD, LLC
243 E. MAIN ST. / P. O. Box 130
GLOSTER, MS 39638
(601) 225-9200
info@wilkamiterecord.com

2016 Annual Drinking Water Quality Report
Coles Community Water Association
PWS#: 0030001
May 2017
PUBLIC NOTICE

eCom Direct, Inc is Sole Managing Member / Publisher for the MISSISSIPPI Limited Liability Corporation hereinafter known as the Wilk-Amite Record, LLC. I, Kanisha White, do hereby affirm that I am of lawful age, being duly sworn upon oath and also declare that I am a Managing Editor of the Wilk-Amite Record, LLC, a weekly publication that is a "legal newspaper" as may be defined or acknowledged within the Mississippi Code Ann § 9-15-67; § 11-33-43; § 13-3-32; § 23-15-877 and 23-15-879; § 27-41-57; § 91-7-147; § 95-1-5; § 97-23-35 and 97-23-37, and that the attachment hereto contains a true and correct copy of what was presented to the Wilk-Amite Record to be published on the behalf of the Coles Community Water Association – PWS# 0030001, a(n) municipality/company/firm/agency/association with said legal newspaper as per the following:

Date of Publication: 6/9/17 - Volume 204- Number 29 ; page 3

Total Word Count: 1403

Rate of Service: \$0.12 per word on the first run; \$0.10 per word for additional runs

Publication Fee: \$180.36

Respectfully submitted,



Managing Editor

STATE OF MISSISSIPPI
COUNTY OF AMITE

Signed and sworn to me this 12th day of June, 20 17

by Kanisha White on the behalf of the Wilk-Amite Record, LLC.



Notary Public

My Commission Expires: April 24, 20 21

NOTARY PUBLIC
ID No. 24989
Commission Expires
Apr 24, 2021



2016 Annual Drinking Water Quality Report
 Coles Community Water Association
 PWS#: 0030001
 May 2017

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Geneva T. Nicko at 601.639.7218. We want our valued customers to be informed about their water utility. If you want to learn more you can attend the annual meeting, the time and date will be announced.

Our water source is from wells drawing from the Miocene Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Coles Community Water Association have received a lower ranking in terms of susceptibility to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2016. In cases where monitoring wasn't required in 2016, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2014*	.6	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes

10. Barium	N	2014*	.1014	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2014*	.9	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2014/16*	.01	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2014/16*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
Chlorine	N	2016	1.4	1.3 – 1.4	mg/l	0	MRDL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2016.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Coles Community Water Association work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

1403

ACCOUNT NO. 010011000 SERVICE FROM 04/22 SERVICE TO 05/20
 SERVICE ADDRESS 1089 NEBO ROAD

RETURN THIS STUB WITH PAYMENT TO:

COLES COMMUNITY WATER ASSN
 P.O. BOX 666
 CROSBY, MS 39633
 601-639-7218

PLEASE
 PLACE
 STAMP
 HERE

METER READINGS
 CURRENT 391560
 PREVIOUS 390290
 USED 1270

CHARGE FOR SERVICES
 WTR 30.00
 NET DUE >>> 30.00
 SAVE THIS >> 3.00
 GROSS DUE >> 33.00

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE 06/10/2017	PAY GROSS AMOUNT AFTER DUE DATE
NET AMOUNT 30.00	SAVE THIS 3.00	GROSS AMOUNT 33.00

~~CCR PUBLISHED IN WILK-AMITE~~
 RECORD JUNE 8, 2016 ((REVERSE))

010011000
 BOBBY NICK
 1089 NEBO ROAD
 GLOSTER MS 39638

Net amount due by the 10th of each month.
Cut off is the 15th.
NO CASH PAYMENTS ACCEPTED.

Annual Meeting
June 12, 2017 ~ 6:30 pm
1077 Nebo Road • Gloster, MS

Business Phone: 601-639-7218

Notice: A penalty of 10% of the net amount will be charged if not paid by the 10th of the month. If service is disconnected due to non-payment, a reconnect fee of \$75.00 will be applied.