

2017 JUL -7 AM 8:52

Consumer Confidence Report Certification Form (updated with electronic delivery methods)

(suggested format)

CWS Name: Black Creek Retreat

PWSID No: 180021

The community water system named above hereby confirms that its consumer confidence report has been distributed to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the state/primacy agency.

Certified by:

Name: Steve Womack

Title: Operator

Phone #: (601) 382-2538 Date: 7-5-17

Please check all items that apply.

CCR was distributed by mail.

CCR was distributed by other direct delivery method. Specify direct delivery methods:

Mail – notification that CCR is available on website via a direct URL

Email – direct URL to CCR

Email – CCR sent as an attachment to the email

Email – CCR sent embedded in the email

Other: Posted at community center

If the CCR was provided by a direct URL, please provide the direct URL Internet address:

www. _____

If the CCR was provided electronically, please describe how a customer requests paper CCR delivery:

2017 JUL -7 AM 8:52

___ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods as recommended by the state/primacy agency:

___ posting the CCR on the Internet at www._____

___ mailing the CCR to postal patrons within the service area (attach a list of zip codes used)

___ advertising availability of the CCR in news media (attach copy of announcement)

___ publication of CCR in local newspaper (attach copy)

posting the CCR in public places (attach a list of locations)

___ delivery of multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers

___ delivery to community organizations (attach a list)

___ electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)

___ electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)

___ (for systems serving at least 100,000 persons) Posted CCR on a publicly-accessible Internet site at the address: www._____

Delivered CCR to other agencies as required by the state/primacy agency (attach a list)

List of Places!

Community Center

Black Creek Grocery

black creek retreat

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from? under gound aquifer

under ground aquifer

Source water assessment and its availability

under ground aquifer

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

report any illegal activity

Monitoring and reporting of compliance data violations

no adverse effects the homes were built after 1998 all homes are pvc and apex

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Black Creek Retreat is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	1.1	1	1.6	2016	No	Water additive used to control microbes
TTHMs [Total Trihalomethanes] (ppb)	NA	80	1.06	0	1.06	2016	No	By-product of drinking water disinfection
Inorganic Contaminants								
Cyanide (ppb)	200	200	.015	0	.15	2016	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Nitrate [measured as Nitrogen] (ppm)	10	10	.18	0	.18	2016	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	.02	0	.02	2016	No	Runoff from fertilizer use; Leaching from septic

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
								tanks, sewage; Erosion of natural deposits
Volatile Organic Contaminants								
1,2-Dichloropropane (ppb)	0	5	.5	0	.5	2016	No	Discharge from industrial chemical factories
Benzene (ppb)	0	5	.5	0	.5	2016	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	0	5	.5	0	.5	2016	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	.5	0	.5	2016	No	Discharge from chemical and agricultural chemical factories
Styrene (ppb)	100	100	.5	0	.5	2016	No	Discharge from rubber and plastic factories; Leaching from landfills
Toluene (ppm)	1	1	.5	0	.5	2016	No	Discharge from petroleum factories

Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Violation	Typical Source
Trichloroethylene (ppb)	0	5	ND	No	Discharge from metal degreasing sites and other factories

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	

Important Drinking Water Definitions	
	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Steve Womack
 Address: Po box 643
 mendenhall, ms 39114
 Phone: 6013822538