

2017 JUN 26 AM 9:02

CERTIFICATION

Consumer Confidence Report (CCR)

Blue Lake Water Association, Inc

Public Water Supply Name

0420041

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
- Advertisement in local paper (attach copy of advertisement)
 - On water bills (attach copy of bill)
 - Email message (MUST Email the message to the address below)
 - Other _____
- Date(s) customers were informed: 0/6/ , 12/ , 1/7/
- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____
- Date Mailed/Distributed: / /
- CCR was distributed by Email (MUST Email MSDH a copy) Date Emailed: / /
- As a URL (Provide URL _____)
 - As an attachment
 - As text within the body of the email message
- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*
- Name of Newspaper: Greenwood Commonwealth
- Date Published: 06/21/2017
- CCR was posted in public places. *(Attach list of locations)* Date Posted: / /
- CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**): _____

CERTIFICATION

I hereby certify that the Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply

William Fleck, manager
Name/Title (President, Mayor, Owner, etc.)

6-22-17
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Fax: (601) 576 - 7800

Email: water.reports@msdh.ms.gov

CCR Deadline to MSDH & Customers by July 1, 2017!

PROOF OF PUBLICATION

City	W	L	Pct	GB
Chicago	31	38	.449	6
West Division				
Houston	48	24	.667	—
Los Angeles	37	37	.500	12
Texas	35	35	.500	12
Seattle	36	37	.493	12½
Oakland	31	40	.437	16½

Tuesday's Games

Baltimore 6, Cleveland 5
 L.A. Angels 8, N.Y. Yankees 3
 Tampa Bay 6, Cincinnati 5
 Texas 6, Toronto 1
 Minnesota 9, Chicago White Sox 7
 Boston 8, Kansas City 3
 Houston 8, Oakland 4
 Seattle 5, Detroit 10 Innings

Golf

PGA Tour Statistics

FedExCup Season Points

1, Dustin Johnson, 2,269.650. 2, Hideki Matsuyama, 2,145.380. 3, Justin Thomas, 2,059.706. 4, Jon Rahm, 1,707.826. 5, Brooks Koepka, 1,533.707. 6, Jordan Spieth, 1,478.946. 7, Kevin Kisner, 1,457.507. 8, Rickie Fowler, 1,429.196. 9, Pat Perez, 1,425.591. 10, Brian Harman, 1,402.389.

Scoring Average

1, Rickie Fowler, 69.322. 2, Sergio Garcia, 69.359. 3, Jordan Spieth, 69.559. 4, Justin Thomas, 69.614. 5, Francesco Molinari, 69.779. 6, Hideki Matsuyama, 69.798. 7, Marc Leishman, 69.881. 8, Jon Rahm, 69.891. 9, Dustin Johnson, 69.898. 10, Justin Rose, 69.925.

Driving Distance

1, Dustin Johnson, 312.1. 2, Luke List, 311.4. 3, Brandon Hagy, 310.0. 4, Andrew Loupe, 309.6. 5, Brooks Koepka, 307.6. 6, Ryan Brehm, 307.1. 7, Kevin Tway, 306.4. 8, Tony Finau, 306.0. 9, Grayson Murray, 305.9. 10, Trey Mullinax, 305.4.

Driving Accuracy Percentage

1, Steve Stricker, 74.34%. 2, Jim Furyk, 72.32%. 3, Francesco Molinari, 72.12%. 4, Brian Stuard, 71.03%. 5, Chez Reavie, 70.81%. 6, Graeme McDowell, 70.40%. 7, Boo Weekley, 70.23%. 8, William McGirt, 70.11%. 9, Kevin Kisner, 69.96%. 10, Ryan Armour, 69.81%.

Greens in Regulation Percentage

1, Dustin Johnson, 72.22%. 2, Kyle Stanley, 71.95%. 3, Jordan Spieth, 70.89%. 4, Jim Herman, 70.81%. 5, Paul Casey, 70.79%.

College World Series

NCAA College World Series Glance
 At TD Ameritrade Park Omaha
 Omaha, Neb.
 (Double Elimination; x-if necessary)

Saturday, June 17

Oregon State 6, Cal State Fullerton 5
 LSU 5, Florida State 4

Sunday, June 18

Louisville 8, Texas A&M 4
 Florida 3, TCU 0

Monday, June 19


time one
 same tear
 sons in an
 The gar
 175 miles
 days in the
 TCU won
 against the
 beat them
 regular-se
 LSU wil
 out the de
 face Florid
 contest at
 LSU, the
 itself in th
 to top see
 The Tig
 urday in th
 The Tig
 senior le
 against Fl
 stave off el
 Despite
 LSU's win
 Saturday,
 limited pi
 threw 30
 what he t
 session. O
 of a Wed
 have thro
 day.
 He logg
 relief to ea
 State, mat
 wins recor
 While it
 the same
 appearanc
 it provides
 the other.
 "I think
 think I've
 least once.
 seen them
 executes b
 The Tig
 their secon
 today agai
 The Tig
 times, inc
 Mainieri:
 and 2015
 LSU's fir
 with its fir
 when the

STATE OF MISSISSIPPI,
 CITY OF GREENWOOD,
 LEFLORE COUNTY

Before me, Eddie Ray, A Notary Public
 of said County, personally appeared Amber Stanley
 Clerk of the Greenwood Commonwealth, a newspaper published in Leflore
 County, who, on oath, stated that the notice attached hereto

was published in said newspaper for
 times, beginning June 22 20 17, and ending
June 22 20, 17, in the following issues, to wit:

Vol. 121 No. 146 Dated June 21 20 17
 Vol. _____ No. _____ Dated _____ 20 _____
 Vol. _____ No. _____ Dated _____ 20 _____



Printer's Fee \$ _____
Amber Stanley Clerk
 Sworn to and subscribed before me this 22 day of
June 20 17
Amber Stanley
 Notary Public

A Notary Public
berstang
 newspaper published in Leflore
 notice attached hereto

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water is purchased from the City of Itta Bena.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the City of Itta Bena received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Ollie Seals at 662-254-7943. We want our valued customers to be informed about their water utility. If you want to learn more, please attend a special meeting being held on Tuesday, June 20, 2017 at 305 Thurman Street, Itta Bena at 5:00 pm.

Blue Lake Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2016. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2016	0.0121	None	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2016	6.2	None	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/12 to 12/31/14*	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2016	0.25	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	1/1/12 to 12/31/14*	1	None	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	1/1/16 to 12/31/16	0.50	0.45 to 0.69	ppm	4	4	Water additive used to control microbes
73. THM (Total trihalomethanes)	N	2016	17.3	No Range	ppb	0	80	By-product of drinking water chlorination
HAA5	N	2016	6.0	No Range	ppb	0	60	By-product of drinking water chlorination

* Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Blue Lake Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report is being published in the paper and will not be mailed. Please call our office if you would like a copy or if you have any questions.

20 17, and ending

in the following issues, to wit:

line 21 20 17

20 _____

20 _____

20 _____

20 _____

20 _____

22 nd day of

ary Public

Annual Drinking Water Quality Report
Blue Lake Water Association, Inc.
PWS ID # 0420041
May 2017

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water is purchased from the City of Itta Bena.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the City of Itta Bena received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Ollie Seals at 662-254-7943. We want our valued customers to be informed about their water utility. If you want to learn more, please attend a special meeting being held on Tuesday, June 20, 2017 at 305 Thurman Street, Itta Bena at 5:00 pm.

Blue Lake Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2016. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2016	0.0121	None	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2016	6.2	None	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/12 to 12/31/14*	0.1	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2016	0.25	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	1/1/12 to 12/31/14*	1	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	1/1/16 to 12/31/16	0.50	0.45 to 0.69	ppm	4	4	Water additive used to control microbes
73. TTHM [Total tri-halomethanes]	N	2016	17.3	No Range	ppb	0	80	By-product of drinking water chlorination
HAA5	N	2016	6.0	No Range	ppb	0	60	By-product of drinking water chlorination

* Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Blue Lake Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report is being published in the paper and will not be mailed. Please call our office if you would like a copy or if you have any questions.