

2017 JUN 30 AM 8:09

CERTIFICATION

Consumer Confidence Report (CCR)

Toomsuba Water System

Public Water Supply Name

380009

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must mail, fax or email a copy of the CCR and Certification to MSDH. Please check all boxes that apply.**

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper (attach copy of advertisement)
- On water bills (attach copy of bill)
- Email message (MUST Email the message to the address below)
- Other _____

Date(s) customers were informed: 4/29/17, 5/29/17, 6/28/17

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

CCR was distributed by Email (MUST Email MSDH a copy)

Date Emailed: / /

- As a URL (Provide URL _____)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper: *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: / / CCR was posted in public places. *(Attach list of locations)*Date Posted: / / CCR was posted on a publicly accessible internet site at the following address (**DIRECT URL REQUIRED**):toomsuba.water.com/ccr/**CERTIFICATION**

I hereby certify that the Consumer Confidence Report (CCR) has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the public water system officials by the Mississippi State Department of Health, Bureau of Public Water Supply

WJ Barrett Pres.

Name/Title (President, Mayor, Owner, etc.)

6/29/2015

Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Fax: (601) 576 - 7800**Email:** water.reports@msdh.ms.gov**CCR Deadline to MSDH & Customers by July 1, 2017!**

*Annual Drinking Water Quality Report
Toomsuba Water System
PWS ID # 0380009
April 2017*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of 3 wells that draw from the Lower Wilcox Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Toomsuba Water System received a lower susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Carol Hall at 601-632-4366. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Monday of each month at the Toomsuba Water Office at 6:00 pm.

Toomsuba Water System routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2016. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2015*	0.352	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2015*	1.4	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/14 to 12/31/16	0.3	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2015*	0.137	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	1/1/14 to 12/31/16	1	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	1/1/16 to 12/31/16	1.40	1.10 to 2.28	ppm	4	4	Water additive used to control microbes

* Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Toomsaba Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have any questions.

*Annual Drinking Water Quality Report
Toomsuba Water System
PWS ID # 0380009
April 2017*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of 3 wells that draw from the Lower Wilcox Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for Toomsuba Water System received a lower susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Carol Hall at 601-632-4366. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 1st Monday of each month at the Toomsuba Water Office at 6:00 pm.

Toomsuba Water System routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2016. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2015*	0.352	No Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2015*	1.4	No Range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	1/1/14 to 12/31/16	0.3	None	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2015*	0.137	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	1/1/14 to 12/31/16	1	None	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfectants & Disinfectant By-Products								
Chlorine (as Cl ₂)	N	1/1/16 to 12/31/16	1.40	1.10 to 2.28	ppm	4	4	Water additive used to control microbes

* Most recent sample results available

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Toomsba Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Please call our office if you have any questions.

011560000	05/26	06/26
SERVICE ADDRESS		
7253 LAUD TOOM RD		
CURRENT	METER READING	PREVIOUS
46990	45260	1730
CHARGE FOR SERVICES		

WTR 16.00
NET DUE >>> 16.00
V/FD DONATION> 2.00
TOTAL AMOUNT> 18.00

TOOMSUBA WATER SYSTEM
P O BOX 520
TOOMSUBA, MS 39364

FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 01
TOOMSUBA, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
16.00	07/14/2017	17.60
NET AMOUNT	SAVE THIS	GROSS AMOUNT
16.00	1.60	17.60

TOOMSUBAWATER.COM



RETURN SERVICE REQUESTED
011560000
ROBERT SKINNER

7253 LAUDERDALE TOOMSUBA RD
TOOMSUBA MS 39364-9731



011314000	04/28	05/26
SERVICE ADDRESS		
7570 J O THOMAS RD		
CURRENT	METER READING	PREVIOUS
430390	430390	
CHARGE FOR SERVICES		

WTR 16.00
PAST DUE 140.09
NET DUE >>> 156.09
V/FD DONATION> 2.00
TOTAL AMOUNT> 158.09

UTF

RETURN THIS STUB WITH PAYMENT TO:
TOOMSUBA WATER SYSTEM
P O BOX 520
TOOMSUBA, MS 39364

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 01
TOOMSUBA, MS


PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
156.09	06/15/2017	171.70
NET AMOUNT	SAVE THIS	GROSS AMOUNT
156.09	15.61	171.70

TOOMSUBAWATER.COM



RETURN SERVICE REQUESTED
011314000
SHARON BURTON

7570 J O THOMAS RD
TOOMSUBA MS 39364-9666



010769000	03/25	04/27
SERVICE ADDRESS		
3655 SOUTH FLORA DR		
CURRENT	METER READING	PREVIOUS
52330	49400	2930
CHARGE FOR SERVICES		

WTR 20.65
NET DUE >>> 20.65
V/FD DONATION> 2.00
TOTAL AMOUNT> 22.65

UTF

RETURN THIS STUB WITH PAYMENT TO:
TOOMSUBA WATER SYSTEM
P O BOX 520
TOOMSUBA, MS 39364

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 01
TOOMSUBA, MS

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
20.65	05/15/2017	22.72
NET AMOUNT	SAVE THIS	GROSS AMOUNT
20.65	2.07	22.72

TOOMSUBAWATER.COM



RETURN SERVICE REQUESTED
010769000
ROGER CARLISLE JR.

3655 S FLORA DR
LAUDERDALE MS 39335-9419

UTF



IMPORTANT INFORMATION
about your drinking water
is available in the 2016
CONSUMER CONFIDENCE REPORT

at
www.toomsubawater.com/ccr

You may request a
HARD COPY by
checking this box

or by calling our
office at
(601)632-4366.

PLEASE MAKE CHECKS PAYABLE TO:

TOOMSUBA WATER SYSTEM
P O BOX 520
TOOMSUBA, MS 39364

THERE IS A 10% PENALTY ADDED TO
BALANCE IF PAYMENT IS NOT RECEIVED
IN OUR OFFICE BY THE 14TH.

BUSINESS HOURS:
MONDAY THRU FRIDAY
8-12 AND 1-5

BUSINESS PHONE:
601-632-4366

BILL MUST BE PAID BY THE
END OF THE MONTH OR SERVICE
WILL BE DISCONNECTED WITH
NO FURTHER NOTICE.

IMPORTANT INFORMATION
about your drinking water
is available in the 2016
CONSUMER CONFIDENCE REPORT

at
www.toomsubawater.com/ccr

You may request a
HARD COPY by
checking this box

or by calling our
office at
(601)632-4366.

PLEASE MAKE CHECKS PAYABLE TO:

TOOMSUBA WATER SYSTEM
P O BOX 520
TOOMSUBA, MS 39364

THERE IS A 10% PENALTY ADDED TO
BALANCE IF PAYMENT IS NOT RECEIVED
IN OUR OFFICE BY THE 14TH.

BUSINESS HOURS:
MONDAY THRU FRIDAY
8-12 AND 1-5

BUSINESS PHONE:
601-632-4366

BILL MUST BE PAID BY THE
END OF THE MONTH OR SERVICE
WILL BE DISCONNECTED WITH
NO FURTHER NOTICE.

IMPORTANT INFORMATION
about your drinking water
is available in the 2016
CONSUMER CONFIDENCE REPORT

at
www.toomsubawater.com/ccr

You may request a
HARD COPY by
checking this box

or by calling our
office at
(601)632-4366.

PLEASE MAKE CHECKS PAYABLE TO:

TOOMSUBA WATER SYSTEM
P O BOX 520
TOOMSUBA, MS 39364

THERE IS A 10% PENALTY ADDED TO
BALANCE IF PAYMENT IS NOT RECEIVED
IN OUR OFFICE BY THE 14TH.

BUSINESS HOURS:
MONDAY THRU FRIDAY
8-12 AND 1-5

BUSINESS PHONE:
601-632-4366

BILL MUST BE PAID BY THE
END OF THE MONTH OR SERVICE
WILL BE DISCONNECTED WITH
NO FURTHER NOTICE.