

# 2017 CERTIFICATION

## Consumer Confidence Report (CCR)

2018 MAY 17 AM 9:31

Silvum Water Association

Public Water System Name

130015, 130016, 130017, 130023

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper *(Attach copy of advertisement)*

On water bills *(Attach copy of bill)*

Email message *(Email the message to the address below)*

Other \_\_\_\_\_

Date(s) customers were informed: 5/1/2018 6/1/2018 7/1/2018

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

CCR was distributed by Email *(Email MSDH a copy)*

Date Emailed: \_\_\_\_ / \_\_\_\_ / 2018

As a URL \_\_\_\_\_ *(Provide Direct URL)*

As an attachment

As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Daily Times Leader

Date Published: 5/2/2018

CCR was posted in public places. *(Attach list of locations)*

Date Posted: \_\_\_\_ / \_\_\_\_ / 2018

CCR was posted on a publicly accessible internet site at the following address: \_\_\_\_\_

*(Provide Direct URL)*

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

[Signature]  
Name/Title *(President, Mayor, Owner, etc.)*

5-14-2018  
Date

### Submission options *(Select one method ONLY)*

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**Fax:** (601) 576-7800

**\*\*Not a preferred method due to poor clarity\*\***

## CCR Deadline to MSDH & Customers by July 1, 2018!

# Siloam Water 2017 Drinking Water Quality Report

<b>Is my water safe?</b>	Last year, as in years past, your tap water met all U.S. Environment Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. This report is a snapshot of last years water quality. Included are details about where your water comes from, what it contains and how it compares to standards set by regulatory agencies. We are committed to providing the best information about the quality of your drinking water.
<b>Do I need to take special precautions?</b>	Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk for infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791
<b>Where does my water come from?</b>	Our water comes from 8 different wells that draw from the Eutaw, Gordo and McShan Aquifers.
<b>Source water assessment and its availability:</b>	Our source water assessment is available on request.
<b>Why are there contaminants in my drinking water?</b>	Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791
<b>How can I get involved?</b>	Our board members meet the 2 <sup>nd</sup> Monday of every month at 5:00 pm at the Siloam Water Office. Our annual meeting is the 1 <sup>st</sup> Monday in April. The exact time and place will be printed on your water bill. This is a very important meeting and we encourage all of our members to attend.
<b>Contact Information</b>	Harvey Cummings - Certified Operator P.O. Box 224 West Point, Ms 39773 Phone 662-494-1852 fax 662-494-8903

**CHLORINE**

Well	PWS ID#	MCLG	MCL	Your Water	Low	High	Sample Date	Violation
Beasley I/Beasley II	130016	4	4	1.00	1.00	1.00	2017	N
Gates/Griffith	130015	4	4	1.30	1.20	1.40	2017	N
Pine Bluff	130017	4	4	1.20	1.20	1.20	2017	N
Una/Muldon	130023	4	4	1.20	1.00	1.40	2017	N

Typical Source : Water additive used to control microbes. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**NITRATE/NITRATE**

Well	PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date
Beasley I/Beasley II	130016	10	10	0	No	Jan-17
Gates/Griffith	130015	10	10	0	No	Jan-17
Pine Bluff	130017	10	10	0	No	Jan-17
Una/Muldon	130023	10	10	0	No	Jan-17

Typical Source: Runoff from fertilizer use; leaching from septic tanks and sewage. Erosion of natural deposits.

**LEAD**

Well	PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date
Beasley I/Beasley II	130016	0	15	0.001	No	Sep-14
Gates/Griffith	130015	0	15	0.001	No	Sep-14
Pine Bluff	130017	0	15	0.002	No	Sep-17
Una/Muldon	130023	0	15	0.002	No	Sep-17

Typical Source: Corrosion of household plumbing systems. Erosion of natural deposits.

**COPPER**

Well	PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date
Beasley I/Beasley II	130016	1.3	1.3	0.20	No	Sep-14
Gates/Griffith	130015	1.3	1.3	0.00	No	Sep-14
Pine Bluff	130017	1.3	1.3	0.30	No	Sep-17
Una/Muldon	130023	1.3	1.3	0.40	No	Sep-17

Typical Source: Corrosion of household plumbing systems. Erosion of natural deposits.

**CHLORINE**

Well	PWS ID#	MCLG	MCL	Your Water	Low	High	Sample Date	Violation
Beasley I/Beasley II	130016	4	4	1.00	1.00	1.00	2017	N
Gates/Griffith	130015	4	4	1.10	1.00	1.30	2017	N
Pine Bluff	130017	4	4	1.20	1.00	1.20	2017	N
Una/Muldon	130023	4	4	1.10	1.00	1.20	2017	N

Typical Source : Water additive used to control microbes. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**NITRATE/NITRATE**

Well	PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date
Beasley I/Beasley II	130016	10	10	0.1	No	Jan-17
Gates/Griffith	130015	10	10	0.1	No	Jan-17
Pine Bluff	130017	10	10	0.1	No	Jan-17
Una/Muldon	130023	10	10	0.1	No	Jan-17

Typical Source: Runoff from fertilizer use; leaching from septic tanks and sewage. Erosion of natural deposits.

**LEAD**

Well	PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date
Beasley I/Beasley II	130016	0	15	0.001	No	Sep-17
Gates/Griffith	130015	0	15	0.001	No	Sep-17
Pine Bluff	130017	0	15	0.003	No	Sep-17
Una/Muldon	130023	0	15	0.004	No	Sep-17

Typical Source: Corrosion of household plumbing systems. Erosion of natural deposits.

**COPPER**

Well	PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date
Beasley I/Beasley II	130016	1.3	1.3	0.20	No	Sep-17
Gates/Griffith	130015	1.3	1.3	0.00	No	Sep-17
Pine Bluff	130017	1.3	1.3	0.36	No	Sep-17
Una/Muldon	130023	1.3	1.3	0.40	No	Sep-17

Typical Source: Corrosion of household plumbing systems. Erosion of natural deposits.

<b>Additional Information on Lead</b>	<p>If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Siloam Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.</p> <p>When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap water for 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <a href="http://www.epa.gov/safeater/lead">http://www.epa.gov/safeater/lead</a></p> <p>The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10.00 per sample. Please contact 601-576-7582 if you wish to have your water tested.</p>
---------------------------------------	--

Term	Definition
PPM	parts per million, or milligrams per liter (mg/l)
PPB	parts per billion, or micrograms per liter (ug/l)
MCL-Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology
MCLG-Maximum Contaminant Level Goal	<p>The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety</p> <p>A required process intended to reduce the level of a contaminant in drinking water</p>
TT- Treatment Technique	The concentration of a contaminant which, if exceeded, contaminant in drinking water
AL- Action Level	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow
MRDLG- Maximum Residual Disinfectant Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MCLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL-Maximum Residual Disinfectant Level	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

2018 MAY 17 AM 9:31

AFFP

AFFIDAVIT OF PUBLICATION

STATE OF MISSISSIPPI                      SS  
COUNTY OF CLAY

Cindy Cannon being duly sworn , says:

That she is Classified Clerk of Daily Times Leader, a daily newspaper of general circulation, printed and published in West Point, Clay County, Mississippi; that the publication, a copy of which is attached hereto, was published in the said newspaper on the following dates:

May 6, 2018

\_\_\_\_\_

\_\_\_\_\_

That said newspaper was regularly issued and circulated on those dates:  
SIGNED

Cindy Cannon  
CLASSIFIED CLERK



Subscribed to and sworn to me this 10th day of May, 2018.

Amy Berry by: Charmit Lewis D.C.

My Commission Expires January 6, 2020

# Siloam Water 2017 Drinking Water Quality Report

RECEIVED-WATER SUPPLY

2018 MAY 17 AM 9:31

is my water safe?  
 Last year, as in years past, your tap water met all U.S. Environmental Protection Agency (EPA) and Mississippi State Department of Health drinking water standards. This report is a snapshot of last year's water quality. Included are details about where your water comes from, what it contains and how it compares to standards set by regulatory agencies. We are committed to providing the best information about the quality of your drinking water.

Do I need to take special precautions?  
 Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk for infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Where does my water come from?  
 Our water comes from 8 different wells that draw from the Eulaw, Gordon and McShan Aquifers.  
 Our source water assessment is available on request.

Why are there contaminants in my drinking water?  
 Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

How can I get involved?  
 Our board members meet the 2<sup>nd</sup> Monday of every month at 5:00 pm at the Siloam Water Office. Our annual meeting is the 1<sup>st</sup> Monday in April. The exact time and place will be printed on your water bill. This is a very important meeting and we encourage all of our members to attend.

Contact Information  
 Harvey Cummings - Certified Operator  
 P.O. Box 224 West Point, Ms 38773  
 Phone: 662-494-1852 fax: 662-494-8903

**CHLORINE**

Well	PWS ID#	MCLG	MCL	Your Water	Low	High	Sample Date
Beasley I/Beasley II	130016	4	4	1.00	1.00	1.00	2017/N
Gates/Griffith	130015	4	4	1.10	1.00	1.30	2017/N
Pine Bluff	130017	4	4	1.20	1.00	1.20	2017/N
Una/Muldon	130023	4	4	1.10	1.00	1.20	2017/N

Typical Source: Water additive used to control microbes. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**NITRATE/NITRATE**

Well	PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date
Beasley I/Beasley II	130016	10	10	0.1	No	Jan-17
Gates/Griffith	130015	10	10	0.1	No	Jan-17
Pine Bluff	130017	10	10	0.1	No	Jan-17
Una/Muldon	130023	10	10	0.1	No	Jan-17

Typical Source: Runoff from fertilizer use; leaching from septic tanks and sewage. Erosion of natural deposits.

**LEAD**

Well	PWS ID#	MCLG	MCL	Your Water	Violation	Sample Date
------	---------	------	-----	------------	-----------	-------------

Well	PWS ID#	MCLG	MCL	Four Years	Original Date
Beasley /Beasley II	130016	1.3	1.3	0.20	Nov-17
Gates/Griffith	130015	1.3	1.3	0.00	Nov-17
Pine Bluff	130017	1.3	1.3	0.36	Nov-17
Una/Muldon	130024	1.3	1.3	0.40	Nov-17

Typical Source: Corrosion of household plumbing systems. Erosion of natural deposits.

**Additional Information on Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Lead and Copper Rule is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap water for 30 seconds to 2 minutes before using water for drinking and cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10.00 per sample. Please contact 601-576-7582 if you wish to have your water tested.

Term	Definition
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
MCL-Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG-Maximum Contaminant Level Goal	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. A required process intended to reduce the level of a contaminant in drinking water.
TT- Treatment Technique	The concentration of a contaminant which, if exceeded, contaminant in drinking water.
AL- Action Level	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MRDLG- Maximum Residual Disinfectant Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MCLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL- Maximum Residual Disinfectant Level	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.