

2017 CERTIFICATION

RECEIVED - WATER SUPPLY

Consumer Confidence Report (CCR)

2018 JUN -8 AM 9: 07

Yocona Water Association, Inc

Public Water System Name

360017

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper *(Attach copy of advertisement)*
- On water bills *(Attach copy of bill)*
- Email message *(Email the message to the address below)*
- Other _____

Date(s) customers were informed: ___ / ___ / 2018 ___ / ___ / 2018 ___ / ___ / 2018

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ / ___

CCR was distributed by Email *(Email MSDH a copy)*

Date Emailed: ___ / ___ / 2018

- As a URL _____ *(Provide Direct URL)*
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Oxford Eagle

Date Published: 5 / 31 / 2018

CCR was posted in public places. *(Attach list of locations)*

Date Posted: ___ / ___ / 2018

CCR was posted on a publicly accessible internet site at the following address:

_____ *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

M. Vanderlip

Name/Title *(President, Mayor, Owner, etc.)*

06/05/2018

Date

Submission options *(Select one method ONLY)*

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2018!

2017 Annual Drinking Water Quality Report
 Yocona Water Association, Inc.
 PWS#: 0360017
 April 2018

2018 JUN -8 AM 9: 07

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Lower Wilcox Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Yocona Water Association, Inc. have received a lower susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Michael Vanderlip at 662-234-0009. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meeting scheduled for Tuesday, July 3, 2018 at 7:00 PM at 758 HWY 334, Oxford, MS 38655.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2017. In cases where monitoring wasn't required in 2017, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2015*	.0297	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2015*	1.4	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2015*	3	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2015*	4.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	1	.80 – 1	Mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2017.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Yocona Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Notice: A copy of this report will not be mailed to each customer; however you may request a copy by calling 662.234.0009.

COMBINED INVOICE AND STATEMENT

OXFORD NEWSMEDIA, LLC
 P.O. BOX 866
 OXFORD, MS 38655
 662-234-4331

BILLING DATE	TOTAL AMOUNT DUE	PAYMENT DUE BY
5/31/2018	412.50	6/10/2018
BILLING PERIOD	FROM: 5/1/2018	TO: 5/31/2018
ACCOUNT NO	Account/Invoice #	AMOUNT ENCLOSED
67186	67186/0518	

REMIT TO: OXFORD NEWSMEDIA, LLC
 P.O. BOX 866
 OXFORD, MS 38655

YOCONA WATER ASSOCIATION
 758 HWY 334
 OXFORD, MS 38655

Pay by credit card: VISA MC DISC

Card #: _____

Amount Paid: _____ Exp Date: _____

Name on Card: _____

PLEASE DETACH AND RETURN UPPER PORTION WITH YOUR REMITTANCE

Date	Ref #	Pub Name	Description	Size/Quantity	Rate	Amount
			BALANCE FORWARD			0.00
05/31/18	515798	Oxford Eagle	YOCONA WATER ASSOCIATION WATER	33. Inches	12.5	412.50



CUSTOMER SUMMARY FOR		31 - 60 DAYS	61 - 90 DAYS	OVER 90 DAYS	CURRENT CHARGES	412.50
Account # 67186					Past Due	0.00
Period Ending:	5/31/2018	0.00	0.00	0.00		
Previous Balance:	0.00					
Current Charges:	412.50					
Payments/Credits:	0.00					
BALANCE DUE:	412.50				PLEASE PAY THIS AMOUNT	412.50

Yocona Water Association, Inc.
 758 Highway 334
 Oxford, MS 38655
 (662) 234-0009

FIRST-CLASS MAIL
 U.S. POSTAGE PAID

PERMIT NO.

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	65810	62040	3,770	18.83
Credit				(1.91)

Yocona Water Association, Inc.

CUSTOMER		DUE DATE PAST DUE AFTER THIS DATE
ROUTE	ACCOUNT	
1	173	6/10/18
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
16.92		18.61

MAIL THIS STUB WITH YOUR PAYMENT

805 HWY 334

Service From 4/18/2018 TO 5/15/2018 ACCOUNT 173 5/24/18

WELLS, LEE
 805 HWY 334
 OXFORD MS 38655

METER READ MONTH	DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
5	15	1	16.92	1.69	18.61

NOTE: When water pressure is lost, call 662-234-0009 and boil water for the next 72 hours.

YOCONA WATER'S CONSUMER CONFIDENCE REPORT WILL BE PUBLISHED IN THE OXFORD EAGLE ON 5/31/18

Yocona Water Association, Inc.
 758 Highway 334
 Oxford, MS 38655
 (662) 234-0009

FIRST-CLASS MAIL
 U.S. POSTAGE PAID

PERMIT NO.

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	411700	411700	0	15.75
ACH fee				0.25

Yocona Water Association, Inc.

CUSTOMER		DUE DATE PAST DUE AFTER THIS DATE
ROUTE	ACCOUNT	
1	49	6/10/18
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
16.00		17.60

MAIL THIS STUB WITH YOUR PAYMENT

16 HWY 331

THIS BILL IS PAID BY BANK DRAFT. DO NOT PAY

Service From 4/18/2018 TO 5/15/2018 ACCOUNT 49 5/24/18

WALKER, WILLIAM
 7680 WAVE DR.
 NEW ORLEANS LA 70128

METER READ MONTH	DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
5	15	7	16.00	1.60	17.60

NOTE: When water pressure is lost, call 662-234-0009 and boil water for the next 72 hours.

YOCONA WATER'S CONSUMER CONFIDENCE REPORT WILL BE PUBLISHED IN THE OXFORD EAGLE ON 5/31/18