RECEIVED-WATER SUPPLY
2018 JUN 18 AM 9:36

2017 CERTIFICATION

Consumer Confidence Report (CCR)

C.S. + D. Water Company
Public Water System Name

0110002
List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: ***(Attach copy of publication, water bill or other)***

- ☑ Advertisement in local paper ***(Attach copy of advertisement)***
- ☐ On water bills ***(Attach copy of bill)***
- ☐ Email message ***(Email the message to the address below)***
- ☐ Other _____

Date(s) customers were informed: 06/07/2018 / /2018 / /2018

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: 06/07/18

CCR was distributed by Email (***Email MSDH a copy***) Date Emailed: / /2018

- ☐ As a URL _____ ***(Provide Direct URL)***
- ☐ As an attachment
- ☐ As text within the body of the email message

CCR was published in local newspaper. ***(Attach copy of published CCR or proof of publication)***

Name of Newspaper: The Port Gibson Reveille

Date Published: 06/07/18

CCR was posted in public places. ***(Attach list of locations)*** Date Posted: / /2018

CCR was posted on a publicly accessible internet site at the following address:

_____ ***(Provide Direct URL)***

CERTIFICATION
I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

V Cleo Rotan Vice Pres.
Name/Title (*President, Mayor, Owner, etc.*)

6-14-18
Date

Submission options (*Select one method ONLY*)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800
Not a preferred method due to poor clarity

CCR Deadline to MSDH & Customers by July 1, 2018!

RECEIVED-WATER SUPPL
2018 JUN 12 AM 8: 08

2017 Annual Drinking Water Quality Report
CS&I Water Association
PWS#: 0110002
May 2018

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Catahoula Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the CS&I Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Cleo Dotson at 601.437.3681. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of the month at 5:00 PM at 3148 Karnac Ferry Rd., Port Gibson, MS.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st , 2017. In cases where monitoring wasn't required in 2017, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in $10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in $10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2017	.7	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2017	.02	.0099 - .02	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2017	3.8	1.5 – 3.8	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14. Copper	N	2015/17	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2017	1.05	.641 – 1.05	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2017	61	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2017	44.7	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	.9	.4– 1.2	mg/l	0	MDRL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2017.*

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

Significant Deficiencies

During a sanitary survey conducted on 9/09/2015, the Mississippi State Department of Health cited the following significant deficiency(s).
Inadequate internal cleaning/maintenance of storage tanks
Corrective actions: This deficiency is included in a compliance plan to complete corrective actions by 7/01/2019

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The CS & I Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

rinking Water Quality Report
ssociation PWS#: 0110002
May 2018

ou this year's Annual Quality Water Report. This report is de-
quality water and services we deliver to you every day. Our con-
a safe and dependable supply of drinking water. We want you
ke to continually improve the water treatment process and pro-
e committed to ensuring the quality of your water. Our water
m the Catahoula Aquifer.

t has been completed for our public water system to determine
drinking water supply to identified potential sources of con-
detailed information on how the susceptibility determinations
o our public water system and is available for viewing upon re-
Vater Association have received lower susceptibility rankings to

out this report or concerning your water utility, please contact
Ve want our valued customers to be informed about their water
e, please attend any of our regularly scheduled meetings. They
of the month at 5:00 PM at 3148 Karnac Ferry Rd., Port Gib-

ontaminants in your drinking water according to Federal and
all of the drinking water contaminants that we detected during
cember 31st, 2017. In cases where monitoring wasn't required
ost recent results. As water travels over the surface of land or
lly occurring minerals and, in some cases, radioactive materials
ontaminants from the presence of animals or from human ac-
such as viruses and bacteria, that may come from sewage treat-
agricultural livestock operations, and wildlife; inorganic
metals, which can be naturally occurring or result from urban
r domestic wastewater discharges, oil and gas production, min-
herbicides, which may come from a variety of sources such as
runoff, and residential uses; organic chemical contaminants,
rganic chemicals, which are by-products of industrial processes
can also come from gas stations and septic systems; radioactive
turally occurring or be the result of oil and gas production and
sure that tap water is safe to drink, EPA prescribes regulations
contaminants in water provided by public water systems. All
d drinking water, may be reasonably expected to contain at least
inants. It's important to remember that the presence of these
ily indicate that the water poses a health risk.

any terms and abbreviations you might not be familiar with. To
se terms we've provided the following definitions:

ation of a contaminant which, if exceeded, triggers treatment
water system must follow.

vel (MCL) - The "Maximum Allowed" (MCL) is the highest
llowed in drinking water. MCLs are set as close to the MCLGs
ble treatment technology.

vel Goal (MCLG) - The "Goar(MCLG) is the level of a contam-
which there is no known or expected risk to health. MCLGs

tant Level (MRDL) - The highest level of a disinfectant allowed
vincing evidence that addition of a disinfectant is necessary to

ctant Level Goal (MRDLG) - The level of a drinking water dis-
no known or expected risk of health. MRDLGs do not reflect
fectants to control microbial contaminants.

Milligrams per liter (mg/l) - one part per million corresponds to
ngle penny in $10,000.

Micrograms per liter - one part per billion corresponds to one
gle penny in $10,000,000.

TEST RESULTS

Lead Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
7	No Range	ppb	n/a	10	Erosion of natural deposits; run from orchards; runoff from glas and electronics production wast

PUBLISHER'S OATH

RECEIVED WATER SUPPLY

STATE OF MISSISSIPPI,
CLAIBORNE COUNTY, MISSISSIPPI

2018 JUN 18 AM 9:36

Personally appeared before the undersigned NOTARY PUBLIC of said County, EMMA F. CRISLER, Publisher of The Reveille, a weekly newspaper, printed and published in the town of Port Gibson, in said county and state, who, being duly sworn deposes and says that said newspaper has been established for more than twelve months next prior to first publication mentioned below; and who further makes oath that publication of a notice, of which, the annexed is a copy, has been made in said paper consecutively, to wit:

On the 7th day of June, 2018
On the _____ day of _____, 2018
On the _____ day of _____, 2018
On the _____ day of _____, 2018

_____, Publisher

And I, _____ do hereby certify that the papers containing said notice have been produced before me, and compared with the copy annexed, and that I find the proof of publication thereof to be correctly made.

Witness my hand and seal, this 11 of _____, 2018.

_____, Notary Public

Fees and proof of publication, $319.00

STATE OF MISSISSIPPI
WANDA B. BROWN
ID# 2283
NOTARY PUBLIC
Comm. Expires
Jan. 28, 2022
CLAIBORNE COUNTY