

2018 JUN 29 AM 7:53

2017 CERTIFICATION

Consumer Confidence Report (CCR)

Twelve Oaks Utility Co., Inc.

Public Water System Name

0360069

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- † Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - † Advertisement in local paper *(Attach copy of advertisement)*
 - † On water bills *(Attach copy of bill)*
 - † Email message *(Email the message to the address below)*
 - † Other U.S. Mail

Date(s) customers were informed: / / 2018 / / 2018 / / 2018

- † CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used U.S. MAIL
- † Date Mailed/Distributed: 6/29/2018

- † CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: / / 2018
 - † As a URL *(Provide Direct URL)*
 - † As an attachment
 - † As text within the body of the email message


- † CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*
 - Name of Newspaper:
 - Date Published: / /

- † CCR was posted in public places. *(Attach list of locations)* Date Posted: / / 2018

- † CCR was posted on a publicly accessible internet site at the following address: *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply


Name/Title (President, Mayor, Owner, etc.)

6/21/2018
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2018!

2018 JUN 28 PM 4: 26

2017 Annual Drinking Water Quality Report
 Twelve Oaks Utility Co., Inc.
 PWS#: 0360069
 June 2018

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from a well drawing from the Meridian Upper Wilcox.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The well for the Twelve Oaks Utility Co., Inc. has received lower rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Billy Westbrook at 662.801.1011. We want our valued customers to be informed about their water utility. If you want to learn more, please contact us at the phone number above.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2017. In cases where monitoring wasn't required in 2017, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
5. Gross Alpha	N	2014*	.6	.3 - .6	pCi/L	0	15	Erosion of natural deposits
6. Radium 226 Radium 228	N	2014*	.1 .4	No Range	pCi/L	0	5	Erosion of natural deposits

Inorganic Contaminants									
10. Barium	N	2015*	.0205	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
13. Chromium	N	2015*	1.1	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits	
14. Copper	N	2017	0	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
17. Lead	N	2017	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits	
19. Nitrate (as Nitrogen)	N	2017	.53	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	
Disinfection By-Products									
Chlorine	N	2017	1.18	1 – 1.3	mg/l	0	MRDL = 4	Water additive used to control microbes	
Treatment Technique									
TT Violation	Explanation	Duration of Violation	Corrective Actions	Health Effects Language					
Ground Water Rule	Failure to Take Corrective Action Within Required Timeframe	Sept 16 - Present	The system has entered into a bilateral compliance agreement, issuing working with the State on an agreement, and/or corrected the deficiency.	Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites, which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.					

* Most recent sample. No sample required for 2017.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

Significant Deficiencies

During a sanitary survey conducted on 10/19/2015, the Mississippi State Department of Health cited the following significant deficiency(s).

Lake of Redundant Mechanical Components

Corrective actions: MSDH is currently completing enforcement to return the system back into compliance by 6/30/2018

No Approved Emergency Response Plan or Vulnerability Analysis

Corrective actions: This deficiency is included in a compliance plan to complete corrective actions by 6/30/2018

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Twelve Oaks Utility Co., Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

TWELVE OAKS UTILITY CO., INC
P O BOX 993
OXFORD, MS 38655
662-234-1011
tish@westbrook.ms
melissawb65@gmail.com

June 27, 2018

Township of Twelve Oaks
Customers of Twelve Oaks Utility Company

RE: Consumer Confidence Report (CCR)

I have attached for you a form entitled "MS State Department of Health Bureau of Public Water Supply" that was completed in order to have the CCR report available on-line for our customers.

The Consumer Confidence Report (CCR) is a report that is published on line for the availability to our customers for safe drinking water and is required by the Federal Safety Drinking Water Act (SDWA). This report will be available at this website:

<http://www.msrrwa.org/2017ccr/twelveoaks.pdf> once the CCR is completed by the MS Rural Water Association. You may also go to this site: www.msrrwa.org which is MS Rural Water Association and go to the heading of CCR (to the far right) and scroll down to CCR hosting and put your cursor on "participants." Once the word "participants" is entered, the names of several utility companies in Mississippi will be present; which you can scroll to the "T's" and Twelve Oaks Utility Company will be present. If you have any questions or concerns, please contact our office (662) 234-1011 between the hours of 8:00 to 3:00 Monday thru Friday.

Thank you,



Tish N. Bevill
Office Manager
Enclosure: