

**2017 CERTIFICATION**

2018 JUN 11 AM 9:53

## Consumer Confidence Report (CCR)

Liberty Hill Water Assoc

Public Water System Name

540012

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)

- Advertisement in local paper (*Attach copy of advertisement*)
- On water bills (*Attach copy of bill*)
- Email message (*Email the message to the address below*)
- Other \_\_\_\_\_

Date(s) customers were informed: \_\_\_ / \_\_\_ / 2018 \_\_\_ / \_\_\_ / 2018 \_\_\_ / \_\_\_ / 2018

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_ / \_\_\_ / \_\_\_

CCR was distributed by Email (*Email MSDH a copy*)

Date Emailed: \_\_\_ / \_\_\_ / 2018

- As a URL \_\_\_\_\_ (*Provide Direct URL*)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)Name of Newspaper: PanolaianDate Published: 06/05/18CCR was posted in public places. (*Attach list of locations*)

Date Posted: \_\_\_ / \_\_\_ / 2018

CCR was posted on a publicly accessible internet site at the following address:

\_\_\_\_\_ (*Provide Direct URL*)**CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

✓ Paul C WilliamsName/Title (*President, Mayor, Owner, etc.*)6-4-18

Date

**Submission options** (*Select one method ONLY*)

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)**Fax:** (601) 576 - 7800**\*\*Not a preferred method due to poor clarity\*\*****CCR Deadline to MSDH & Customers by July 1, 2018!**

# The Panolian

••••• Panola County's Largest Print Advertising Medium •••••

662-563-4591- 1-800-310-4591 • Fax: 662-563-5610  
website: www.panolian.com - email: legals@panolian.com

# PROOF OF PUBLICATION

THE STATE OF MISSISSIPPI  
COUNTY OF PANOLA

DAVID MAGEE, personally appeared before me, the undersigned authority in and for said County and State, and states on oath that he is the CLERK of The Panolian, a newspaper published in the City of Batesville, State and County aforesaid, and having a general circulation in said county, and that the publication of the notice, a copy of which is hereto attached, has been made in said paper 1 consecutive times, to wit:

- Volume No. 138 on the 5th day of JUNE, 2018.
- Volume No. 138 on the \_\_\_\_\_ day of \_\_\_\_\_, 2018.
- Volume No. 138 on the \_\_\_\_\_ day of \_\_\_\_\_, 2018.
- Volume No. 138 on the \_\_\_\_\_ day of \_\_\_\_\_, 2018.



affiant

Sworn and subscribed before me, this the 5th day of JUNE, 2018.

By Sarah Pierce  
My Commission Expires \_\_\_\_\_

**Billing Information**

A. Single first insertion of _____ words @ .12	\$ _____
B. Week 2 . . . . . words @ .10	\$ _____
C. Week 3 . . . . . words @ .10	\$ _____
D. Week 4 . . . . . words @ .10	\$ _____
DISPLAY LEGAL <u>3x12</u> COL. INCHES X 8.00 =	\$ <u>288.00</u>
Proof of Publication <u>1</u> @ \$3.00 ea.	\$ <u>3.00</u>
TOTAL LEGAL BILLING FEE . . . . .	\$ <u>291.00</u>



**BILL TO:**

Liberty Hill Water Association  
P.O. Box 81  
Pope, MS 38658

Phone (w/area code) 662-256-1239

BATESVILLE, MS

## All camps

Camp for boys will be from 8 a.m. to 5 p.m.

Campers will be divided by grade level. Awards will be given for each skill competition for the different age groups in the areas of 1-on-1, 3-on-3, basketball shot and free throw.

Each age group will be tested in skill competitions of dribbling, passing, shooting and all-purpose.

For a form, contact athletic director Harrison Nickle at North Delta School, 563-4536 or email [nickle@northdelta-school.net](mailto:nickle@northdelta-school.net).

Follow us on Twitter: @thepanolian

## Openings for Childcare

6 Weeks - 12 Years  
Breakfast • Lunch • Snacks  
Tutoring for After-School Children



## Kiddie Korner Daycare

(662) 654-1662 • 569 Hwy. 6 West • Batesville

### 2017 Annual Drinking Water Quality Report Liberty Hill Water Association PWS. Id # 0540012 May 30, 2018

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is three wells. Our well draws from the Middle Wilcox Aquifer and the other two drawing from the Lower Wilcox Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Liberty Hill Water Association received a moderate ranking to contaminations.

I'm pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Donald Phelps Jr. at (662)-609-2507. We want our valued customers to be informed about their water utility. If you want to learn more, please attend one of our bi-monthly meetings. They are held on the first Tuesday of the month.

Liberty Hill Water Association routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2017. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment

(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCL/G	MCL	Likely Source of Contamination
Chlorite (as Cl <sub>2</sub> ) (ppm)	N	2017	1.90	1.20-2.90	Ppm	4	4	Water additive used to control microbes
Inorganic Contaminants								
Barium	N	*2016	.0578	No-range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper	N	2017	0.2	No-range	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead	N	2017	2.0	No-range	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Chromium	N	*2013	7.0	No-range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

No sample required in 2017

\*\*\*Additional Information for Lead\*\*\*

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Liberty Hill Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Your CCR will not be mailed to you however, you may obtain a copy at the Water Office. Please call 662-563-1239 if you have any questions. Please call our office if you have questions.

e!

SEE THE  
LATEST  
AT

**JOHNSON'S**  
FURNITURE  
SHOWROOM

ign needs!



**12 Months Same As Cash!**

234-7711 • [johnsonfurnitureonline.com](http://johnsonfurnitureonline.com)