RECEIVED-WATER SUPPLY

2017 CERTIFICATION Consumer Confidence Report (CCR)

Pearl	Biver	Central	Whoter	Association	
		Public Wate	er System Na	ame	

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH. Please check all boxes that apply.

☐ Advertisement in local paper (Attach copy of advertisement)
☐ On water bills (Attach copy of bill)
☐ Email message (Email the message to the address below)
☐ Other
Date(s) customers were informed: / /2018 / /2018 / /2018
CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used
Date Mailed/Distributed://
CCR was distributed by Email (<i>Email MSDH a copy</i>) Date Emailed: / / 2018
☐ As a URL(Provide Direct URL)
☐ As an attachment
☐ As text within the body of the email message
CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)
CCR was published in local newspaper. (Attach copy of published CCR or proof of publication) Name of Newspaper:
Name of Newspaper:
Name of Newspaper: Date Published: //

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service) MSDH, Bureau of Public Water Supply

P.O. Box 1700

Jackson, MS 39215

Email: water.reports@msdh.ms.gov

(601) 576 - 7800 Fax:

Not a preferred method due to poor clarity

CCR Deadline to MSDH & Customers by July 1, 2018!

CONSUMER CONFIDENCE REPORT PEARL RIVER CENTRAL WATER ASSOCIATION PPL

COHHECTED COP 2018 AUG -7 AM 7: 39

Is my water safe?

Last year your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

We serve our customers with groundwater that is drawn from 2 wells that tap into the Upper Pascagoula aquifer,

Source water assessment and its availability

Our source water assessment has been completed. Our wells ranked lower in terms of susceptibility to contamination. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Drinking Water Hotline at 1-800-426-4791.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).**How can I get involved?**

If you have any questions or concerns, please contact Larry Copling at 601-798-3103. We want our customers to be informed about their water quality. If you would like to learn more, please attend any of our regularly scheduled meetings. Monthly meetings are held at 2:00pm on the fourth Tuesday of each month at our offices located: 17 White Chapel Rd., Carriere.

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisims that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Additional Information for Lead If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. PEARL RIVER CENTRAL WATER ASSOCIATION is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report, Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels, Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or	MCL, TT, or	Your Water	Low	High	Sample Date	Violation	Typical Source
	MRDLG	MRDL						
Disinfectants & Disin	fectant B	y-Produc	ts					W. 11.
(There is convincing ev	vidence tha	t additio	of a disi	infecta	nt is ne	cessary fo	r control of	microbial contaminants)
Chlorine (as Cl2) (MG/L)	4	4	.70	.43	1,14	2017	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	5.0	1.0	5.0	2016	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	11.1	NA	11.1	2016	No	By-product of drinking water disinfection
Inorganic Contamina	ants						371	
Nitrate [measured as Nitrogen] (ppm)	10	10	.08	.08	.08	2017	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	.02	.02	.02	2017	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Cyanide [as Free Cn] (ppm)	0,2	0.2	.015	.015	.015	2015	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Antimony (ppb)	6	6	0,5	0.5	0.5	2016	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	0.5	0.5	0.5	2016	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	.0097	NA	.0097	2016	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposit

Berryllium (ppb)	4	4	0.5	0.5	0.5	2016	No	Discharge from metal refineries, Coal burning factories. Discharge from electrical, aerospace, and defense industries.
Cadmium (ppb)	5	5	0.5	0.5	0,5	2016	No	Corrosion of galvanized pi Erosion of natural deposit Discharge from metal refineries; runoff from wa batteries and paints
Chromium (ppb)	100	100	.17	NA	_{>x} 17	2016	No	Discharge from steel and mills; Erosion of natural deposits
Fluoride (ppm)	4	4	0.181	NA	0.181	2016	No	Erosion of natural deposit Water additive which promotes strong teeth; Discharge from fertilizer a aluminum factories
Mercury [Inorganic] (ppb)	2	2	0.5	0.5	0.5	2016	No	Erosion of natural deposit Discharge from refineries factories; Runoff from landfills; Runoff from cropland
Selenium (ppm)	0.05	0.05	.0025	.002	.002 5	2016	No	Discharge from petroleum metal refineries; Erosion o natural deposits; Discharg from mines
Thallium (ppb)	0.5	2	0.5	0.5	0.5	2016	No	Discharge from electronic glass, and Leaching from processing sites; drug factorics
Volatile Organic Cor	taminant		•					*
1,2,4 Trichlorobenzene (ppb)	70	70	0.5	0.5	0.5	2006	No	Discharge from textile finishing factories
cis-1,2 Dichlorocthylene (ppb)	70	70	0.5	0.5	0.5	2006	No	Discharge from industrial chemical factories
Xylenes (ppm)	10	10	0.0005	0.00 05	0.000 5	2016	No	Discharge from petroleum factories; Discharge from chemical factories
o-Dichlorobenzene (ppb)	600	600	0.5	0.5	0.5	2016	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	0.5	0.5	2016	No	Discharge from industrial chemical factories
Vinyl Chloride (ppb)	0	2	0.5	0.5	0.5	2016	No	Leaching from PVC piping Discharge from plastics factories
1,1-Dichloroethylene (ppb)	7	7	0.5	0.5	0.5	2016	No	Discharge from industrial chemical factories
trans-1,2 Dicholoroethylene	100	100	0.5	0.5	0.5	2016	No	Discharge from industrial chemical factories

Radioactive Contaminants

Uranium (ppb)	0	30	0.5			2012	N	No.	Ето	sion of natural deposits
I,1,1-Trichloroethane (ppb)	200	200	0.5	0.5	0.5	2016	N	lo	deg	charge from metal reasing sites and other ories
Carbon Tetrachloride (ppb)	0	5	0.5	0.5	0.5	2016	N	lo	plan	charge from chemical ats and other industrial vities
1,2-Dichloropropane (ppb)	0	5	0.5	0.5	0.5	2016	N	lo	ı	charge from industrial
Trichloroethylene (ppb)	0	5	0,5	0.5	0.5	2016	N	10	deg	charge from metal reasing sites and other ories
1,1,2-Trichloroethane (ppb)	3	5	0.5	0,5	0.5	2016	N	10	ı	charge from industrial mical factorics
Tetrachloroethylene (ppb)	0	5	0.5	0.5	0.5	2016	N	lo	ı	charge from factories and cleaners
Benzene (ppb)	0	5	0.5	0.5	0.5	2016	N	10	Lca	charge from factories; ching from gas storage cs and landfills
Toluene (ppm)	1	1	0.0005	0.00 05	0.000 5	2016	N	10	ı	charge from petroleum ories
Ethylbenzene (ppb)	700	700	0.5	0.5	0.5	2016	N	lo	ı	charge from petroleum neries
Styrene (ppb)	100	100	0.5	0.5	0.5	2016	N	10	plas	charge from rubber and stic factories; Leaching n landfills
Dichloromethane (ppb)	0	5	0.5	0.5	0.5	2016	N	10	pha	charge from rmaceutical and chemical cories
Contaminants	MCLG	AL	Your Water		nple	# Samp		Exced	eds	Typical Source
Inorganic Contamina	ints	1								
Copper - action level at consumer taps (ppm)	1.3	1.3	Л	2	017	0		No	-	Corrosion of household plumbing systems; Erosior of natural deposits
Lead - action level at consumer taps (ppb)	0	15	0	2	.017	0		No		Corrosion of household plumbing systems; Erosion of natural deposits

nit Descriptions								
Term	Definition							
ppm	ppm: parts per million, or milligrams per liter (mg/L)							
ppb	ppb: parts per billion, or micrograms per liter (μg/L)							
NA	NA: not applicable							
ND	ND: Not detected							
NR	NR: Monitoring not required, but recommended.							

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water, MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCI or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: LARRY COPLING

Address:
P.O. BOX 419
MCNEILL, MS 39457
Phone: 601-798-3103
Fax: 601-798-3130
E-Mail: prcwater@att.net

CONSUMER CONFIDENCE REPORT PEARL RIVER CENTRAL WATER ASSOCIATION PWS ID# 550002 2017

Is my water safe?

Last year your tap water met all U.S. Environmental Protection Agency (EPA) and state drinking water health standards. Local Water vigilantly safeguards its water supplies and once again we are proud to report that our system has not violated a maximum contaminant level or any other water quality standard.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

We serve our customers with groundwater that is drawn from 2 wells that tap into the Upper Pascagoula aquifer.

Source water assessment and its availability

Our source water assessment has been completed. Our wells ranked lower in terms of susceptibility to contamination. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Drinking Water Hotline at 1-800-426-4791.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). **How can I get involved?**

If you have any questions or concerns, please contact Larry Copling at 601-798-3103. We want our customers to be informed about their water quality. If you would like to learn more, please attend any of our regularly scheduled meetings. Monthly meetings are held at 2:00pm on the fourth Tuesday of each month at our offices located: 17 White Chapel Rd., Carriere.

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisims that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Additional Information for Lead If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. PEARL RIVER CENTRAL WATER ASSOCIATION is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL		Low	High	Sample Date	Violation	Typical Source
Disinfectants & Disi	nfectant By	-Produc	ts	III I	100	5 1/23		
There is convincing e	vidence the	t addition	of a dis	infecta	nt is ne	cessary fo	r control of	microbial contaminants)
Chlorine (as Cl2) (MG/L)	4	4	.70	.43	1.14	2017	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	5.0	1.0	5.0	2016	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	11.1	NA	11.1	2016	No	By-product of drinking water disinfection
Inorganic Contamin	ants					Sel Sur	le letti	
Nitrate [measured as Nitrogen] (ppm)	10	10	.08	.08	.08	2017	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	.02	.02	.02	2017	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Cyanide [as Free Cn] (ppm)	0.2	0.2	.015	.015	.015	2015	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Antimony (ppb)	6	6	0.5	0.5	0.5	2016	No	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition.
Arsenic (ppb)	0	10	0.5	0.5	0.5	2016	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	.0097	NA	.0097	2016	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposit

Berryllium (ppb)	4	4	0.5	0.5	0.5	2016	No	Discharge from metal refineries, Coal burning factories. Discharge from electrical, aerospace, and defense industries.
Cadmium (ppb)	5	5	0.5	0.5	0.5	2016	No	Corrosion of galvanized pipes; Erosion of natural deposits; Discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppb)	100	100	.17	NA	.17	2016	No	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	4	4	0.181	NA	0.181	2016	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury [Inorganic] (ppb)	2	2	0.5	0.5	0.5	2016	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from cropland
Selenium (ppm)	0.05	0.05	.0025	.002 5	.002 5	2016	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Thallium (ppb)	0.5	2	0.5	0.5	0.5	2016	No	Discharge from electronics, glass, and Leaching from ore processing sites; drug factories
Volatile Organic Con	teminant	161			1770	wite's		
1,2,4 Trichlorobenzene (ppb)	70	70	0.5	0.5	0.5	2006	No	Discharge from textile finishing factories
cis-1,2 Dichloroethylene (ppb)	70	70	0.5	0.5	0.5	2006	No	Discharge from industrial chemical factories
Xylenes (ppm)	10	10	0.0005	0.00 05	0.000 5	2016	No	Discharge from petroleum factories; Discharge from chemical factories
o-Dichlorobenzene (ppb)	600	600	0.5	0.5	0.5	2016	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	0.5	0.5	0.5	2016	No	Discharge from industrial chemical factories
Vinyl Chloride (ppb)	0	2	0.5	0.5	0.5	2016	No	Leaching from PVC piping; Discharge from plastics factories
1,1-Dichloroethylene (ppb)	7	7	0.5	0.5	0.5	2016	No	Discharge from industrial chemical factories
trans-1,2 Dicholoroethylene (ppb)	100	100	0.5	0.5	0.5	2016	No	Discharge from industrial chemical factories

Radioactive Contaminants

Uranium (ppb)	0	30	0.5			2012	No	Erosion of natural deposits
1,1,1-Trichloroethane (ppb)	200	200	0.5	0.5	0.5	2016	No	Discharge from metal degreasing sites and other factories
Carbon Tetrachloride (ppb)	0	5	0.5	0.5	0.5	2016	No	Discharge from chemical plants and other industrial activities
1,2-Dichloropropane (ppb)	0	5	0.5	0.5	0.5	2016	No	Discharge from industrial chemical factories
Trichloroethylene (ppb)	0	5	0.5	0.5	0.5	2016	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	0.5	0.5	0.5	2016	No	Discharge from industrial chemical factories
Tetrachloroethylene (ppb)	0	5	0.5	0.5	0.5	2016	No	Discharge from factories and dry cleaners
Benzene (ppb)	0	5	0.5	0.5	0.5	2016	No	Discharge from factories; Leaching from gas storage tanks and landfills
Toluene (ppm)	1	1	0.0005	0.00 05	0.000 5	2016	No	Discharge from petroleum factories
Ethylbenzene (ppb)	700	700	0.5	0.5	0.5	2016	No	Discharge from petroleum refineries
Styrene (ppb)	100	100	0.5	0.5	0.5	2016	No	Discharge from rubber and plastic factories; Leaching from landfills
Dichloromethane (ppb)	0	5	0.5	0.5	0.5	2016	No	Discharge from pharmaceutical and chemical factories
Contaminants	MCLG	AL	Your Water		nple	# Samj Exceedin		A Company of the Comp
Inorganic Contamina	ints			M.	HAV.		V-1287	
Copper - action level at consumer taps (ppm)	1.3	1.3	0	2	014	0	N	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	0	2	014	0	N	Corrosion of household plumbing systems; Erosion of natural deposits

nit Descriptions							
Term	Definition						
ppm	ppm: parts per million, or milligrams per liter (mg/L)						
ррь	ppb: parts per billion, or micrograms per liter (μg/L)						
NA	NA: not applicable						
ND	ND: Not detected						
NR	NR: Monitoring not required, but recommended.						

Important Drinking Water Definitions

Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: LARRY COPLING

Address: P.O. BOX 419

MCNEILL, MS 39457 Phone: 601-798-3103 Fax: 601-798-3130 E-Mail: prcwater@att.net

PEARL RIVER CENTRAL WATER ASSOC. P.O. BOX 419, MCNEILL, MS 39457

41600 previous charge		41600 35.70	07/15/2017 52.70	After the 15th 52.70	
previous reading present reading consumption credit balance charge	05/02/2018 06/01/2018 1200	108500 109700 gallons 17.00	41600 41600 Office hours 8:00am to 5:00pm Monday - Friday The CCR is now available at http://ccrwater.net/prcwater-39296 If you would like to receive a hard copy please call our office at (601)798-3103		
07/15/2017 109 SEVENTH	52.70 AVE	35.70 After the 15th 52.70	P.O. BOX 222 MCNEILL, MS 3	MELODY A COPLING P.O. BOX 222 MCNEILL, MS 39457- *Return service requested	