

2017 CERTIFICATION

RECEIVED-WATER SUPPLY

Consumer Confidence Report (CCR) 2018 JUN -4 AM 9: 05

Town of Summertown

Public Water System Name

0590009

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper *(Attach copy of advertisement)*
- On water bills *(Attach copy of bill)*
- Email message *(Email the message to the address below)*
- Other Enclosed w/ water Bills

Date(s) customers were informed: 5/31/2018 / /2018 / /2018

CCR was distributed by (U.S. Postal Service) or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: 5/31/18

CCR was distributed by Email *(Email MSDH a copy)*

Date Emailed: ___ / ___ /2018

- As a URL _____ *(Provide Direct URL)*
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: ___ / ___ /

CCR was posted in public places. *(Attach list of locations)*

Date Posted: ___ / ___ /2018

CCR was posted on a publicly accessible internet site at the following address:

_____ *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Suzana Hickman City Clerk
Name/Title *(President, Mayor, Owner, etc.)*

5-31-2018
Date

Submission options *(Select one method ONLY)*

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

Not a preferred method due to poor clarity

CCR Deadline to MSDH & Customers by July 1, 2018!

2018 JUN 15 AM 9:48

Corrected 2017 Annual Drinking Water Quality Report
Jumpertown Water Dept.
PWS ID# 0590009
June 15, 2018

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is two wells. Our wells draw from the Gordo Formation.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are **moderate** susceptibility to contamination and is available for viewing upon request.

I'm pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Donna Hickman at (662) 728-3658. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:00 P.M. at the Town Hall.

Jumpertown Water Dept. routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2017. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Disinfectants & Disinfection By-Products (There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl ₂) (ppm)	N	2017	1.5	0.60—2.0	Ppm	4	4	Water additive used to control microbes
Inorganic Contaminants								
Chromium	N	*2016	1.6	No-range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Barium	N	*2016	.241	No-Range	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Lead	N	1/1/15-12/31/17	1.0	No-Range	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Cyanide	N	*2016	27.0	No-Range	Ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Copper	N	1/1/15-12/31/17	0.6	No-Range	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Volatile Organic Contaminants								
HAA5	N	*2016	6.0	No-Range	Ppb	0	60	By-product of drinking water chlorination

*Most recent sample. No sample was required in 2017

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The **Town of Jumpertown** is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call 662-728-3658 if you have any questions.

2018 JUN -1 PM 4: 18

2017 Annual Drinking Water Quality Report

Jumpertown Water Dept.

PWS ID# 0590009

May 7, 2018

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is two wells. Our wells draw from the Gordo Formation.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are moderate susceptibility to contamination and is available for viewing upon request.

I'm pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Donna Hickman at (662) 728-3658. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:00 P.M. at the Town Hall.

Jumpertown Water Dept. routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2017. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.)								
Chlorine (as Cl ₂) (ppm)	N	2017	1.5	0.60—2.0	Ppm	4	4	Water additive used to control microbes
Inorganic Contaminants								
Chromium	N	*2016	1.6	No-range	Ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Barium	N	*2016	.241	.236--241	Ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Lead	N	*2011	.9	.7--.9	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
Cyanide	N	*2016	27.0	No-Range	Ppb	200	200	Discharge from steel/metal factories; discharge from plastic and fertilizer factories
Copper	N	2017	.5544	.0038--.5544	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Volatile Organic Contaminants								
HAA5	N	*2016	6.0	No-Range	Ppb	0	60	By-product of drinking water chlorination

*Most recent sample. No sample was required in 2017

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Jumpertown is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call 662-728-3658 if you have any questions.

JUMPERTOWN WATER DEPT.
 679 HWY 4 WEST
 BOONEVILLE, MS 38829-0000
 (662)728-3658 () -

Route - 1 Account - 10

Reading Date - 05/23/2018

-PRE AUTHORIZED DRAFT-

Due By: 06/10/2018

Amount: 19.00

Amount Enclosed:

Due After: 06/10/2018

Amount: 20.90

BOBBY JENNINGS

1402 NINTH STREET
 BOONEVILLE, MS 38829

Return this portion with your payment

Account Information		Service	Present	Previous	Usage	Charge
Route- 1 Acctno- 10 BOBBY JENNINGS 1402 NINTH STREET BOONEVILLE, MS 38829		WA M1	2033650	2032760	890	18.00 1.00
Remaining Meter Deposit						
Water	75.00					
Account Aging						
Current	19.00					
30 Day	0.00					
60 Day	0.00					
90 Day & Over	0.00					
Last Payment Of \$ 19.00 Made On 05/09/2018 Check #						
Total Due By: 06/10/2018						19.00
Late Charge:						1.90
Amount Due If Paid After: 06/10/2018						20.90

2017 CCR REPORT ENCLOSED WITH WATER BILL

JUMPERTOWN WATER DEPT.
 679 HWY 4 WEST BOONEVILLE, MS 38829-0000 (662)728-3658 () -