

2017 CERTIFICATION 2018 JUL 13 AM 8:51

Consumer Confidence Report (CCR)

Leesburg Water Association, Inc.

Public Water System Name

610013

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

† Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

† Advertisement in local paper *(Attach copy of advertisement)*

† On water bills *(Attach copy of bill)*

† Email message *(Email the message to the address below)*

† Other _____

Date(s) customers were informed: 04 / 25 / 2018 05 / 24 / 2018 06 / 25 / 2018

† CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ____ / ____ / ____

† CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: ____ / ____ / 2018

† As a URL _____ *(Provide Direct URL)*

† As an attachment

† As text within the body of the email message

† CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: ____ / ____ / ____

† CCR was posted in public places. *(Attach list of locations)* Date Posted: 06 / 25 / 2018

† CCR was posted on a publicly accessible internet site at the following address:

leesburgwater.com/ccr/ _____ *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Kathy Nguyen Manager
Name/Title *(President, Mayor, Owner, etc.)*

6/25/2018
Date

Submission options *(Select one method ONLY)*

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2018!

2017 Annual Drinking Water Quality Report
 Leesburg Water Association, Inc.
 PWS#: 0610013
 April 2018

2018 APR 25 PM 1:51

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Sparta Sand Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Leesburg Water Association have received lower susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Kathy Nazary, Manager at 601.854.8729. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday following the 5th of the month at 6:30 PM at the Leesburg Water Assn office or the annual meeting is held the first Monday in March at 7:00 PM at the Leesburg Volunteer Fire Dept.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2017. In cases where monitoring wasn't required in 2017, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2016*	.0486	.0029 - .0486	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

14. Copper	N	2014/16*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2016*	.848	.765 - .848	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2014/16*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2017	.39	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2016*	6	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	1.02	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	1.9	1.2 – 2.2	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2017

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our system is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.3 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.3 ppm was 97%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Leesburg Water Association, Inc. works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

LEESBURG WATER ASSN., INC.
 368 HWY. 481
 PELAHATCHIE, MS 39145

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PELAHATCHIE, MS
 PERMIT NO. 2

PLEASE READ NOTICE ON BACK RETURN SERVICE REQUESTED

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	130	0	130	25.50

ROUTE	CUSTOMER ACCOUNT	DUE DATE PAST DUE AFTER THIS DATE
1	476	7/10/18
TOTAL DUE UPON RECEIPT		28.05
		25.50

MAIL THIS STUB WITH YOUR PAYMENT
 LEESBURG/LIBERTY VOL. FIRE DEPT. \$1.00

C/O CHARLIE SHOEMAKER

METER READ MONTH DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
6 20	1	25.50	2.55	28.05

NMR
 BILLY WOOTEN
 C/O CHARLIE SHOEMAKER
 1056 IRBY ROAD
 MORTON MS 39117

CUTOFF DATE 7/21/18
 2017 CCR REPORT AVAILABLE ON WEBSITE
 LEESBURG WATER.COM/CCR/
 CONTACT OFFICE FOR A HARD COPY
 OFFICE WILL BE CLOSED JUNE 4, 2018

LEESBURG WATER ASSN., INC.
 368 HWY. 481
 PELAHATCHIE, MS 39145

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PELAHATCHIE, MS
 PERMIT NO. 2

PLEASE READ NOTICE ON BACK

RETURN SERVICE REQUESTED

TYPE OF SERVICE	METER READING		USED	CHARGES
	PRESENT	PREVIOUS		
Water	297920	295450	2.470	27.57

CUSTOMER		DUE DATE
ROUTE	ACCOUNT	PAST DUE AFTER THIS DATE
2	897	6/10/18
TOTAL DUE UPON RECEIPT		PAST DUE AMOUNT
27.57		30.33

MAIL THIS STUB WITH YOUR PAYMENT

LEESBURG/LIBERTY VOL. FIRE DEPT.-\$1.00

2079 HWY 43 N



ACCOUNT # 897 5/24/2018

METER READ MONTH	METER READ DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
5	15	1	27.57	2.76	30.33

TERREL T. MCKAY
 2079 HIGHWAY 43 N
 PELAHATCHIE MS
 39145-2836

CUTOFF DATE 6/21/2018
 2017 CCR REPORT AVAILABLE ON WEBSITE
 LEESBURGWATER.COM/CCR/
 CONTACT OFFICE FOR A HARD COPY

LEESBURG WATER ASSN., INC.
 368 HWY. 481
 PELAHATCHIE, MS 39145

RETURN SERVICE REQUESTED

PLEASE READ NOTICE ON BACK

TYPE OF SERVICE	METER READING PRESENT	METER READING PREVIOUS	USED	CHARGES
Water	985860	979760	6.100	43.54

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PELAHATCHIE, MS
 PERMIT NO. 2

CUSTOMER ROUTE	ACCOUNT	DUE DATE PAST DUE AFTER THIS DATE
1	347	5/10/18
TOTAL DUE UPON RECEIPT		43.54
		PAST DUE AMOUNT
		43.54

MAIL THIS STUB WITH YOUR PAYMENT
 LEESBURG/LIBERTY VOL. FIRE DEPT.-\$1.00

5962 MEASLES RD
 THIS BILL IS PAID BY BANK DRAFT. DO NOT PAY!!!
 ACCOUNT # 347 4/25/2018

METER READ MONTH	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
4	1	43.54	0.00	43.54

CUTOFF DATE 5/21/2018
 2017 CCR REPORT AVAILABLE ON WEBSITE
 LEESBURGWATER.COM
 CONTACT OFFICE FOR A HARD COPY

BONNIE MINTON
 C/O KAREN LAMPKIN
 233 FLEMING RD
 PELAHATCHIE MS
 39145-2865

Leesburg Water Association

From: Leesburg Water Association <lburgwtr1@att.net>
Sent: Tuesday, July 10, 2018 1:17 PM
To: 'water.reports@msdh.gov'
Subject: Leesburg Water Association - CCR Report
Attachments: 2017CCRREPORT.pdf

Please find attached, the 2017 CCR Report as required by the State Department of Health. Please let me know if you need any additional information.

Thanks,
Kathy Nazary
Leesburg Water Association
60-854-8729

We have copies in our office, it has been posted to URL ^{Leesburg} _{water.com}
 ccr/

also was printed on 3 months of bills.



PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
39145 PELAHATCHIE, MS
PERMIT NO. 2

LEESBURG WATER ASSN., INC.
368 HWY. 481
PELAHATCHIE, MS 39145

RETURN SERVICE REQUESTED

PLEASE READ NOTICE ON BACK

METER READING		USED	CHARGES
TYPE OF SERVICE	PRESENT	PREVIOUS	
Water	983860	979760	6.100 43.54

CUSTOMER ACCOUNT NO. 347	DUE DATE 5/10/18
TOTAL DUE UPON RECEIPT 43.54	PAST DUE AMOUNT 43.54

MAIL THIS STUB WITH YOUR PAYMENT

LEESBURG LIBERTY VOL. FIRE DEPT. -\$1.00



5962 MEASEL RD
THIS BILL IS PAID BY BANK DRAFT. DO NOT PAY!!!
ACCOUNT # 347 4/25/2018

BONNIE MINTON
C/O KAREN LAMPKIN
233 FLEMING RD
PELAHATCHIE MS
39145-2865

METER READ MONTH	DAY	CLASS	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
4	20	1	43.54	0.00	43.54

CUTOFF DATE 5/21/2018
2017 CCR REPORT AVAILABLE ON WEBSITE
LEESBURGWATER.COM
CONTACT OFFICE FOR A HARD COPY