

2017 CERTIFICATION

Consumer Confidence Report (CCR)

SRG Water Association, Inc

Public Water System Name

0620011 + 0620023

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper *(Attach copy of advertisement)*

On water bills *(Attach copy of bill)*

Email message *(Email the message to the address below)*

Other _____

Date(s) customers were informed: 7/1/2018 / / 2018 / / 2018

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

CCR was distributed by Email *(Email MSDH a copy)*

Date Emailed: / / 2018

As a URL _____ *(Provide Direct URL)*

As an attachment

As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Scott Co. Times

Date Published: 05/30/2018

CCR was posted in public places. *(Attach list of locations)*

Date Posted: / / 2018

CCR was posted on a publicly accessible internet site at the following address: _____

(Provide Direct URL)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Kerry Hannon
Name/Title *(President, Mayor, Owner, etc.)*

6-12-18
Date

Submission options *(Select one method ONLY)*

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576-7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2018!

2017 Annual Drinking Water Quality Report
 SRG Water Association, Inc.
 PWS#: 0620011 & 0620023
 April 2018

RECEIVED-WATER SUPPLY
 2018 MAY -1 AM 8:48

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Meridian Sand and Meridian Upper Wilcox Aquifers.

If you have any questions about this report or concerning your water utility, please contact Mary Ann Warren at 601.469.2530. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Monday of each month at 7:00 PM at the S.R.G. office.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the SRG Water Association have received a lower susceptibility ranking to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2017. In cases where monitoring wasn't required in 2017, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID #: 0620011		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2016*	.0029	.0023 - .0029	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2016*	.21	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								

81. HAA5	N	2016*	12	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	11.64	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	.6	.6 – .7	Mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID #: 0620023		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
5. Gross Alpha	N	2014*	.6	No Range	pCi/L	0	15	Erosion of natural deposits
Inorganic Contaminants								
10. Barium	N	2016*	.0027	.0014 - .0027	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2016*	2.8	1.1 – 2.8	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2016*	.125	.104 - .125	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	.7	.6 – .7	Mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2017.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected, however, the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The SRG Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

(See Attached)

AFFIDAVIT OF PUBLICATION

State of Mississippi
County of Scott

On the 7th day of June, 2018,

Personally came Cindy Harrell, clerk,
of The Scott County Times, a weekly newspaper
established more than twelve months before the date first
hereinafter mentioned, printed and published in the City
of Forest, County of Scott, State of Mississippi, before
me, the undersigned authority in and for said County,
who being duly sworn, deposes and says that a certain

Legal ad,
a copy of which is hereto attached, was published in said
paper _____ consecutive weeks, to wit:

May 30, 2018
_____, 2018
_____, 2018
_____, 2018

Signed Cindy Harrell

Sworn to and subscribed before me this 7th day
of June, 2018.

Lee Anne Palmer
Notary Public
xlolunick &



LEE ANNE LIVINGSTON PALMER
CHANCERY CLERK, SCOTT CO., MS
MY COMMISSION EXPIRES JAN. 6, 2020



The Scott County Public Library staff is excited to kick-off the library's summer reading program "Libraries Rock". Pictured from left, Selena Swink, Branch Manager, Lake Library, Dianne McLaurin, Asst. Branch Manager, Forest Library, Brandi Parker, Youth Services Specialist, and Andrea Arney, Branch Manager, Sebastopol Library.

Libraries

From page 1

provide funding and support to the library system. It is their funding and support that helps make the summer programs successful. The aforesaid support is utilized to the maximum by the hard work and dedication of all library staff and volunteers. It is their tireless effort and planning that allows Scott County to offer a summer reading program that benefits children, teenagers and adults in all library locations.

"The branch managers at the Scott County libraries decided to collaborate this year with the public announcement of each library's scheduled events. Parents will be able to see what's going on when and where and attend as many programs as possible during this six-week period," McLaurin added.

Public libraries meet the social needs of young people by providing a safe, and fun learning environment, to meet-up with their friends and classmates throughout the summer. Books are no different from movies, music and sports when it comes to school-aged children. If it is popular with their friends, they are more inclined to open the book and read it. Studies show that 80 percent of students who read recreationally out-perform those who don't. The county libraries have worked hard to make recreational reading interactive and fun so that more kids will understand that reading can be fun and enjoyable.

2017 Annual Drinking Water Quality Report SRG Water Association, Inc. PWS# 0620011 & 0620023 April 2018

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Meridian Sand and Meridian Upper Witcox Aquifers.

If you have any questions about this report or concerning your water utility, please contact Mary Ann Warren at 801.498.2530. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the third Monday of each month at 7:00 PM at the S.R.G. office.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the SRG Water Association have received a lower susceptibility ranking to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2017. In cases where monitoring wasn't required in 2017, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID #: 0620011							
TEST RESULTS							
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/AQL	Unit Measurement	MCLG MCL	Likely Source of Contamination
Inorganic Contaminants							
10. Barium	N	2018*	.0029	.0023 - .0029	ppm	2	2
13. Chromium	N	2018*	21	No Range	ppb	100	100
14. Copper	N	2018/17	4		ppm	1.3	1.3

Discharge of drilling wastes, discharge from metal refineries; erosion of natural deposits

Discharge from steel and pulp mills; erosion of natural deposits

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	By-Product of drinking water disinfection
81. HAA5	N	2016*	12	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. THM (Total trihalomethanes)	N	2016*	11.84	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	6	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID #: 0620023

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
5. Gross Alpha	N	2014*	5	No Range	pCi/L	0	15	Erosion of natural deposits

Radioactive Contaminants

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
10. Barium	N	2016*	.0027	.0014-.0027	ppm	2	2	Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits
13. Chromium	N	2016*	2.8	1.1-2.8	ppb	100	100	Discharge from steel and pulp mills, erosion of natural deposits
14. Copper	N	2015/17	2	0	bpm	1.3	AL=3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2016*	125	104-125	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

Inorganic Contaminants

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

Disinfection By-Products

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects (or # of Samples Exceeding MCL/AGL)	Unit Measurement	MCLG	MCL	Likely Source of Contamination
81. HAA5	N	2016*	24	No Range	ppb	0	60	By-Product of drinking water disinfection
82. THM (Total trihalomethanes)	N	2016*	29.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017	7	6-7	Mg/l	0	MDRL = 4	Water additive used to control microbes

jects and interests from which to chose. The formats include magazines, graphic novels, public computers and WiFi capabilities so that school children's reading choices are available on, and through, numerous educational mediums.

In this technology driven day-and-time having choices is incredibly important. Local libraries have worked very hard to offer students all possible ways to find, and enjoy, their reading material. McLaurn says, "it's going to be a rockin' summer for sure!"

Listed below are all the summer library scheduled events and contact numbers for Forest, Lake, Morton, and Sebastopol.

FOREST PUBLIC LIBRARY
601-469-1481

Preschool Story Time - Wednesday at 11:15 a.m.
K-6th Grades - Tuesday at 2:00 p.m.
June 5 - Magician Donan LaChance
June 12 - Storyteller Dianne Butler
June 19 - Animal Tales
June 26 - Freedom Ranch
July 3 - Dan the Banjo Man
July 10 - CMRLS Puppets
TEENS - Tuesday at 5:00 p.m.
June 19 - Lip Sync Live
July 10 - Karaoke Crooners

MORTON PUBLIC LIBRARY
601-732-6288

Preschool Story Time - Tuesday at 10:30 a.m.
K-6th Grades - Thursday at 2:00 p.m.
June 7 - Storyteller Dianne Butler (Special Performance at 5:00 p.m.)
June 14 - CMRLS Puppets
June 21 - Let's Make Music
June 28 - Animal Tales (Special Performance at 5:00 p.m.)
July 5 - Dancing Dan the Banjo Man
July 12 - Guitar Art and Party
TEENS - Tuesday at 2:00 p.m.
June 7 - CD Art
June 28 - Teen Movie Sing (Universal Pictures - PG, 1 hour 46 mins)
ADULTS - Tuesday at 5:00 p.m.
June 14 - ZUMBA

LAKE PUBLIC LIBRARY
601-775-3560

K-6th - Thursday at 10:00 a.m.
June 7 - Children's Illustrator Chuck Galey
June 14 - CMRLS Puppets
June 21 - Animal Tales
June 28 - Steel Drummer Mitch Warner
July 5 - Cupcake Creations @ Pheanice's Sweet Creations
July 12 - Bagniper Zoe Brumfield
TEENS - Wednesday at 1:00 p.m.
June 13 - Teen Theater
June 27 - Teen Dance-Of
July 11 - Teen Theater
ADULTS - Monday at 1:30 p.m.
June 11 - Adult Art Class (Pre-registration required. Cost for materials - \$10.00)

SEBASTOPOL PUBLIC LIBRARY
601-625-8826

K-6th Grades - Wednesday at 10:00 a.m.
June 6 - Magician Donan LaChance
June 13 - INKY the Clown
June 20 - MSU Extension Service
June 27 - CMRLS Puppets
July 4 - LIBRARIES CLOSED
July 11 - Sebastopol Fire Department
For more information about any of the county's summer library programs please contact the libraries at the numbers listed above. All four of the Scott County public libraries are part of the Central Mississippi Regional Library System.

SEBASTOPOL PUBLIC LIBRARY
601-625-8826

K-6th Grades - Wednesday at 10:00 a.m.
June 6 - Magician Donan LaChance
June 13 - INKY the Clown
June 20 - MSU Extension Service
June 27 - CMRLS Puppets
July 4 - LIBRARIES CLOSED
July 11 - Sebastopol Fire Department
For more information about any of the county's summer library programs please contact the libraries at the numbers listed above. All four of the Scott County public libraries are part of the Central Mississippi Regional Library System.

SEBASTOPOL PUBLIC LIBRARY
601-625-8826

K-6th Grades - Wednesday at 10:00 a.m.
June 6 - Magician Donan LaChance
June 13 - INKY the Clown
June 20 - MSU Extension Service
June 27 - CMRLS Puppets
July 4 - LIBRARIES CLOSED
July 11 - Sebastopol Fire Department
For more information about any of the county's summer library programs please contact the libraries at the numbers listed above. All four of the Scott County public libraries are part of the Central Mississippi Regional Library System.

SEBASTOPOL PUBLIC LIBRARY
601-625-8826

K-6th Grades - Wednesday at 10:00 a.m.
June 6 - Magician Donan LaChance
June 13 - INKY the Clown
June 20 - MSU Extension Service
June 27 - CMRLS Puppets
July 4 - LIBRARIES CLOSED
July 11 - Sebastopol Fire Department
For more information about any of the county's summer library programs please contact the libraries at the numbers listed above. All four of the Scott County public libraries are part of the Central Mississippi Regional Library System.

SEBASTOPOL PUBLIC LIBRARY
601-625-8826

K-6th Grades - Wednesday at 10:00 a.m.
June 6 - Magician Donan LaChance
June 13 - INKY the Clown
June 20 - MSU Extension Service
June 27 - CMRLS Puppets
July 4 - LIBRARIES CLOSED
July 11 - Sebastopol Fire Department
For more information about any of the county's summer library programs please contact the libraries at the numbers listed above. All four of the Scott County public libraries are part of the Central Mississippi Regional Library System.

SEBASTOPOL PUBLIC LIBRARY
601-625-8826

K-6th Grades - Wednesday at 10:00 a.m.
June 6 - Magician Donan LaChance
June 13 - INKY the Clown
June 20 - MSU Extension Service
June 27 - CMRLS Puppets
July 4 - LIBRARIES CLOSED
July 11 - Sebastopol Fire Department
For more information about any of the county's summer library programs please contact the libraries at the numbers listed above. All four of the Scott County public libraries are part of the Central Mississippi Regional Library System.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have teamed through our monitoring and testing that some contaminants have been detected, however, the EPA has determined that your water is SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDOH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601-576-7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The SFG Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.