

2019 MAY 21 AM 8:40

2018 CERTIFICATION

Consumer Confidence Report (CCR)

Town of Silver Creek
Public Water System Name

0390005

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)
 - Advertisement in local paper (*Attach copy of advertisement*)
 - On water bills (*Attach copy of bill*)
 - Email message (*Email the message to the address below*)
 - Other _____

Date(s) customers were informed: 4/23/2019 / / /2019

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used USPS

Date Mailed/Distributed: 4/23/2019

- CCR was distributed by Email (*Email MSDH a copy*) Date Emailed: ___ / ___ / 2019
 - As a URL _____ (*Provide Direct URL*)
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: _____


Date Published: ___ / ___ / ___

- CCR was posted in public places. (*Attach list of locations*) Date Posted: ___ / ___ / 2019

- CCR was posted on a publicly accessible internet site at the following address: _____ (*Provide Direct URL*)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply


Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

4-23-19
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2019!

Inorganic Contaminants

13. Chromium	N	2015*	1.3	1.1 – 1.3	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.1	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2015*	3.05	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	1.1	.95 – 1.1	ppm	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2018.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Town of Silver Creek has recently completed updating distribution lines and also abandoned an old well and water tank. We are in the process of applying for a grant to update more distribution lines.

TOWN OF SILVER CREEK

PO BOX 129

Silver Creek, MS 39663

(601) 886-7866

SRVC	PRESENT RDG	PREVIOUS RDG	USED	AMOUNT
WAT	363700	360730	2970	18.39

ACCOUNT #	ROUTE
194	01
SERVICE ADDRESS	
35 LESTER HAAS ROAD	
DUE DATE	NOW DUE
05/15/19	18.39
PAY EARLY SAVE THIS	REMIT AFTER DUE DATE

CCR AVAILABLE AT TOWN HALL

ALL THIS STUB WITH YOUR PAYMENT

ACCOUNT #	ROUTE
194	
SERVICE ADDRESS	
35 LESTER HAAS ROAD	
DUE DATE	REMIT AFTER DUE DATE
05/15/19	20.64

BARBARA BURAS
PO BOX 87
SILVER CREEK, MS 39663

TOWN OF SILVER CREEK
PO Box 129
Silver Creek, MS 39663
(601) 886-7866

TOWN OF SILVER CREEK

PO BOX 129

Silver Creek, MS 39663

(601) 886-7866

SRVC	PRESENT RDG	PREVIOUS RDG	USED	AMOUNT
WAT	163920	162430	1490	18.39

ACCOUNT #	ROUTE
101	01
SERVICE ADDRESS	
17 DOGWOOD DR.	
DUE DATE	NOW DUE
05/15/19	18.39
PAY EARLY SAVE THIS	REMIT AFTER DUE DATE
2.02	20.41

CCR AVAILABLE AT TOWN HALL

ALL THIS STUB WITH YOUR PAYMENT

ACCOUNT #	ROUTE
101	
SERVICE ADDRESS	
17 DOGWOOD DR.	
DUE DATE	REMIT AFTER DUE DATE
05/15/19	20.41

D.T. BURT
17 DOGWOOD DR.
SILVER CREEK, MS 39663

TOWN OF SILVER CREEK
PO Box 129
Silver Creek, MS 39663
(601) 886-7866

TOWN OF SILVER CREEK

PO BOX 129

Silver Creek, MS 39663

(601) 886-7866

SRVC	PRESENT RDG	PREVIOUS RDG	USED	AMOUNT
WAT	52170	49570	2600	15.23
TAX				1.07

ACCOUNT #	SERVICE
088	3154 SOUTHERN AVE
DUE DATE	REMIT AFTER DUE DATE
05/15/19	23.47
PAY EARLY SAVE THIS	

CCR AVAILABLE AT TOWN HALL

MAIL THIS STUB WITH YOUR PAYMENT

ACCOUNT #	ROUTE
088	
SERVICE ADDRESS	
3154 SOUTHERN AVE	
DUE DATE	REMIT AFTER DUE DATE
05/15/19	23.47

BUSY B, LLC
PO BOX 760
MONTICELLO, MS 39654

TOWN OF SILVER CREEK
PO Box 129
Silver Creek, MS 39663
(601) 886-7866

TOWN OF SILVER CREEK

PO BOX 129

Silver Creek, MS 39663

(601) 886-7866

SRVC	PRESENT RDG	PREVIOUS RDG	USED	AMOUNT
WAT	336120	332460	3660	19.08

ACCOUNT #	SERVICE
028	1437 N.A SANDLER RD
DUE DATE	REMIT AFTER DUE DATE
05/15/19	26.20
PAY EARLY SAVE THIS	

CCR AVAILABLE AT TOWN HALL

MAIL THIS STUB WITH YOUR PAYMENT

ACCOUNT #	ROUTE
028	
SERVICE ADDRESS	
1437 N.A SANDLER RD	
DUE DATE	REMIT AFTER DUE DATE
05/15/19	26.20

C.R. BUTLER
CHRISTOPHER BUTLER
1437 N.A. SANDLER R
SILVER CREEK, MS 396

TOWN OF SILVER CREEK
PO Box 129
Silver Creek, MS 39663
(601) 886-7866