

2019 MAY 14 PM 3: 24

2018 CERTIFICATION

Consumer Confidence Report (CCR)

Mt. Comfort Water Association

Public Water System Name

0070010 0070011 0070017 0070020

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)
 - Advertisement in local paper (*Attach copy of advertisement*)
 - On water bills (*Attach copy of bill*)
 - Email message (*Email the message to the address below*)
 - Other _____

Date(s) customers were informed: 5 / 8 / 2019 5 / 10 / 2019 5 / 25 / 2019

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ / ___

- CCR was distributed by Email (*Email MSDH a copy*) Date Emailed: ___ / ___ / 2019
 - As a URL _____ (*Provide Direct URL*)
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: The Calhoun County Journal

Date Published: 5 / 8 / 2019

- CCR was posted in public places. (*Attach list of locations*) Date Posted: ___ / ___ / 2019

- CCR was posted on a publicly accessible internet site at the following address: _____ (*Provide Direct URL*)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

[Signature], MANAGER
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5 / 10 / 19
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2019!

RECEIVED WATER SUPPLY

2018 Annual Drinking Water Quality Report
 Mt. Comfort Water Association
 PWS#: 070010, 070011, 070017 & 070020
 May 2019

2019 MAY -7 PM 1:05

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Chris Shelton at 662.983.8024. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 7:00 PM at the Mt. Comfort Water Association office located at 209 Center Street, Bruce, MS.

Our water source is from wells drawing from the Gordo Formation & Eutaw Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Mt. Comfort Water Association have received lower to moderate susceptibility rankings to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID # 070010		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
6. Radium 226 Radium 228	N	2016*	.6 <.4	No Range	pCi/L	0	5	Erosion of natural deposits
Inorganic Contaminants								
8. Arsenic	N	2018	3.9	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2018	.1678	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	2.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018	.403	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

16. Fluoride	N	2018	.14	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2018	4.7	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2017*	2.37	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	.4	.1 – .54	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID # 070011

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	--------------------	------	-----	--------------------------------

Inorganic Contaminants

8. Arsenic	N	2017*	2.1	2 – 2.1	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2017*	.1508	.1507 - .1508	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2017*	1.1	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2017*	.16	.156 - .16	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Volatile Organic Contaminants

76. Xylenes	N	2018	.000596	.000564 - .00596	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
-------------	---	------	---------	------------------	-----	----	----	---

Disinfection By-Products

Chlorine	N	2018	1	.63 – 1.31	mg/l	0	MDRL = 4	Water additive used to control microbes
----------	---	------	---	------------	------	---	----------	---

PWS ID # 070017

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	--------------------	------	-----	--------------------------------

Inorganic Contaminants

8. Arsenic	N	2018	5.1	4.6 – 5.1	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2018	.3549	.3298 - .3549	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2018	2.7	2.5 – 2.7	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018	.142	.139 - .142	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2018	5.8	5 – 5.8	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

81. HAA5	N	2017*	1	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2017*	3.46	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	.6	.11 – 1.63	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID # 070020

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	-------------------	------	-----	--------------------------------

Radioactive Contaminants

6. Radium 226 Radium 228	N	2016*	1.6 1	.7 – 1.6 No Range	pCi/L	0	5	Erosion of natural deposits
-----------------------------	---	-------	----------	----------------------	-------	---	---	-----------------------------

Inorganic Contaminants

8. Arsenic	N	2018	2.7	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2018	.1514	.1505 - .1514	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	2.9	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018	.175	.165 - .175	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2017*	1	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2017*	4.64	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	.4	.22 – .83	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2018.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality

drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Mt. Comfort Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Proof Of Publication

STATE OF MISSISSIPPI,
COUNTY OF CALHOUN

Personally came before me, the undersigned, a Notary Public, in and for Calhoun County, Mississippi, Joel McNeece, Publisher of The Calhoun County Journal, a newspaper published in Bruce, Calhoun County, in said state, who being duly sworn, deposes and says that The Calhoun County Journal is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858 of the Mississippi Code of 1942, and the publication of a notice, of which annexed copy, in the matter of

MT. COMFORT WATER ASSOCIATION WATER QUALITY REPORT

has been made in said newspaper one time, to-wit:

On the 8 day of MAY 2019

Joel McNeece

Joel McNeece
Publisher


Sworn to and subscribed before me, this 8 day of May

Celia D. Hillhouse

Celia D. Hillhouse,
Notary Public

My commission expires February 18, 2023

SEAL



2019 Annual Drinking Water Quality Report
Mt. Comfort Water Association
PWS# 070010, 070011, 070017 & 070020
May 2019

We're pleased to present to you this year's Annual Drinking Water Report. This report is designed to inform you about the quality of water and services we provide to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want to update you on the progress we've made in continually improving our water treatment processes and protecting water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or collecting your water bills, please contact Greg Brinkley at 662-681-2014. We will also have our staff available to you by appointment. If you want to learn more, please attend any of our monthly Drinking Water Meetings. They are held on the first Tuesday of each month at 7:00 PM at the Mt. Comfort Water Association Office located at 205 Center Street, Bruce, MS.

Our water supply is from wells drawing from the Gulf Piedmont and Blue Aquifer. The water treatment plant has been designed to treat water from these sources to meet the health and safety of our customers. The water treatment plant has been designed to meet the health and safety of our customers. The water treatment plant has been designed to meet the health and safety of our customers.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. The table below lists all of the drinking water contaminants that we monitor during the course of regular monitoring. In December 2018, we tested for 219 drinking water contaminants. As water flows from the surface of land or underground, it naturally contains various minerals, salts, and other substances. Some of these substances are naturally occurring and some are the result of human activities. Some of these substances are naturally occurring and some are the result of human activities. Some of these substances are naturally occurring and some are the result of human activities.

In this table you will find many terms and abbreviations you may not be familiar with. To help you better understand these terms, we've provided the following definitions:

- Action Level** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Contaminant Level (MCL)** - The "Maximum Allowable" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set at a value to protect the public health over the long-term based on the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG)** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected adverse health effects. MCLG is set at a level that is as close to zero as is technically feasible.
- National Primary Drinking Water Regulation (NPDWR)** - The federal level of a drinking water quality standard. There is a governing regulation that applies to a contaminant in drinking water.
- Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
- Parts per million (ppm) or milligrams per liter (mg/l)** - One part per million (ppm) is one millionth of a whole (one in 1,000,000). One part per billion (ppb) is one billionth of a whole (one in 1,000,000,000).

PWS ID # 070010 TEST RESULTS

Contaminant	Analysis Unit	Date Collected	Last Detected	Range of Values in 2018	Unit	MCL	MCLG	Health Effects of Contaminant
Radioactive Contaminants								
9. Radium 226 (Radium 226)	Bq/L	2018	18	No Range	ppb	0	0	Exposure to radium in drinking water can increase the risk of cancer.
Inorganic Contaminants								
4. Arsenic	ppm	2018	0.5	No Range	ppm	0.05	0.01	Exposure to arsenic in drinking water can increase the risk of cancer and heart disease.
10. Boron	ppm	2018	16.18	No Range	ppm	0	0	Exposure to boron in drinking water can cause harm to infants and young children.
13. Chloride	ppm	2018	2.4	No Range	ppm	100	100	Exposure to chloride in drinking water can cause harm to infants and young children.
14. Copper	ppm	2018	0.3	0	ppm	1.3	0.1	Exposure to copper in drinking water can cause harm to infants and young children.
16. Fluoride	ppm	2018	1.1	No Range	ppm	0	0	Exposure to fluoride in drinking water can cause harm to infants and young children.
17. Lead	ppm	2018	0	0	ppm	0	0	Exposure to lead in drinking water can cause harm to infants and young children.
21. Sulfate	ppm	2018	0.2	No Range	ppm	0	0	Exposure to sulfate in drinking water can cause harm to infants and young children.

Disinfection By-Products

Contaminant	Analysis Unit	Date Collected	Last Detected	Range of Values in 2018	Unit	MCL	MCLG	Health Effects of Contaminant
19. THM (Total Trihalomethanes)	ppm	2018	1.1	0.1 - 1.1	ppm	0	0	Exposure to THM in drinking water can cause harm to infants and young children.
20. Haloacetic Acids (HAA5)	ppm	2018	1.1	0.1 - 1.1	ppm	0	0	Exposure to HAA5 in drinking water can cause harm to infants and young children.

PWS ID # 070011 TEST RESULTS

Contaminant	Analysis Unit	Date Collected	Last Detected	Range of Values in 2018	Unit	MCL	MCLG	Health Effects of Contaminant
Inorganic Contaminants								
4. Arsenic	ppm	2018	0.1	0 - 0.1	ppm	0.05	0.01	Exposure to arsenic in drinking water can increase the risk of cancer and heart disease.
10. Boron	ppm	2018	16.18	0.00 - 16.18	ppm	0	0	Exposure to boron in drinking water can cause harm to infants and young children.
13. Chloride	ppm	2018	1.1	No Range	ppm	100	100	Exposure to chloride in drinking water can cause harm to infants and young children.
14. Copper	ppm	2018	0.1	0	ppm	1.3	0.1	Exposure to copper in drinking water can cause harm to infants and young children.
16. Fluoride	ppm	2018	0.18	0.00 - 0.18	ppm	0	0	Exposure to fluoride in drinking water can cause harm to infants and young children.
17. Lead	ppm	2018	0.1	0	ppm	0	0	Exposure to lead in drinking water can cause harm to infants and young children.

Volatile Organic Compounds

Contaminant	Analysis Unit	Date Collected	Last Detected	Range of Values in 2018	Unit	MCL	MCLG	Health Effects of Contaminant
18. MTHCA	ppm	2018	0.00000	0.00000 - 0.00000	ppm	0	0	Exposure to MTHCA in drinking water can cause harm to infants and young children.
Disinfection By-Products								
19. THM (Total Trihalomethanes)	ppm	2018	1.1	0.1 - 1.1	ppm	0	0	Exposure to THM in drinking water can cause harm to infants and young children.

PWS ID # 070017 TEST RESULTS

Contaminant	Analysis Unit	Date Collected	Last Detected	Range of Values in 2018	Unit	MCL	MCLG	Health Effects of Contaminant
Inorganic Contaminants								
4. Arsenic	ppm	2018	0.1	0 - 0.1	ppm	0.05	0.01	Exposure to arsenic in drinking water can increase the risk of cancer and heart disease.
10. Boron	ppm	2018	16.18	0.00 - 16.18	ppm	0	0	Exposure to boron in drinking water can cause harm to infants and young children.
13. Chloride	ppm	2018	1.1	0 - 1.1	ppm	100	100	Exposure to chloride in drinking water can cause harm to infants and young children.
14. Copper	ppm	2018	0.1	0 - 0.1	ppm	1.3	0.1	Exposure to copper in drinking water can cause harm to infants and young children.
16. Fluoride	ppm	2018	0.18	0.00 - 0.18	ppm	0	0	Exposure to fluoride in drinking water can cause harm to infants and young children.
17. Lead	ppm	2018	0.1	0	ppm	0	0	Exposure to lead in drinking water can cause harm to infants and young children.
21. Sulfate	ppm	2018	0.1	0 - 0.1	ppm	0	0	Exposure to sulfate in drinking water can cause harm to infants and young children.
Disinfection By-Products								
19. THM (Total Trihalomethanes)	ppm	2018	1.1	0.1 - 1.1	ppm	0	0	Exposure to THM in drinking water can cause harm to infants and young children.

RETURN THIS STUB WITH PAYMENT TO:
MT. COMFORT WATER ASSN.

P.O. BOX 595
 BRUCE, MS 38915

PHONE:
 662-983-7420

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PERMIT NO. 5
 BRUCE, MS

ACCOUNT NO.	SERVICE FROM	SERVICE TO
020001500	03/25	04/25

SERVICE ADDRESS
 381 HWY 9 W

CURRENT	METER READINGS PREVIOUS	USED
824500	819800	4700

CHARGE FOR SERVICES	
PAY NET AMOUNT ON OR BEFORE DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
NET AMOUNT	GROSS AMOUNT
31.83	35.01

NET AMOUNT	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
31.83	05/25/2019	35.01
	SAVE THIS	
	3.18	

CCR AVAILABLE @ ASSOCIATION
 OFFICE!

WTR 31.83
 NET DUE >>> 31.83
 SAVE THIS >> 3.18
 GROSS DUE >> 35.01

RETURN SERVICE REQUESTED

020001500
 BEN PRATT
 381 HWY 9 W
 BRUCE, MS 38915