

2019 MAY 14 PM 3: 24

2018 CERTIFICATION

Consumer Confidence Report (CCR)

Mt. Comfort Water Association

Public Water System Name

0070610 0070011 0070017 0070020

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)
- Advertisement in local paper (*Attach copy of advertisement*)
 - On water bills (*Attach copy of bill*)
 - Email message (*Email the message to the address below*)
 - Other _____

Date(s) customers were informed: 5 / 8 /2019 5 / 10 /2019 5 / 25 /2019

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

- CCR was distributed by Email (*Email MSDH a copy*) Date Emailed: / /2019
- As a URL _____ (*Provide Direct URL*)
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: The Calhoun County JournalDate Published: 5 / 8 /2019

- CCR was posted in public places. (*Attach list of locations*) Date Posted: / /2019

- CCR was posted on a publicly accessible internet site at the following address:

_____ (*Provide Direct URL*)**CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

[Signature], MANAGER
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5 / 10 / 19
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2019!

RECEIVED WATER SUPPLY
2019 MAY -7 PM 1:05

2018 Annual Drinking Water Quality Report
Mt. Comfort Water Association
PWS#: 070010, 070011, 070017 & 070020
May 2019

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Chris Shelton at 662.983.8024. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 7:00 PM at the Mt. Comfort Water Association office located at 209 Center Street, Bruce, MS.

Our water source is from wells drawing from the Gordo Formation & Eutaw Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Mt. Comfort Water Association have received lower to moderate susceptibility rankings to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID # 070010		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
6. Radium 226 Radium 228	N	2016*	.6 <.4	No Range	pCi/L	0	5	Erosion of natural deposits
Inorganic Contaminants								
8. Arsenic	N	2018	3.9	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2018	.1678	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	2.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018	.403	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

16. Fluoride	N	2018	.14	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2018	4.7	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2017*	2.37	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	.4	.1 – .54	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID # 070011

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	--------------------	------	-----	--------------------------------

Inorganic Contaminants

8. Arsenic	N	2017*	2.1	2 – 2.1	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2017*	.1508	.1507 - .1508	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2017*	1.1	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2017*	.16	.156 - .16	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Volatile Organic Contaminants

76. Xylenes	N	2018	.000596	.000564 - .00596	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories
-------------	---	------	---------	------------------	-----	----	----	---

Disinfection By-Products

Chlorine	N	2018	1	.63 – 1.31	mg/l	0	MDRL = 4	Water additive used to control microbes
----------	---	------	---	------------	------	---	----------	---

PWS ID # 070017

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	--------------------	------	-----	--------------------------------

Inorganic Contaminants

8. Arsenic	N	2018	5.1	4.6 – 5.1	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2018	.3549	.3298 - .3549	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2018	2.7	2.5 – 2.7	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018	.142	.139 - .142	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2018	5.8	5 – 5.8	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

81. HAA5	N	2017*	1	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2017*	3.46	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	.6	.11 – 1.63	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID # 070020

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	--	-------------------	------	-----	--------------------------------

Radioactive Contaminants

6. Radium 226 Radium 228	N	2016*	1.6 1	.7 – 1.6 No Range	pCi/L	0	5	Erosion of natural deposits
-----------------------------	---	-------	----------	----------------------	-------	---	---	-----------------------------

Inorganic Contaminants

8. Arsenic	N	2018	2.7	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2018	.1514	.1505 - .1514	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	2.9	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018	.175	.165 - .175	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2017*	1	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2017*	4.64	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	.4	.22 – .83	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2018.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality

drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Mt. Comfort Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Proof Of Publication

STATE OF MISSISSIPPI,
COUNTY OF CALHOUN

Personally came before me, the undersigned, a Notary Public, in and for Calhoun County, Mississippi, Joel McNece, Publisher of The Calhoun County Journal, a newspaper published in Bruce, Calhoun County, in said state, who being duly sworn, deposes and says that The Calhoun County Journal is a newspaper as defined and prescribed in Senate Bill No. 203 enacted at the regular session of the Mississippi Legislature of 1948, amending Section 1858 of the Mississippi Code of 1942, and the publication of a notice, of which annexed copy, in the matter of

MT. COMFORT WATER ASSOCIATION WATER QUALITY REPORT


has been made in said newspaper one time, to-wit:

On the 8 day of MAY 2019



Joel McNece
Publisher


Sworn to and subscribed before me, this 8 day of May



Celia D. Hillhouse,
Notary Public

My commission expires February 18, 2023

SEAL



We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We ask you to understand the risks we take to continuously improve our water treatment processes and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about the report or obtaining your water quality report, please contact Greg Buehler at 602-603-5004. We will also accept comments to be included in our next report. If you prefer, you may contact the report by e-mail. The report is available on our website at 602-603-5004.

The water quality is being tested with the Quality Protection & Public Protection. The water quality report has been obtained for all public water supply to determine the public responsibility of an annual water quality report. A public water quality report is a document that provides information on how the water quality is being tested and the results. It is a public water quality report and is available for viewing upon request. The report is for the Mt. Comfort Water Association which serves the following communities: Brainerd, Brainerd Springs, and Brainerd Springs.

We regularly monitor for contaminants in your public water according to Federal and State laws. The 2018 report lists all of the drinking water contaminants that were analyzed during the period of January 1st to December 31st, 2018. It lists where the drinking water was sampled in 2018, the date and time the report was made. As water flows from the source of water to the tap of the consumer, it can become contaminated. It can also contain substances that can pose a health risk. Our water quality report includes information on the monitoring of drinking water quality, such as: drinking water quality, water supply, water treatment processes, water treatment, water distribution, and water distribution. The report also includes information on the monitoring of drinking water quality, such as: drinking water quality, water supply, water treatment processes, water treatment, water distribution, and water distribution.

In this table you will find many facts and information you may not be familiar with. To help you better understand these items, we've provided the following definitions:

Action Level: the combination of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL): The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set to protect the public health based on the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The "MCLG" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs do not reflect the benefits of the use of treatment to reduce natural contaminants.

Parts per billion (ppb) or micrograms per liter (µg/L): One part per billion (ppb) is one millionth of one percent or one billionth of one percent.

Parts per million (ppm) or milligrams per liter (mg/L): One part per million (ppm) is one millionth of one percent or one millionth of one percent.

PWS ID # 070010 TEST RESULTS

Contaminant	Unit	Sample Date	Test Date	Range of Results or MCL	Unit	MCL	MCLG	Notes
Radioactive Contaminants								
Radon (Radium 226 and Radium 230)	picCi/L	2018	2/1	No Range	picCi/L	5	5	Excess of radon increases the risk of certain cancers.
Inorganic Contaminants								
Asbestos	ML	2018	2/5	No Range	ML	7.0	7.0	Excess of asbestos increases the risk of cancer and lung disease.
Barium	ML	2018	1/18	No Range	ML	4	4	Excess of barium can affect the heart and blood vessels.
Bromine	ML	2018	2/4	No Range	ML	100	100	Excess of bromine can affect the nervous system.
Chlorine	ML	2018	1/2	No Range	ML	4.0	4.0	Excess of chlorine can affect the nervous system and cause skin irritation.
Copper	ML	2018	1/2	No Range	ML	1.3	1.3	Excess of copper can cause digestive problems and damage to the heart.

PWS ID # 070011 TEST RESULTS

Contaminant	Unit	Sample Date	Test Date	Range of Results or MCL	Unit	MCL	MCLG	Notes
Inorganic Contaminants								
Asbestos	ML	2018	2/1	1.0 - 2.1	ML	7.0	7.0	Excess of asbestos increases the risk of cancer and lung disease.
Barium	ML	2018	1/18	1.27 - 1.58	ML	4	4	Excess of barium can affect the heart and blood vessels.
Bromine	ML	2018	2/4	No Range	ML	100	100	Excess of bromine can affect the nervous system.
Chlorine	ML	2018	1/2	2	ML	4.0	4.0	Excess of chlorine can affect the nervous system and cause skin irritation.
Copper	ML	2018	1/2	1.5 - 1.8	ML	1.3	1.3	Excess of copper can cause digestive problems and damage to the heart.
Ferric	ML	2018	1/2	0	ML	4.0	4.0	Excess of ferric iron can cause digestive problems and damage to the heart.
Lead	ML	2018	1/2	0	ML	0.01	0.01	Excess of lead can cause developmental problems and damage to the heart.

PWS ID # 070012 TEST RESULTS

Contaminant	Unit	Sample Date	Test Date	Range of Results or MCL	Unit	MCL	MCLG	Notes
Inorganic Contaminants								
Asbestos	ML	2018	2/1	1.8 - 2.1	ML	7.0	7.0	Excess of asbestos increases the risk of cancer and lung disease.
Barium	ML	2018	1/18	1.35 - 1.45	ML	4	4	Excess of barium can affect the heart and blood vessels.
Bromine	ML	2018	2/4	No Range	ML	100	100	Excess of bromine can affect the nervous system.
Chlorine	ML	2018	1/2	1	ML	4.0	4.0	Excess of chlorine can affect the nervous system and cause skin irritation.
Copper	ML	2018	1/2	1.4 - 1.5	ML	1.3	1.3	Excess of copper can cause digestive problems and damage to the heart.
Ferric	ML	2018	1/2	0	ML	4.0	4.0	Excess of ferric iron can cause digestive problems and damage to the heart.
Lead	ML	2018	1/2	0	ML	0.01	0.01	Excess of lead can cause developmental problems and damage to the heart.

PWS ID # 070013 TEST RESULTS

Contaminant	Unit	Sample Date	Test Date	Range of Results or MCL	Unit	MCL	MCLG	Notes
Inorganic Contaminants								
Asbestos	ML	2018	2/1	1.8 - 2.1	ML	7.0	7.0	Excess of asbestos increases the risk of cancer and lung disease.
Barium	ML	2018	1/18	1.35 - 1.45	ML	4	4	Excess of barium can affect the heart and blood vessels.
Bromine	ML	2018	2/4	No Range	ML	100	100	Excess of bromine can affect the nervous system.
Chlorine	ML	2018	1/2	1	ML	4.0	4.0	Excess of chlorine can affect the nervous system and cause skin irritation.
Copper	ML	2018	1/2	1.4 - 1.5	ML	1.3	1.3	Excess of copper can cause digestive problems and damage to the heart.
Ferric	ML	2018	1/2	0	ML	4.0	4.0	Excess of ferric iron can cause digestive problems and damage to the heart.
Lead	ML	2018	1/2	0	ML	0.01	0.01	Excess of lead can cause developmental problems and damage to the heart.

PWS ID # 070014 TEST RESULTS

Contaminant	Unit	Sample Date	Test Date	Range of Results or MCL	Unit	MCL	MCLG	Notes
Inorganic Contaminants								
Asbestos	ML	2018	2/1	1.8 - 2.1	ML	7.0	7.0	Excess of asbestos increases the risk of cancer and lung disease.
Barium	ML	2018	1/18	1.35 - 1.45	ML	4	4	Excess of barium can affect the heart and blood vessels.
Bromine	ML	2018	2/4	No Range	ML	100	100	Excess of bromine can affect the nervous system.
Chlorine	ML	2018	1/2	1	ML	4.0	4.0	Excess of chlorine can affect the nervous system and cause skin irritation.
Copper	ML	2018	1/2	1.4 - 1.5	ML	1.3	1.3	Excess of copper can cause digestive problems and damage to the heart.
Ferric	ML	2018	1/2	0	ML	4.0	4.0	Excess of ferric iron can cause digestive problems and damage to the heart.
Lead	ML	2018	1/2	0	ML	0.01	0.01	Excess of lead can cause developmental problems and damage to the heart.

PWS ID # 070015 TEST RESULTS

Contaminant	Unit	Sample Date	Test Date	Range of Results or MCL	Unit	MCL	MCLG	Notes
Inorganic Contaminants								
Asbestos	ML	2018	2/1	1.8 - 2.1	ML	7.0	7.0	Excess of asbestos increases the risk of cancer and lung disease.
Barium	ML	2018	1/18	1.35 - 1.45	ML	4	4	Excess of barium can affect the heart and blood vessels.
Bromine	ML	2018	2/4	No Range	ML	100	100	Excess of bromine can affect the nervous system.
Chlorine	ML	2018	1/2	1	ML	4.0	4.0	Excess of chlorine can affect the nervous system and cause skin irritation.
Copper	ML	2018	1/2	1.4 - 1.5	ML	1.3	1.3	Excess of copper can cause digestive problems and damage to the heart.
Ferric	ML	2018	1/2	0	ML	4.0	4.0	Excess of ferric iron can cause digestive problems and damage to the heart.
Lead	ML	2018	1/2	0	ML	0.01	0.01	Excess of lead can cause developmental problems and damage to the heart.

RETURN THIS STUB WITH PAYMENT TO:

MT. COMFORT WATER ASSN.

P.O. BOX 595
BRUCE, MS 38915

PHONE:
662-983-7420

PRESORTED
FIRST-CLASS MAIL
U.S. POSTAGE
PAID
PERMIT NO. 5
BRUCE, MS

ACCOUNT NO.	SERVICE FROM	SERVICE TO
020001500	03/25	04/25

SERVICE ADDRESS
381 HWY 9 W

CURRENT	METER READINGS PREVIOUS	USED
824500	819800	4700

CHARGE FOR SERVICES

PAY NET AMOUNT ON OR BEFORE DUE DATE	NET AMOUNT	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
31.83	31.83	05/25/2019	35.01

CCR AVAILABLE @ ASSOCIATION OFFICE!

WTR 31.83
NET DUE >>> 31.83
SAVE THIS >> 3.18
GROSS DUE >> 35.01

RETURN SERVICE REQUESTED

020001500
BEN PRATT

381 HWY 9 W
BRUCE, MS 38915