

2019 MAY -6 AM 10:48

2018 CERTIFICATION

Consumer Confidence Report (CCR)

Yalobusha Water & Sewer Dist Inc

Public Water System Name

0810028 + 0810029

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: (*Attach copy of publication, water bill or other*)

- Advertisement in local paper (*Attach copy of advertisement*)
- On water bills (*Attach copy of bill*)
- Email message (*Email the message to the address below*)
- Other _____

Date(s) customers were informed: ____ / ____ / 2019 ____ / ____ / 2019 ____ / ____ / 2019

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ____ / ____ / ____

- CCR was distributed by Email (*Email MSDH a copy*) Date Emailed: ____ / ____ / 2019
- As a URL _____ (*Provide Direct URL*)
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. (*Attach copy of published CCR or proof of publication*)

Name of Newspaper: North Ms Herald

Date Published: 04 / 25 / 19

CCR was posted in public places. (*Attach list of locations*) Date Posted: ____ / ____ / 2019

CCR was posted on a publicly accessible internet site at the following address:

(Provide Direct URL)**CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Larry Gray

Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

05 / 01 / 2019

Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov**Fax:** (601) 576 - 7800****Not a preferred method due to poor clarity******CCR Deadline to MSDH & Customers by July 1, 2019!**

2018 Annual Drinking Water Quality Report
 Yalobusha Water & Sewer District
 PWS ID#: 0810028 & 0810029
 April 2019

RECEIVED-WATER SUPPLY
 2019 APR -8 AM 9:33

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Joel Rogers at 662.473.3137. We want our valued customers to be informed about their water utility. If you want to learn more, please attend the meeting scheduled for the second Tuesday of each quarter at 7:00 PM at the Pine Valley Warehouse.

Our water source is from wells drawing from the Lower and Middle Wilcox Aquifers. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Yalobusha Water & Sewer District have received moderate susceptibility rankings to contamination.

The Yalobusha Water & Sewer District routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

PWS ID #: 0810028		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2016*	.0099	.0097 - .0099	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2016*	1.9	1.2 - 1.9	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2016*	14	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	18.4	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	1.1	1 - 1#	mg/l	0	MDRL = 4	Water additive used to control microbes

PWS ID #: 0810029**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2016*	.0159	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2016*	1.9	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2016*	4	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	7.5	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	1.1	.8 – 1.4	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2018.

As you can see by the table, our system had no. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Significant Deficiencies

Monitoring and Reporting of Compliance Data Violations:

During a sanitary survey conducted on 09/22/2017, the Mississippi State Department of Health cited the following significant deficiency(s): Inadequate Internal Cleaning/Maintenance of Storage Tanks

Corrective Actions: This system is under a Bilateral Compliance Agreement with the MSDH to complete corrective actions by 09/30/2019.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Yalobusha Water & Sewer District works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**PROOF OF PUBLICATION
OF NOTICE**

**State of Mississippi
Yalobusha County**

Before me, BETTY K. SHEARER, Notary Public of said County, this day came David Howell, who stated on oath that he is the Editor and Publisher of the North Mississippi Herald, a public newspaper publishing and having a general circulation in the City of Water Valley, said County and State, and made oath further that advertisement, of which a copy as printed is annexed, was published in said newspaper for 1 consecutive weeks in its issues numbered and dated as follows, to-wit:

- Vol. 131 No. 5 Dated the 25 of April 2019
- Vol. ___ No. ___ Dated the ___ of ___ 20__
- Vol. ___ No. ___ Dated the ___ of ___ 20__
- Vol. ___ No. ___ Dated the ___ of ___ 20__
- Vol. ___ No. ___ Dated the ___ of ___ 20__

Affiant further states that he has examined the foregoing 1 issues of said newspaper, that the attached Notice appeared in each of said 1 as aforesaid of said newspaper.

David Howell

Editor and Publisher
North Mississippi Herald

Sworn to and subscribed before me, this 25 day of April 2019
Water Valley, Yalobusha County, Mississippi

Betty Shearer

NOTARY PUBLIC
STATE OF MISSISSIPPI
ID # 18982
BETTY K. SHEARER
Commission Expires July 26, 2019
YALOBUSHA COUNTY

Words _____ Times _____
Proof of Publication _____
Total Due _____

2019 MAY -6 AMID: 48

ED-WATER SUPPLY 2018 Annual Drink Yalobusha W PWS ID# 0810028

We're pleased to present to you this year's Annual Quality Water services we deliver to you every day. Our constant goal is to provide understand the efforts we make to continually improve the water ensuring the quality of your water.

If you have any questions about this report or concerning your water customers to be informed about their water utility. If you want to it each quarter at 7:00 PM at the Pine Valley Warehouse.

Our water source is from wells drawing from the Lower and Middle public water system to determine the overall susceptibility of its containing detailed information on how the susceptibility determin available for viewing upon request. The wells for the Yalobusha contamination.

The Yalobusha Water & Sewer District routinely monitors for con table shows the results of our monitoring for the period of Januar 2018, the table reflects the most recent results. As water travels on as microbes, inorganic and organic chemicals, and radioactive; reasonably expected to contain at least small amounts of som contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you mi provided the following definitions:

Action Level - the concentration of a contaminant which, if exce follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (M MCLs are set as close to the MCLGs as feasible using the best ava

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of health. MRDLGs do not reflect the benefits of the use of disinfectants

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per

Parts per billion (ppb) or Micrograms per liter - one part per billion

PWS ID #: 0810028		TEST RE		
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Det or # of Sam Exceeding MCL/AC
Inorganic Contaminants				
10. Barium	N	2018*	.0099	.0097 - .0099
13. Chromium	N	2018*	1.9	1.2 - 1.9

... will be assessed
... without the statement.
... will be paid in person.
... a closed account will
... charged for checks re-
... \$25.00 to \$35.00.
... until 8:00 pm
... or disconnection
... for customer request-

istrict competition at Northwest District Show atatesville. Gilley was hi oring individual.

Students of Hope Ch an Academy in Water V y who were winners he Accelerated Christi ducation Competiti ere Jerry Moffett, Bec otts, Dee Greer, Beve eel, Alex Dorris, Greg r, Donnie Schmitz, St ng Schmitz, Chris Pot nd Kevin Stewart.

A retirement party w eld for Harry Fair, lor me owner of Valley A arts.

Mrs Maye Donaldson akland was honored e Mississippi Reput an Women's Organizati uring their 50th anniv ary meeting.

A special award w presented to district co ervationist Jerry Griffin. offevelle, district cons ationist, at the SCS Awar anquet in Jackson.

40 Years—April 26, 19 Mayor Garlon Mayn as pictured as he crown nriifer Jones, daughter. r. and Mrs. Baxter Jon miss Teen Age Poke S; et at the Pageant. Oth winners were: Tracy-Hur miss Poke Sallet; Lee A Vaughn, Tiny Miss; An Valley, Junior Miss; ar Margaret Hill, Little Miss Missy Davis, daught of Mr. and Mrs. Joe Dav

PUI
The City of W be changing so changes are as **RECONNEC** trical service a to pay will incr



YALOBUSHA WATER ASSOCIATION
 P.O. BOX 170
 WATER VALLEY, MISSISSIPPI 38965
 (662) 473-3137



RETURN SERVICE REQUESTED

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 WATER VALLEY, MS
 PERMIT NO. 10

TYPE OF SERVICE	METER READINGS		USED	CHARGES
	PRESENT	PREVIOUS		
Water	443700	441000	2,700	25.00

4936 CR 2019

RECEIVED WATER VALLEY
 2019 MAY -6 AM 10:48

CUSTOMER		PAY GROSS AMOUNT	
ROUTE	ACCOUNT	AFTER THIS DATE	
3	279	5/10/19	
NET AMOUNT TO BE PAID		GROSS AMOUNT TO BE PAID	
25.00		28.75	

MAIL THIS STUB WITH YOUR PAYMENT

Service From 3/12/2019 TO 4/12/2019 ACCOUNT # 279 4/25/19

METER READ MONTH	CLASS DAY	TOTAL DUE UPON RECEIPT	LATE CHARGE AFTER DUE DATE	PAST DUE AMOUNT
4	12 1	25.00	3.75	28.75

Consumer Confidence Report available upon request

Also in North Miss Herald April 24th edition



38922-9776

