

2019 MAY 20 AM 9:08

2018 CERTIFICATION**Consumer Confidence Report (CCR)**South East Greene Water Authority

Public Water System Name

210012

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper *(Attach copy of advertisement)*
- On water bills *(Attach copy of bill)*
- Email message *(Email the message to the address below)*
- Other SEGW office.

Date(s) customers were informed: / / 2019 / / / 2019 / / / 2019

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: / / 2019
- As a URL _____ *(Provide Direct URL)*
- As an attachment
- As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Greene County HeraldDate Published: 4 / 25 / 2019

- CCR was posted in public places. *(Attach list of locations)* In office Date Posted: 4 / 25 / 2019

- CCR was posted on a publicly accessible internet site at the following address:

_____ *(Provide Direct URL)***CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Jeff McNeil office manager
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5-16-19
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2019!

2019 APR -9 AM 11:16

2018 Annual Drinking Water Quality Report
 Southeast Greene Water Authority
 PWS#: 0210012
 April 2019

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Judy McLeod at 601-947-9044. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of each month at 5:30 PM at the Southeast Greene Water Authority office.

Our water source is from two wells drawing from the Miocene Series and Catahoula Formation Aquifer. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Southeast Greene Water Authority have received moderate susceptibility rankings to contamination.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination

Inorganic Contaminants								
10. Barium	N	2018	.0083	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
17. Lead	N	2015/17*	7	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2018	.19	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection By-Products								
82. TTHM [Total trihalomethanes]	N	2018	2.	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	1.9	1.6 – 2.4	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2018.

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Southeast Greene Water Authority works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.


PROOF OF PUBLICATION

STATE OF MISSISSIPPI
COUNTY OF GREENE

Personally appeared before me, the authority, in and for the State and County aforesaid, GEORGE R. TURNER, who being duly sworn, on his oath deposes and states that he is the Editor/Publisher of the Greene County Herald, a newspaper having a general circulation in Greene County, Mississippi.

Volume 121 No. 1 Dated 25th Day of April, 2019
Volume _____ No. _____ Dated _____ Day of _____, 2019
Volume _____ No. _____ Dated _____ Day of _____, 2019
Volume _____ No. _____ Dated _____ Day of _____, 2019

And I hereby certify that the several numbers of the newspapers containing the notice hereto attached, have been before me exhibited and examined, and I find publication thereof to have been correctly made as stated.



GEORGE R. TURNER,
Editor/Publisher

Sworn to and subscribed before me, this 25th day of April, A.D., 2019.





Joni McMillon

Notary Public

My Commission Expires : November 9, 2019

▶ Events

Continued from Page 3

Food vendors will be on site and LifeSouth Blood Mobile will be on site collecting blood and platelets. Check out the FB page @blacktoppossemc for more information.

GCHS Parent-Student Social

The GCHS Class of 2020 Student and Parent Social and Info meeting is set for Monday, May 13, at 6 p.m. in the GCHS cafeteria.

Karaoke Contest

Neely Rusty Riders will host a Karaoke Contest April 26 at 7 p.m. at the Old Neely Factory, located at 6400 Old Hwy 24 in Neely. The entry fee is \$10 per contestant. For more information call Ray Dixon at (601)394-9779 or Dana Dixon at (601)525-3707. All proceeds will benefit the Neely Volunteer Fire Department's First Responders.

Trail Ride & Dance

Neely Rusty Riders will host a Trail Ride April 27 beginning at 8 a.m. at the Old Neely Factor Building located at 6400 Old Hwy 24 in Neely. Riders are welcome to come in on Friday and camp out. The

will be on another Dance and

from the county courthouse. For more information or to be a part of the event, contact Rebekah Stowers at (601)770-2394.

Stone County Senior Citizens Expo

The 2019 Stone County Senior Citizens Expo will be held Saturday, May 11, from 9 a.m.-2 p.m., at the Stone County Fairgrounds Exhibit Building, 711 Airport Road, Wiggins. There will be demonstrations, entertainment, candle stumping, door prizes and a chance to win \$500 cash. Mark your calendars and follow the event on Facebook for details. For vendor applications or more information call (601)928-4802, or email publisher@stonecountyenterprize.com.

LJHS Athletic Booster Club fundraiser

The LJHS Athletic Booster Club is hosting a fundraiser Saturday, May 11, at the LJHS football field with a carwash and BBQ plates. BBQ plates will be on sale for pre-order or

order the day of the event. All pre-orders are \$8 and can be purchased through any LJHS athletic club member or coach. All pre-orders must be received by Friday, May 3. Plates on the day of the event will be \$9. The carwash is for a donation, and the plates will be ready for pickup at 10 a.m.

CDL Class

The Jones College - Greene County Center will be offering a CDL Class starting Saturday, May 4 from 8 a.m. - 4 p.m. For more details call (601)394-4421 or (601)477-4238.

Ingalls Shipbuilding Hiring Fair

Do you have what it takes to build freedom, one great ship at a time? No experience? No problem! Learn how you can sharpen your skills to join the Ingalls Shipbuilding team on Saturday, May 4, 2019, from 8 - 11 a.m., at the Jones County Junior College Advanced Technology Center, 72 Technology Blvd, Ellisville, MS 39437. Job offers will be made on-the-spot to qualified candidates. Email

questions to Ingalls.TA@hi-ingalls.com. Candidates from the Stonewall and Leakesville areas are encouraged to attend and learn

about opportunities for skills advancement in your local area.

Jones College Kids Softball Camp

Jones College will host a Kids Softball Camp May 28-29, at Community Bank Park on

campus. The children ages 6-11 from 9 a.m.-11 a.m. The cost is \$60. Contact Jones Robinson at chris.robinson@

Political Announcements

The Greene County Herald has been authorized to announce the following candidates for political office in the 2019 election cycle.

CHANCERY CLERK Michelle D. 'Shelley' Eubanks (D - Leakesville)	TAX ASSESSOR / COLLECTOR Mark Holder (D - Pleasant Hill)	CONSTABLE POST ONE Ryan Walley (D - Sand Hill)
CIRCUIT CLERK Cecelia Bounds (D - Avera)	STATE SENATOR DISTRICT 43 Dennis DeBar, Jr. (R - Leakesville)	SUPERVISOR DIST. ONE James Radcliff (R - Leakesville)
COUNTY CORONER Ladd Pulliam (R - Leakesville)	JUSTICE COURT JUDGE POST 1 Jeff Byrd (D - Bothwell)	SUPERVISOR DIST. THREE Wayburn D. 'Danny' Smith, Jr. (R - Pivate)
SHERIFF Stanley McLeod (D - Leakesville)	JUSTICE COURT JUDGE POST 2 Ryan Longmire (D - Neely)	SUPERVISOR DIST. ONE Scott Maxie (R - Sand Hill)
SHERIFF Larry Byrd (R - Neely)	JUSTICE COURT JUDGE POST 1 Terri Green (R - Winborn Chapel)	SUPERVISOR DIST. ONE Efrid Eubanks (D - Sand Hill)
	JUSTICE COURT JUDGE POST 1 Shannon Busby (D - Mt. Pisgah)	

