

2019 MAY 21 AM 11:56

**2018 CERTIFICATION****Consumer Confidence Report (CCR)**Naval Air Station Meridian, MS

Public Water System Name

0380026

List PWSID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH. Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
- Advertisement in local paper *(Attach copy of advertisement)*
  - On water bills *(Attach copy of bill)*
  - Email message *(Email the message to the address below)*
  - Other \_\_\_\_\_

Date(s) customers were informed: 5/20/2019 / / 2019 / / 2019

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed:  / /

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed:  / / 2019
- As a URL \_\_\_\_\_ *(Provide Direct URL)*
  - As an attachment
  - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: \_\_\_\_\_

Date Published:  / /

- CCR was posted in public places. *(Attach list of locations)* Date Posted: 5/ / 2019

- CCR was posted on a publicly accessible internet site at the following address: \_\_\_\_\_

*(Provide Direct URL)***CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

James B. Colonna *Water operator*  
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5-20-19

Date

**Submission options (Select one method ONLY)**

Mail: (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

Email: [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

Fax: (601) 576-7800

\*\*Not a preferred method due to poor clarity\*\*

**CCR Deadline to MSDH & Customers by July 1, 2019!**

**Annual Drinking Water Quality Report**  
 Naval Air Station Meridian, Ms.  
 MSDH PWS ID # 0380026

May 20, 2019

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from the Wilcox Aquifer.

Our source water assessment has been conducted and is available at this time, and copies of this assessment are available at our office. If you have any questions about this report or concerning your water quality, please contact Bo Coleman or David Chisolm 0600-1530 Monday thru Friday at (601) 679-2151. We want our valued customers to be informed about their water quality. If you want to learn more, please call to schedule a meeting at the NAS Meridian Water Plant.

Mississippi State Department of Health and the Certified Operators of NAS Meridian routinely monitor for 86 constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1, 2018 to December 31, 2018. This table only lists monitored constituents with reportable detectable levels. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Non-Detects (ND)* – laboratory analysis indicates that the constituent is not present.

*Parts per million (ppm) or Milligrams per liter (mg/l)* – one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Picocuries per liter (pCi/L)* – picocuries per liter is a measure of the radioactivity in water.

*Millirems per year (mrem/yr)* – measure of radiation absorbed by the body.

*Action Level (AL)* – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Treatment Technique (TT)* – a treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

*Maximum Contaminant Level (MCL)* – the “Maximum Allowed” is the highest level of a contaminant that is allowed in drinking water.

*Maximum Contaminant Level Goal (MCLG)* – the “Goal” is the level of a contaminant in drinking water below which there is no known expected risk to health. MCLG's allow for a margin of safety.

TEST RESULTS									
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/AL	Unit Measurement	MCLG	MCL	Likely Source of Contamination	
<b>Disinfectant By-product</b>									
			AVERAGE LOW HIGH						
Chlorine	N	1/ 1/18 - 12/31/18	1.90	1.1	2.20	ppm	NONE	4.0	Water additive used to control microbes
Haloacetic Acids (HAA5)(ppb)	N/A	8/27/2018	24.0	N/A	N/A	ppb	0	60	By-product of drinking water disinfection
TTHM,s Total Trihalomethanes (ppb)	N/A	7/09/2015	34.2	N/A	N/A	ppb	0	80	By-product of drinking water disinfection
<b>Microbiological Contaminants</b>									
Total Coliform Bacteria	N	5/1/2018	0	0	ml	0	Presence of coliform bacteria in 5% of monthly samples	Naturally present in the environment	
<b>Inorganic Contaminants</b>									
Barium	N	4/28/15	0.0357	0	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	
Copper	N	1/1/2016-12/31/2018	0.1	0	mg/l	N/A	AL=1.3 mg/l	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	
Xylenes	N	10/9/2018	49.138	0	ppb	N/A	1000	Volatile Organic Compound	
Ethylbenzene	N	10/9/2018	7.206	0	ppb	N/A	700	Volatile Organic Compound	
Lead	N	1/1/2016-12/31/2018	0.001	0	mg/l	0	AL=.015 mg/l	Corrosion of household plumbing systems; erosion of natural deposits	

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Naval Air Station Meridian Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water,

you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601-576-7582 if you wish to have your water tested.


All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.

Please contact us at the following numbers if you have questions: Deputy Public Works Officer (601) 679-2940 or Maintenance Supervisor, (601) 679-2530. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

#### Fluoridation Results

To comply with the "Regulation Governing Fluoridation of community Water Supplies", MS0380026 is required to report certain results pertaining to fluoridation of our water system. The number of months in previous calendar year in which average fluoride sample results were within the optimal range of 0.6 – 1.2 ppm was 12. The percentage of fluoride samples collected in the previous calendar that was within the optimal range of 0.6-1.2 was 100%.

Sincerely,



Jason Britt Cooper  
Deputy Public Works Officer  
Water Plant Owner of Record

## Champion, Terleter

---

**From:** Randall, Penny L CIV USN NAS MERIDIAN MS (USA) <penny.randall@navy.mil>  
**Sent:** Tuesday, May 21, 2019 10:32 AM  
**To:** CNI SE MRDN NAS and All Tenants  
**Cc:** Alphin, Julie CIV USN BRHLTHCLIN MER MS (US; Baker, Victory O CIV (US; Barboza, Lizet PO1 USN BRHLTHCLIN MER MS (US; aaron.berryman.mil@mail.mil; Brooks, Tykia M HN USN BRHLTHCLIN MER MS (US; Browning, Danny R Jr PO2 USN BRHLTHCLIN MER MS (US; Browning, Jana R PO2 USN BRHLTHCLIN MER MS (US; gage.s.carlozzi.mil@mail.mil; johnny.l.cosby.mil@mail.mil; Daniels, Victoria I CIV (US; Daugherty, Mary C CIV CPMS (US; Davis, Latashia A CTR (US; Dorsett, Evelyn M CTR (US; Ehler, Dylan H SA USN (US; Elliott, Austin D HN USN (US; Floyd, Milli CIV USN BRHLTHCLIN MER MS (US; Fournier, Donald C CIV USN BRHLTHCLIN MER MS (US; Goings, Christopher T SN USN (USA; Hankinson, Daniel M PO3 USN BRHLTHCLIN MER MS (US; Hines, Travae L HN USN (US; Adyson.m.hissong.mil@mail.mil; benny.a.husinecky.mil@mail.mil; Jackson, Lakeita L CIV (US; Vantashia.c.jennings.mil@mail.mil; Jia, Lingjiang PO3 USN BRHLTHCLIN MER MS (US; Jimenez, Luis A PO2 USN BRHLTHCLIN MER MS (US; Julien, Kristie M HN USN (US; Kitz, Robert J LT CTW-1 Flight Surgeon; Jason.le.mil@mail.mil; Maier, Holden M SA USN (USA; McDonald, Angela S CIV USN BRHLTHCLIN MER MS (US; quenton.j.morgan.mil@mail.mil; Morris, Courtland J PO2 USN BRHLTHCLIN MER MS (US; Mullen, Jeremy W PO1 USN BRHLTHCLIN MER MS (US; Mullen, Matthew J HN USN (US; jessika.a.myers.mil@mail.mil; dakota.m.neel.mil@mail.mil; Nicholas, Amy N CTR USN BRHLTHCLIN MER MS (US; Nutter, Gregory C CIV (US; Olson, Nichole ; elia.v.ortiz.mil@mail.mil; Padgett, Kenneth ; Kairra.t.phimmasone.mil@mail.mil; Pickett, Hannah J PO2 USN BRHLTHCLIN MER MS (US; Pickett, Shannon M CIV USN BRHLTHCLIN MER MS (US; Samuel.e.pope.mil@mail.mil; Racs, Michael J LCDR USN NAVHOSP JAX FL (US; Ramos, Carlos E SN USN BRHLTHCLIN MER MS (USA; Kenny.a.ransbottom.civ@mail.mil; Sayaman, Edison R CPO USN BRHLTHCLIN MER MS (US; Seals, Zachary O PO3 USN (US; Sharp, Jayde E CIV USN BRHLTHCLIN MER MS (US; Sisemore, Bishop C PO3 USN (US; Snowden, Lora A CTR (US; Taylor, Marie J CIV USN BRHLTHCLIN MER MS (US; Temple, Sherry L CIV (US; Tharp, Anthony R Jr PO2 USN (US; Brandon.s.thomas41.mil@mail.mil; Weibel, Wesley D LCDR USN BRHLTHCLIN MER MS (US; Wilson, Debbie Ann CIV USN BRHLTHCLIN MER MS (US; Wilson, Michael W PO1 USN BRHLTHCLIN MER MS (US; Winebrenner, Levi W PO3 USN (US; Mcpherson, Darlene ; nttcombudsman@gmail.com; Rickles, Julie; Ware, Susan E CTR USN COMTRAWING 1 MER MS (USA); Boyer, Cecelia; angela.crawford@deca.mil; Alawine, Deana S CTR (US); Cornwell, Roy L CTR (US); Cothorn, John M CTR (US); Deloach, Derrick V CTR USN NAVTECHTRACEN MS (USA); Green, Richard G CTR USN NAVTECHTRACEN MS (USA); Jefcoat, Joey M CIV USN NAVTECHTRACEN MS (USA); Spells, Linda D CTR (US); Wallace, Jack A CTR USN NETC HRO PNS FL (USA); McDaniel, Bridgette A CTR (USA); nasmeridianombudsman@gmail.com; cassieayala12@yahoo.com; Jennifer.l.crawford@vtxaero.com; Bright, Joshua A (Josh) CTR USN NAVTECHTRACEN MS (USA); Macon, Tonette; kasiem@sotxlighthouse.org; Hagan, Kenneth D CTR (US); Marsh, Crystal D SPC USARMY 62 MED BDE (USA; Baskin, George L Jr CIV (USA)  
**Subject:** FW: 2018 Consumer Confidence Report for Water Quality on board NAS Meridian  
**Attachments:** 2018 CCR 1.pdf; 2018 CCR 2.pdf

Base population:

The attached is the signed Annual Drinking Water Quality Report which is required to be released to the population of the base.

This report is designed to inform you about the quality water and services deliver to the base. The tables show results of monitoring from the period of January 1, 2018 to December 31, 2018.

For more information or questions, please contact the Deputy Public Works Officer at 601-679-2940 or the Maintenance Supervisor at 601-679-2530.

Thanks

Penny Randall

NAS Meridian, Miss.

Public Affairs Officer

OPSEC Manager

601-679-2602-office

601-679-3670-fax

Penny.randall@navy.mil

"FOUO - PRIVACY SENSITIVE: Information included in this email and/or attachments(s) may contain information protected by the Privacy Act of 1974 and/or the Electronic communications Privacy Act, 18 U.S.C. SS 2510-2521, and is confidential and may be legally privileged. Any misuse or unauthorized disclosure may result in both civil and/or criminal penalties. Limited distribution and handling is required.