

2019 MAY -2 AM 8:48

# 2018 CERTIFICATION

## Consumer Confidence Report (CCR)

### Town of New Augusta

Public Water System Name  
MS0560002

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper *(Attach copy of advertisement)*  
 On water bills *(Attach copy of bill)*  
 Email message *(Email the message to the address below)*  
 Other \_\_\_\_\_

Date(s) customers were informed: 4/25/2019 / / 2019 / / 2019

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed:  / /

CCR was distributed by Email *(Email MSDH a copy)*

Date Emailed:  / / 2019

- As a URL \_\_\_\_\_ *(Provide Direct URL)*  
 As an attachment  
 As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: The Richter Dispatch

Date Published: 4/25/2019

CCR was posted in public places. *(Attach list of locations)*

Date Posted:  / / 2019

CCR was posted on a publicly accessible internet site at the following address:

\_\_\_\_\_ *(Provide Direct URL)*

#### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Sherry Burns, Clerk  
Name/Title *(Board President, Mayor, Owner, Admin. Contact, etc.)*

4-29-2019  
Date

#### Submission options *(Select one method ONLY)*

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**Fax:** (601) 576 - 7800

**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2019!**

*Annual Drinking Water Quality Report  
Town of New Augusta  
PWS ID # 0560002  
April 2019*

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of two wells that draw from the Miocene Aquifer.

A source water assessment has been completed for the water supply to determine the overall susceptibility of its drinking water to identify potential sources of contamination. The water supply for the Town of New Augusta received a moderate susceptibility ranking to contamination.

We're pleased to report that our drinking water meets all federal and state requirements.

If you have any questions about this report or concerning your water utility, please contact Scott Extine at 601964-3710. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at New Augusta Town Hall at 6:00 pm.

The Town of New Augusta routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2018. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Treatment Technique (TT)** - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

## TEST RESULTS

| Contaminant   | Violation Y/N | Date Collected     | Level Detected | Range of Detects or # of Samples Exceeding MCL/ACL | Unit Measurement | MCLG | MCL    | Likely Source of Contamination  |
|---|---------------|--------------------|----------------|--|------------------|------|--------|---|
| <b>Inorganic Contaminants</b>                       |               |                    |                |  |                  |      |        |   |
| 8. Arsenic  | N             | 2016*              | 0.8            | No Range   | Ppb              | n/a  | 50     | Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes                    |
| 10. Barium  | N             | 2016*              | 0.0157         | No Range   | Ppm              | 2    | 2      | Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits                                |
| 13. Chromium  | N             | 2016*              | 0.6            | No Range   | Ppb              | 100  | 100    | Discharge from steel and pulp mills; erosion of natural deposits  |
| 14. Copper  | N             | 1/1/16 to 12/31/18 | 0.3            | None   | ppm              | 1.3  | AL=1.3 | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives                    |
| 16. Fluoride  | N             | 2016*              | 0.627          | No Range   | ppm              | 4    | 4      | Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories |
| 17. Lead  | N             | 1/1/16 to 12/31/18 | 6              | None   | ppb              | 0    | AL=15  | Corrosion of household plumbing systems, erosion of natural deposits  |
| 21. Selenium  | N             | 2016*              | .0031          | No Range   | ppb              | 50   | 50     | Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines                          |
| <b>Disinfectants &amp; Disinfectant By-Products</b> |               |                    |                |  |                  |      |        |   |
| Chlorine (as Cl <sub>2</sub> )                      | N             | 1/1/18 to 12/31/18 | 1.00           | 0.70 to 1.51                                       | ppm              | 4    | 4      | Water additive used to control microbes   |
| 73. TTHM [Total tri-halomethanes]                   | N             | 2018               | 68             | 32 - 69.8  | ppb              | 0    | 80     | By-product of drinking water chlorination   |
| HAAS  | N             | 2018               | 5              | 0 - 9  | ppb              | 0    | 60     | By-product of drinking water chlorination   |

\* Most recent sample results available

### Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of New Augusta is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing for \$10 per sample. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

This report being published in the paper will not be mailed. Please call our office if you have questions.

**Annual Drinking Water Quality Report**

**Town of New Augusta**

**PWS ID # 0560002**

**April 2019**

to present to you this year's Annual Water Quality Report. This report is designed to inform you about water and services we deliver to you every day. Our constant goal is to provide you with a safe and supply of drinking water. We want you to understand the efforts we make to continually improve the water access and protect our water resources. We are committed to ensuring the quality of your water. Our water lists of two wells that draw from the Miocene Aquifer.

ter assessment has been completed for the water supply to determine the overall susceptibility of its ter to identify potential sources of contamination. The water supply for the Town of New Augusta moderate susceptibility ranking to contamination.

ed to report that our drinking water meets all federal and state requirements.

any questions about this report or concerning your water utility, please contact Scott Exfine at 601964- ant our valued customers to be informed about their water utility. If you want to learn more, please attend ularly scheduled meetings. They are held on the first Tuesday of each month at New Augusta Town Hall

of New Augusta routinely monitors for constituents in your drinking water according to Federal and State able shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2018. As water r the land or underground, it can pick up substances or contaminants such as microbes, inorganic and micals, and radioactive substances. All drinking water, including bottled drinking water, may be expected to contain at least small amounts of some constituents. It's important to remember that the these constituents does not necessarily pose a health risk.

you will find many terms and abbreviations you might not be familiar with. To help you better these terms we've provided the following definitions:

el - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements ter system must follow.

Technique (TT) - A treatment technique is a required process intended to reduce the level of a it in drinking water.

Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment

Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below e is no known or expected risk to health. MCLGs allow for a margin of safety.

**TEST RESULTS**

| Violation Y/N | Date Collected | Level Detected | Range of Detects or # of Samples Exceeding MCL/AEL | Unit Measurement | MCLG | MCL | Likely Source of Contamination                                       |
|---------------|----------------|----------------|--|------------------|------|-----|--|
| N             | 2018           | 0.8            | No Range   | Ppb              | n/a  | 50  | Erosion of natural deposits; runoff from orchards; runoff from glass |

SONALLY appeared before me, the undersigned N ic in and for Perry County, Mississippi, Larry A. W authorized representative of *The Richton Dispatch* ly newspaper as defined and prescribed in Sections nd 13-3-32 of the Mississippi Code of 1972, as ame being duly sworn, stated that the notice, a true co ch hereto attached, appeared in the issues of spaper as follows:

- 114 No. 03 Date April 25, 2019
- No. \_\_\_\_\_ Date \_\_\_\_\_, 20\_\_

Published 1 times

Total.....\$ \_\_\_\_\_

ned: Jana Wilson

Authorized Representative of  
*The Richton Dispatch*

SWORN to and subscribed before me the 26th day of April, 2019



Jana Farve  
Notary Public

RECEIVED - WATER SUPPLY  
2019 MAY -2 AM 8:48

**PROOF OF PUBLICATION**  
THE STATE OF MISSISSIPPI • PERRY COUNTY  
RECEIVED - WATER SUPPLY  
2019 MAY -2 AM 8:48

PERSONALLY appeared before me, the undersigned Notary Public in and for Perry County, Mississippi, Larry A. Wilson, an authorized representative of *The Richton Dispatch*, a weekly newspaper as defined and prescribed in Sections 13-3-31 and 13-3-32 of the Mississippi Code of 1972, as amended, who being duly sworn, stated that the notice, a true copy of which hereto attached, appeared in the issues of said newspaper as follows:

Vol. 114 No. 03 Date April 25, 2019  
Vol. \_\_\_\_\_ No. \_\_\_\_\_ Date \_\_\_\_\_, 20\_\_\_\_  
Vol. \_\_\_\_\_ No. \_\_\_\_\_ Date \_\_\_\_\_, 20\_\_\_\_

Published 1 times

Total.....\$ \_\_\_\_\_

Signed: Larry A. Wilson

Authorized Representative of  
*The Richton Dispatch*

SWORN to and subscribed before me the 26th day of April, 2019.



Jana Farve  
Notary Public