2018 CERTIFICATION

Consumer Confidence Report (CCR)

Big V Water Association

Public Water System Name

59-0002

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax** (but not preferred) **or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

☒ Customers were informed of availability of CCR by: ***(Attach copy of publication, water bill or other)***

- ☒ ☐ Advertisement in local paper ***(Attach copy of advertisement)***
- ☐ ☐ On water bills ***(Attach copy of bill)***
- ☐ ☐ Email message ***(Email the message to the address below)***
- ☐ ☐ Other _____

Date(s) customers were informed: 5 /16 /2019 / /2019 / /2019

☐ CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

☐ CCR was distributed by Email (***Email MSDH a copy***) Date Emailed: / / 2019

- ☐ ☐ As a URL _____ ***(Provide Direct URL)***
- ☐ ☐ As an attachment
- ☐ ☐ As text within the body of the email message

☒ CCR was published in local newspaper. ***(Attach copy of published CCR or proof of publication)***

Name of Newspaper: The Banner Independant

Date Published: 5 /16/ 19

☐ CCR was posted in public places. ***(Attach list of locations)*** Date Posted: / / 2019

☐ CCR was posted on a publicly accessible internet site at the following address:

_____ ***(Provide Direct URL)***

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Melinda Ruttledge - Office Manager — 5-18-19

Name/Title (*Board President, Mayor, Owner, Admin. Contact, etc.*) — Date

Submission options (*Select one method ONLY*)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800
Not a preferred method due to poor clarity

CCR Deadline to MSDH & Customers by July 1, 2019!

2018 Annual Drinking Water Quality Report
Big V Water Association
PWS#: 590002
May 2019

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Gordo Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Big V Water Association have received a lower to moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Melinda Rutledge at 662.728.6901. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday after the 10th of each month at 6:00 PM the office located at 410 Outlet Road.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st , 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in $10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in $10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								

5. Gross Alpha	N	2013*	.8	No Range	pCi/L	0	15	Erosion of natural deposits
6. Radium 226	N	2013*	.4	No Range	pCi/1	0	5	Erosion of natural deposits
Inorganic Contaminants								
10. Barium	N	2018	.1311	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	1.6	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2014/16*	.6	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2014/16*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2016*	6	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2016*	1.01	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	2	1.1 – 2.8	Mg/l	0	MRDL = 4	Water additive used to control microbes

** Most recent sample. No sample required for 2018.*

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Big V Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

0107

2018 Annual Drinking Water Quality Report
Big V Water Association
PWS#: 580002
May 2019

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Gordo Formation Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Big V Water Association have received a lower to moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Melinda Rutledge at 662.726.6901. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday after the 10th of each month at 6:00 PM the office located at 410 Outlet Road.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in $10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in $10,000,000.

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
5. Gross Alpha	N	2013*	.8	No Range	pCi/L	0	15	Erosion of natural deposits
6. Radium 226	N	2013*	.4	No Range	pCi/l	0	5	Erosion of natural deposits
Inorganic Contaminants								
10. Berium	N	2018	.1311	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	1.6	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2014/18*	.6	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2014/18*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2018*	6	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2018*	1.01	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	2	1.1 – 2.8	Mg/l	0	MRDL = 4	Water additive used to control microbes

* *Most recent sample. No sample required for 2018.*

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576 [illegible] wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The Big V Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

0284

SEASONAL MAINTENANCE I ARE NOW AV

City of Boon

THE CITY OF BOONEVILLE IS ACCEP FOR SEASONAL PARK MAINTENANCI RATE AT $8 PER HOUR.

APPLICATIONS ARE AVAILABLE AT CI BOONEVILLE, MS. LAST DAY TO TU MAY 17, 2019 AT 5 P.M.

0536

MCAN

Mississippi Classified Advertising Netw

To place your statewide classified ad order, call MS Press

Employment

Mississippi Dept. of Corrections HIRING CORRECTIONAL OFFICERS
Join and Get a 5% Increase in Starting Pay

Join The Mississippi Department of Corrections (MDOC) and get an immediate 5 percent increase in your starting pay, if you have a college degree or experience in the workforce. The starting pay is $2,075.27 monthly. FOUR (4) WEEKS OF PAID ONSITE TRAINING.

STATE PRISON LOCATIONS:
•Central Mississippi Correctional Facility (CMCF) 3794 Highway 468, Pearl, MS
•Mississippi State Penitentiary (MSP) Hwy. 49 West, Parchman, MS
•South Mississippi Correctional Institution (SMCI) 22689 Hwy. 63 North, Leakesville, MS

WALK-IN INTERVIEW DATES/TIMES:
•**Saturday, May 4, 2019** – Applicants will be admitted from 8:00 a.m. to 10:00 a.m.
•**Monday thru Friday, May 13 - 17, 2019** – Applicants will be admitted from 8:00 a.m. – 10:00 a.m. and 1:00 p.m. to 3:00 p.m.
•**Saturday, May 18, 2019** – Applicants will be admitted from 8:00 a.m. to 10:00 a.m.

MINIMUM REQUIREMENTS:
•21 years of age and proof of H.S. diploma or G.E.D.
•Males between the ages of 21-25 proof of Selective Service Registration
•A Valid Driver's License
•No felony or domestic violence

INTERVIEW SCREENING CONSIST OF:
•Interview, Math Test, Report Writing Exercise
•1 mile walk/run within 18 minutes and Tower climb (Appropriate athletic clothing and tennis shoes may be worn)

For additional information, contact MDOC Personnel Services at (601) 359-5686 or the Personnel Department at each facility: CMCF (601) 932-2860 ext. 6701; MSP (662) 745-6611 ext. 2366; or SMCI (601) 394-5600 ext. 1217.

Individuals may also apply online at the Mississippi State Personnel Board website, www.mspb.ms.gov.

Employment

L. E. TUCKER & SON, INC.
DRIVERS needed to run from West Coast. Late model conv tractors. Home weekly. Benefits Pearl, MS. 601-93 www.luckerandson.com

Classes / Train

AIRLINES ARE HIRING - approved hands on Aviation Financial aid for qualified Career placement assistanc Aviation Institute of Maintenance 367-2510.

HEALTHCARE CAREER TR ONLINE. Start a new career in Billing and Coding. Administrative Assistant. To lear call Ultimate Medical Academy 664-5478

PHARMACY TECHNICIAN - TRAINING AVAILABLE! Take step into a new career! Call now 664-4140

For Sale

CHURCH FURNITURE: Do church need pews, pulpit set, b steeple, windows? Big Sale on n ioned pews and pew chairs. 1-8 8360. www.pews1.com

Insurance

DENTAL INSURANCE. Call P Mutual Insurance Company. for NOT just a discount plan, REAL for 350 procedures. 855-397- http://www.dental50plus.com/ Ad# 6118

FREE AUTO INSURANCE Q See how much you can save! SR22 driver policies available! 714-2407

FREE MEDICARE SUPPL QUOTES! Top providers. Excel erage. Call for a no obligation see how much you can save. 855-400-8352

Medical Suppl

OXYGEN - Anytime, Anywh tanks to refill. No deliveries. The Inogen One G4 is only 2.8 pou approved! FREE info kit: 888-96

VIAGRA and CIALIS USERS! SPECIAL $99.00 FREE Shipping guaranteed. CALL NOW! 844-8

Miscellaneou

DONATE YOUR CAR TO C Receive maximum value of writ your taxes. Running or not! A tions accepted. Free pickup. details. 855-400-8263

STATEWIDE DIGITAL ADVER starting at just $700 for two w newspaper web sites. Call Sue 981-3060 for advertising inform

Services-Gene

DIRECTV NOW. No Satellite $40/month. 65 Channels. Breaking News, Live Events, Spo Demand Titles. No Annual Cont Commitment. CALL 1-866-616-