

2019 MAY 30 AM 10:42

2018 CERTIFICATION

Consumer Confidence Report (CCR)

North Lee County Water Association

Public Water System Name

0410001, 0410024, 0410025, 0410035, 0410040, 0410041, 0410042, 0410043

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
 - Advertisement in local paper *(Attach copy of advertisement)*
 - On water bills *(Attach copy of bill)*
 - Email message *(Email the message to the address below)*
 - Other _____

Date(s) customers were informed: 5 / 31 / 2019 / / / 2019

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: / /

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: / / 2019
 - As a URL _____ *(Provide Direct URL)*
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: _____

Date Published: / /

- CCR was posted in public places. *(Attach list of locations)* Date Posted: / / 2019

- CCR was posted on a publicly accessible internet site at the following address:

northleewater.org/assets/file/ccr2018.pdf *(Provide Direct URL)*

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Dustin Hathcock (Water Operator)

Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5/29/19

Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2019!

2018 Annual Drinking Water Quality Report
North Lee County Water Association
PWS#: 410001, 410024, 410025, 410035, 410040, 410041, 410042, 410043
May 2019

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Eutaw, Lower Eutaw, Eutaw-McShan and Gordo Formation Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the North Lee Water Association have received moderate rankings in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Dustin Hathcock at 662.869.1223. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the second Thursday of the month at 7:00 PM at the Birmingham Ridge Fire Department located at 947 CR 1948, Saltillo, MS. Your CCR will not be mailed out to each individual customer, however you may obtain a copy by calling the office at 662.869.1223.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Level 1 assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

PWS ID # 410001

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2018	.087	.0708 - .0727	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	.7	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018	.112	.109 - .112	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
82. TTHM [Total trihalomethanes]	N	2015*	2.6	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	1.3	.3 - 2.2	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410024

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure-ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2017*	.6	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2017*	.1195	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2017*	.9	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.5	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
20. Nitrite (as Nitrogen)	N	2018	.03	No Range	ppm	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
21. Selenium	N	2017*	1.9	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Volatile Organic Contaminants								
66. Ethylbenzene	N	2018	.718	No Range	ppb	700	700	Discharge from petroleum

76. Xylenes	N	2018	.00283	No Range	ppm	10	10	refineries Discharge from petroleum factories; discharge from chemical factories
Disinfection By-Products								
Chlorine	N	2018	1.7	.6 - 2.6	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410025		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
8. Arsenic	N	2018	1.4	No Range	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
10. Barium	N	2018	.4356	.0926 - .4356	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	.6	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2018	.183	.174 - .183	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17	0	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Volatile Organic Contaminants								
76. Xylenes	N	2018	.000639	.000512 - .00639	ppm	10	10	Discharge from petroleum factories; discharge from chemical factories

Disinfection By-Products								
81. HAA5	N	2018	5	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2018	1.3	.30 - 2.6	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410035		TEST RESULTS						
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Radioactive Contaminants								
6. Radium 226	N	2018	.15	No Range	pCi/L	0	5	Erosion of natural deposits
Inorganic Contaminants								
8. Arsenic	N	2018	.9	.8 - .9	ppb	n/a	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes

10. Barium	N	2018	.232	.2209 - .232	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	.9	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits

Disinfection By-Products

81. HAA5	N	2018	1	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2018	1	.3 - 1.9	mg/l	0	MRDL = 4	Water additive used to control microbes

Unregulated Contaminants

Bromide	N	2018	610	530 - 610	UG/L			Naturally-occurring element found in the earth's crust and at low concentrations in seawater, and in some surface and ground water; cobaltous chloride was formerly used in medicines and as a germicide
Manganese	N	2018	72	37 - 72	UG/L			Naturally-occurring element; commercially available in combination with other elements and minerals; used in steel production, fertilizer, batteries and fireworks; drinking water and wastewater treatment chemicals; essential nutrient

PWS ID # 410040

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2015*	.1556	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2015*	1.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2015/17*	.3	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2015*	.136	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2015/17*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
Chlorine	N	2018	1.2	.5 - 2.5	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410041

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	---	--------------------	------	-----	--------------------------------

Radioactive Contaminants

6. Radium 226 Radium 228	N	2018	.60 .56	No Range	pCi/L	0	5	Erosion of natural deposits
-----------------------------	---	------	------------	----------	-------	---	---	-----------------------------

Inorganic Contaminants

10. Barium	N	2017*	.171	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2017*	.8	No Range	ppb	100	100	
14. Copper	N	2016*	.4	0	ppm	1.3	AL=1.3	Discharge from steel and pulp mills; erosion of natural deposits Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2017*	.113	No Range	ppm	4	4	
17. Lead	N	2016*	1	0	ppb	0	AL=15	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories Corrosion of household plumbing systems; erosion of natural deposits
21. Selenium	N	2017*	2	No Range	ppb	50	50	

Disinfection By-Products

81. HAA5	N	2018	1	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2018	4	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	1	.5 - 2.5	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410042

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	---	--------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2015*	.1266	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2015*	2.2	No Range	ppb	100	100	
14. Copper	N	2016*	.2	0	ppm	1.3	AL=1.3	Discharge from steel and pulp mills; erosion of natural deposits Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2018	5.94	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	1	.8 - 1.80	mg/l	0	MRDL = 4	Water additive used to control microbes

PWS ID # 410043

TEST RESULTS

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
-------------	---------------	----------------	----------------	---	--------------------	------	-----	--------------------------------

Inorganic Contaminants

10. Barium	N	2017*	.1488	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
14. Copper	N	2016*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2017*	.133	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2016*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
21. Selenium	N	2017*	1.5	No Range	ppb	50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

Disinfection By-Products

82. TTHM [Total trihalomethanes]	N	2018	1.65	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2017*	1	.3 - 1.85	mg/l	0	MRDL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2018.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some contaminants have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The North Lee County Water Association works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-19537

ACCOUNT NO.	SERVICE FROM	SERVICE TO
011000005	05/20	05/20
SERVICE ADDRESS		
1178 BIRMINGHAM RIDGE RD		
CURRENT	METER READINGS PREVIOUS	USED
517842	512388	5454
CHARGE FOR SERVICES		

WTR 31.25
 NET DUE >>> 31.25
 SAVE THIS >> 5.00
 GROSS DUE >> 36.25

SEE IMPORTANT NOTICE ON BACK OF BILL

NORTH LEE COUNTY WATER ASSOCIATION
 1004 BIRMINGHAM RIDGE ROAD • SALTILLO, MS 38866
 662-869-1223 • nlcwa@atl.net

FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PERMIT NO. 4
 SALTILLO, MS

Pay bill at northleewater.org

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/15/2019	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
31.25	5.00	36.25

northleewater.org/asset/file/
 ccr2018.pdf CUT OFF 6/25/19

RETURN SERVICE REQUESTED

011000005
 TERESA & CHRIS EASTERLING

1178 BIRMINGHAM RIDGE RD
 SALTILLO MS 38866-9132

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-19537

ACCOUNT NO.	SERVICE FROM	SERVICE TO
011000284	05/20	05/20
SERVICE ADDRESS		
137 HIGHLAND RIDGE DR		
CURRENT	METER READINGS PREVIOUS	USED
145527	145527	
CHARGE FOR SERVICES		

WTR 15.00
 SWR 15.00
 NET DUE >>> 30.00
 SAVE THIS >> 5.00
 GROSS DUE >> 35.00

SEE IMPORTANT NOTICE ON BACK OF BILL

RETURN THIS STUB WITH PAYMENT TO:
 NORTH LEE COUNTY WATER ASSOCIATION
 1004 BIRMINGHAM RIDGE ROAD • SALTILLO, MS 38866
 662-869-1223 • nlcwa@atl.net

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PERMIT NO. 4
 SALTILLO, MS

Pay bill at northleewater.org

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/15/2019	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
30.00	5.00	35.00

northleewater.org/asset/file/
 ccr2018.pdf CUT OFF 6/25/19

RETURN SERVICE REQUESTED

011000284
 TOMMY & ANN GALLOWAY

137 HIGHLAND RIDGE DR
 SALTILLO, MS 38866

FORMSINK, LLC • FOR REORDER CALL 1-800-223-4460 • L-19537

ACCOUNT NO.	SERVICE FROM	SERVICE TO
011001005	05/20	05/20
SERVICE ADDRESS		
1197 BIRMINGHAM RIDGE RD		
CURRENT	METER READINGS PREVIOUS	USED
226312	224013	2299
CHARGE FOR SERVICES		

WTR 15.00
 NET DUE >>> 15.00
 SAVE THIS >> 5.00
 GROSS DUE >> 20.00

SEE IMPORTANT NOTICE ON BACK OF BILL

RETURN THIS STUB WITH PAYMENT TO:
 NORTH LEE COUNTY WATER ASSOCIATION
 1004 BIRMINGHAM RIDGE ROAD • SALTILLO, MS 38866
 662-869-1223 • nlcwa@atl.net

PRESORTED
 FIRST-CLASS MAIL
 U.S. POSTAGE
 PAID
 PERMIT NO. 4
 SALTILLO, MS

Pay bill at northleewater.org

PAY NET AMOUNT ON OR BEFORE DUE DATE	DUE DATE	PAY GROSS AMOUNT AFTER DUE DATE
	06/15/2019	
NET AMOUNT	SAVE THIS	GROSS AMOUNT
15.00	5.00	20.00

northleewater.org/asset/file/
 ccr2018.pdf CUT OFF 6/25/19

RETURN SERVICE REQUESTED

011001005
 TRACY THOMPSON

1197 BIRMINGHAM RIDGE RD
 SALTILLO MS 38866