

2018 CERTIFICATION

Consumer Confidence Report (CCR)

City of Verona

Public Water System Name

0410016

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

- Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*
- Advertisement in local paper *(Attach copy of advertisement)*
 - On water bills *(Attach copy of bill)*
 - Email message *(Email the message to the address below)*
 - Other _____

Date(s) customers were informed: ___ / ___ / 2019 / / 2019 / / 2019

- CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: ___ / ___ /

- CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: ___ / ___ / 2019
- As a URL _____ *(Provide Direct URL)*
 - As an attachment
 - As text within the body of the email message

- CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Lee County Courier

Date Published: 04/18/2019

- CCR was posted in public places. *(Attach list of locations)* Date Posted: ___ / ___ / 2019

- CCR was posted on a publicly accessible internet site at the following address: _____

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Robby Williams

5-28-19

Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2019!

2018 Annual Drinking Water Quality Report
 City of Verona
 PWS#: 0410016
 April 2019

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Our water source is from wells drawing from the McShan Formation and Eutaw Formation Aquifers. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Verona have received moderate susceptibility rankings to contamination.

If you have any questions about this report or concerning your water utility, please contact Billy Williams at 662.566.2211 EXT 113. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of the month at 6:00 PM at the City Hall.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants								
10. Barium	N	2016*	.1002	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2016*	2.8	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits

14. Copper	N	2014/16*	.4	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride	N	2016*	.126	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2014/16*	2	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products								
81. HAA5	N	2018	1	No Range	ppb	0	60	By-Product of drinking water disinfection.
82. TTHM [Total trihalomethanes]	N	2018	1.08	No Range	ppb	0	80	By-product of drinking water chlorination.
Chlorine	N	2018	1.7	1 - 2	mg/l	0	MDRL = 4	Water additive used to control microbes

* Most recent sample. No sample required for 2018.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The City of Verona works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PROOF OF PUBLICATION

STATE OF MISSISSIPPI
COUNTY OF LEE

Before the undersigned, a NOTARY
in and for said state and county, JIM CLARK
general manager of the
LEE COUNTY COURIER

in the Town of TOLLO in said county and state, a newspaper published
makes oath that the
WATER REPORT

of which the article hereunto attached is a true copy, was published in said newspa-
per as follows:

- Volume 28, No. 15 Date APRIL 18 2019
- Volume _____, No. _____ Date _____ 20 _____
- Volume _____, No. _____ Date _____ 20 _____
- Volume _____, No. _____ Date _____ 20 _____
- Volume _____, No. _____ Date _____ 20 _____

And I, hereby certify that the issues above mentioned have been examined
by me, and I find the publication thereof to have been duly made, and that The Lee
County Courier has been established, published and had a bona fide circulation in
said city, county and state for more than one year next proceeding the first date writ-
ten above.

[Signature]
General Manager


Sworn to and subscribed before me this the 10 day

May, 20 19

[Signature]
1-6, 2023



of _____
My commission expires _____



HELPING LAW ENFORCEMENT — West Jackson Street School classes presented all Lee County Deputies a "Tactical" bag. These bags will be used for their duty weapon and gear. They also presented a check for the purchase of two bullet proof vests. "We are so thankful for this act of kindness," said Lee County Sheriff Jim Johnson. Pictured from left to right: Sheriff Johnson, deputy George Adams, Investigator Casey Bruce, Investigator Kavin Warren, deputy A.J. Dillard, deputy Austin Kidd and deputy Terry Richardson. The sheriff's department will provide the vests and other equipment, if other churches would like to help — call (662) 841-9040.

Annual Drinking Water Quality Report" City of Verona PWS ID: 0410016 April 2019

This is this year's Annual Quality Water Report. This report is designed to inform you about the quality of water and how we provide it. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to know that we are committed to continually improve the water treatment process and protect our water resources. We are committed to

drawing from the McShan Formation and Eutaw Formation Aquifers. The source water assessment has been conducted to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. Detailed information on how the susceptibility determinations were made has been furnished to our public and is available for viewing upon request. The wells for the City of Verona have received moderate susceptibility rankings to

for this report or concerning your water utility, please contact Billy Williams at 862.566.2211 EXT 113. We want you to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. The next meeting is on the 15th of the month at 6:00 PM at the City Hall.

contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water quality monitoring results for the period of January 1st to December 31st, 2018. In cases where monitoring wasn't required in 2018, the results are not shown. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and materials and can pick up substances or contaminants from the presence of animals or from human activity, including viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and industrial discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from agricultural, urban storm-water runoff, and residential uses; organic chemical contaminants, including solvents, which are by-products of industrial processes and petroleum production, and can also come from gas production and mining operations; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining operations. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some of these substances. It's important to remember that the presence of these contaminants does not necessarily indicate that the

terms and abbreviations you might not be familiar with. To help you better understand these terms we've