

2019 JUN -5 AM 9:27

# 2018 CERTIFICATION

## Consumer Confidence Report (CCR)

City of Petal

Public Water System Name

0180011

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

- Advertisement in local paper *(Attach copy of advertisement)*
- On water bills *(Attach copy of bill)*
- Email message *(Email the message to the address below)*
- Other \_\_\_\_\_

Date(s) customers were informed: 6 / 1 / 2019 / / / 2019

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used \_\_\_\_\_

Date Mailed/Distributed: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: \_\_\_\_\_ / \_\_\_\_\_ / 2019

- As a URL \_\_\_\_\_ *(Provide Direct URL)*
- As an attachment
- As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Petal News

Date Published: 5 / 9 / 19

CCR was posted in public places. *(Attach list of locations)* Date Posted: \_\_\_\_\_ / \_\_\_\_\_ / 2019

CCR was posted on a publicly accessible internet site at the following address: www.cityofpetal.com/annual-water-report *(Provide Direct URL)*

### CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Madina Math City Clerk  
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

6/3/2019  
Date

### Submission options (Select one method ONLY)

**Mail:** (U.S. Postal Service)  
MSDH, Bureau of Public Water Supply  
P.O. Box 1700  
Jackson, MS 39215

**Email:** [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

**Fax:** (601) 576 - 7800  
**\*\*Not a preferred method due to poor clarity\*\***

**CCR Deadline to MSDH & Customers by July 1, 2019!**

2018 Annual Drinking Water Quality Report  
 City of Petal  
 PWS ID#: 0180011  
 April 2019

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

If you have any questions about this report or concerning your water utility, please contact Donald Wagers at 601.544.6981. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first and third Tuesdays of each month at 6:00 PM at the City Hall Board Room.

Our water source is from wells drawing from the Quaternary Alluvium, the Middle Catahoula Formation and the Hattiesburg Formation Aquifers. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Petal have received lower to moderate susceptibility rankings to contamination.

The City of Petal routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Level 1 Assessment: A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.*

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants</b>								
5. Gross Alpha	N	2014*	4	2 - 4	pCi/L	0	15	Erosion of natural deposits
6. Radium 226 Radium 228	N	2014*	1.2 0.6	0.9 - 1.2 No Range	pCi/l	0	5	Erosion of natural deposits
<b>Inorganic Contaminants</b>								
10. Barium	N	2018	.0461	.0349 - .0461	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2018	2.2	.7 – 2.2	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2016/18	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2018	.755	.388 – .755	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2016/18	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2018	.95	.38 – .95	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

### Disinfection By-Products

Chlorine	N	2018	1.5	1.3 – 1.7	mg/l	0	MDRL = 4	Water additive used to control microbes
----------	---	------	-----	-----------	------	---	----------	---

\* Most recent sample. No sample required for 2018.

\*\* Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.6 – 1.2 mg/l

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our system is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 89%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The City of Petal works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**2018 Annual Drinking Water Quality Report**  
**City of Petal**  
**PWS ID#: 0180011**  
**April 2019**

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. If you have any questions about this report or concerning your water utility, please contact Donald Wagers at 601.544.6981. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first and third Tuesdays of each month at 6:00 PM at the City Hall Board Room.

Our water source is from wells drawing from the Quaternary Alluvium, the Middle Catahoula Formation and the Hattiesburg Formation Aquifers. The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Petal have received lower to moderate susceptibility rankings to contamination.

The City of Petal routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2018. In cases where monitoring wasn't required in 2018, the table reflects the most recent results. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Level 1 Assessment:** A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**TEST RESULTS**

Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants</b>								
5. Gross Alpha	N	2014*	4	2-4	pCi/L	0	15	Erosion of natural deposits
6. Radium 226 Radium 228	N	2014*	1.2 0.6	0.9-1.2 No Range	pCi/l	0	5	Erosion of natural deposits
<b>Inorganic Contaminants</b>								
10. Barium	N	2018	.0461	.0349 - .0461	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
13. Chromium	N	2018	2.2	7 -2.2	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2016/18	2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2018 *	.755	.388-.755	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2016/18	1	0	ppb	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2018	.95	.38-.95	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Disinfection By-Products</b>								
Chlorine	N	2018	1.5	1.3 -1.7	mg/l	0	MRDL=4	Water additive used to control microbes

*most recent sample, no sample required for 2010.*

**\*\* Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.6-1.2 mg/l**

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our system is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 12. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 89%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The City of Petal works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**NOTE: THE CONSUMER CONFIDENCE REPORT WILL NOT BE SENT VIA MAIL. YOU MAY OBTAIN A HARD COPY OF THE REPORT BY REQUEST AT THE BILLING OFFICE LOCATED AT 119 W GRH AVE., PETAL, MS**

# Hattiesburg Publishing, Inc.

103 N. 40th Ave. • Hattiesburg, MS 39401  
(601) 268-2331 tel • (601) 268-2965 fax

## Proof of Publication

THE STATE OF MISSISSIPPI, LAMAR COUNTY, FORREST COUNTY  
Personally appeared before me, the undersigned person, representing The PineBelt NEWS, a weekly newspapers published in Lamar County and Forrest County, Mississippi, who, being duly sworn, says that the notice, a true copy of which is hereto annexed, appeared in the issues of said newspapers as follows:

Total # of Words: 4 x 16 Published 1 times  
Date 1st Published: May 9 Amt: 1152.00  
Date 2nd Published: \_\_\_\_\_ Amt: \_\_\_\_\_  
Date 3rd Published: \_\_\_\_\_ Amt: \_\_\_\_\_  
Date 4th Published: \_\_\_\_\_ Amt: \_\_\_\_\_  
Date 5th Published: \_\_\_\_\_ Amt: \_\_\_\_\_  
Subtotal Printer's Fee: 1152.00  
Proof of Publication Fee: 3.00  
TOTAL: 1155.00

(signed) *Yvonne B...*  
The PineBelt NEWS

Sworn to and subscribed before me in my Presence, this 9th day of May, 2019, a Notary Public in and for the County of Lamar, State of Mississippi:  
(signed) *David Gustafson*  
NOTARY PUBLIC  
ID# 100342  
DAVID GUSTAFSON  
Commission Expires Oct 4, 2019  
LAMAR COUNTY

**FOR OFFICE USE ONLY:**

Em P: 05/06

App: 05/06

File Name: CoP - Water Quality Report

Invoice #: 93830

Inv. Cr/Mld: \_\_\_\_\_

Pymt Rec.d: \_\_\_\_\_

POP sent: \_\_\_\_\_

see attached 2 pages

**CITY OF PETAL**  
 PO Box 405, Petal, MS 39465  
 Phone: (601) 544-6981

PRESORTD  
 FIRST CLASS MAIL  
 U.S. POSTAGE PAID  
 LPP  
 28292

ACCOUNT NO.	00004	BILL DATE	6/01/2019
CURRENT READING	202	PREVIOUS READING	202
SERVICE ADDRESS		113 S MAIN ST	
DESCRIPTION		AMOUNT	
Commercial Water		BILLED	13.00
Commercial Garbage		DUE	18.25
Commercial Sewer			32.00
Sewer Treatment			12.00
Water Sales Tax			0.91

ACCOUNT NO.	00004	DUE DATE	6/16/2019
PAY BY DUE DATE	76.16	PAY AFTER DUE DATE	87.58

Past Due Amount must be paid by 6/16/19 to avoid termination of service.

Important information about your drinking water is available in the 2018 Consumer Confidence Report at [www.cityofpetal.com](http://www.cityofpetal.com). You may request a hard copy by calling our office at 601-544-6981.15%

RETURN THIS PORTION WITH PAYMENT

SERVICE FROM	4/24/2019	SERVICE TO	5/23/2019	PAST DUE AMOUNT	0.00
DUE DATE	6/16/2019	PAY BY DUE DATE	76.16	PAY AFTER DUE DATE	87.58

\*\*\*\*\*AUTO\*\*5-DIGIT 39465  
 PETAL MUFFLER SHOP  
 113 S MAIN ST  
 PETAL MS 39465-2331

1

**CITY OF PETAL**  
 PO Box 405, Petal, MS 39465  
 Phone: (601) 544-6981

PRESORTD  
 FIRST CLASS MAIL  
 U.S. POSTAGE PAID  
 LPP  
 28292

ACCOUNT NO.	00020	BILL DATE	6/01/2019
CURRENT READING	900	PREVIOUS READING	895
SERVICE ADDRESS		139 S MAIN ST	
DESCRIPTION		AMOUNT	
Commercial Water		BILLED	31.00
Commercial Garbage		DUE	18.25
Commercial Sewer			35.00
Sewer Treatment			12.00
Water Sales Tax			2.17

ACCOUNT NO.	00020	DUE DATE	6/16/2019
PAY BY DUE DATE	98.42	PAY AFTER DUE DATE	113.18

Past Due Amount must be paid by 6/16/19 to avoid termination of service.

Important information about your drinking water is available in the 2018 Consumer Confidence Report at [www.cityofpetal.com](http://www.cityofpetal.com). You may request a hard copy by calling our office at 601-544-6981.15%

RETURN THIS PORTION WITH PAYMENT

SERVICE FROM	4/24/2019	SERVICE TO	5/23/2019	PAST DUE AMOUNT	0.00
DUE DATE	6/16/2019	PAY BY DUE DATE	98.42	PAY AFTER DUE DATE	113.18

\*\*\*\*\*AUTO\*\*5-DIGIT 39465  
 PETAL FAMILY DENTISTRY LLC  
 139 S MAIN ST  
 PETAL MS 39465-2331

3

**CITY OF PETAL**  
 PO Box 405, Petal, MS 39465  
 Phone: (601) 544-6981

PRESORTD  
 FIRST CLASS MAIL  
 U.S. POSTAGE PAID  
 LPP  
 28292

ACCOUNT NO.	00006	BILL DATE	6/01/2019
CURRENT READING	147	PREVIOUS READING	146
SERVICE ADDRESS		112 B S MAIN ST	
DESCRIPTION		AMOUNT	
Commercial Water		BILLED	13.00
Commercial Garbage		DUE	18.25
Commercial Sewer			32.00
Sewer Treatment			12.00
Water Sales Tax			0.91

ACCOUNT NO.	00006	DUE DATE	6/16/2019
PAY BY DUE DATE	76.16	PAY AFTER DUE DATE	87.58

Past Due Amount must be paid by 6/16/19 to avoid termination of service.

Important information about your drinking water is available in the 2018 Consumer Confidence Report at [www.cityofpetal.com](http://www.cityofpetal.com). You may request a hard copy by calling our office at 601-544-6981.15%

RETURN THIS PORTION WITH PAYMENT

SERVICE FROM	4/24/2019	SERVICE TO	5/23/2019	PAST DUE AMOUNT	0.00
DUE DATE	6/16/2019	PAY BY DUE DATE	76.16	PAY AFTER DUE DATE	87.58

\*\*\*\*\*AUTO\*\*5-DIGIT 39465  
 SMOKIES  
 112B S MAIN ST  
 PETAL MS 39465-2347

2

**CITY OF PETAL**  
 PO Box 405, Petal, MS 39465  
 Phone: (601) 544-6981

PRESORTD  
 FIRST CLASS MAIL  
 U.S. POSTAGE PAID  
 LPP  
 28292

ACCOUNT NO.	00021	BILL DATE	6/01/2019
CURRENT READING	250	PREVIOUS READING	250
SERVICE ADDRESS		209 S MAIN ST	
DESCRIPTION		AMOUNT	
Residential Water		BILLED	13.00
Garbage Late Charge		DUE	2.74
Residential Garbage			18.25
Residential Sewer			32.00
Sewer Treatment			12.00
W/S Late Charges			8.55

ACCOUNT NO.	00021	DUE DATE	6/16/2019
PAY BY DUE DATE	161.79	PAY AFTER DUE DATE	173.08

Past Due Amount must be paid by 6/16/19 to avoid termination of service.

Important information about your drinking water is available in the 2018 Consumer Confidence Report at [www.cityofpetal.com](http://www.cityofpetal.com). You may request a hard copy by calling our office at 601-544-6981.15%

RETURN THIS PORTION WITH PAYMENT

SERVICE FROM	4/24/2019	SERVICE TO	5/23/2019	PAST DUE AMOUNT	75.25
DUE DATE	6/16/2019	PAY BY DUE DATE	161.79	PAY AFTER DUE DATE	173.08

\*\*\*\*\*AUTO\*\*5-DIGIT 39465  
 HELEN MCCAFFERY  
 209 S MAIN ST  
 PETAL MS 39465-2333

4

