

RECEIVED WATER DIVISION
2019 JUN -7 AM 8:44

2018 CERTIFICATION

Consumer Confidence Report (CCR)

City of Amory Water Department
Public Water System Name

MS480002

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. **You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH.** Please check all boxes that apply.

Customers were informed of availability of CCR by: *(Attach copy of publication, water bill or other)*

Advertisement in local paper *(Attach copy of advertisement)*

On water bills *(Attach copy of bill)*

Email message *(Email the message to the address below)*

Other _____

Date(s) customers were informed: 5 / 22 / 2019 / / / 2019 / / / 2019

CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used _____

Date Mailed/Distributed: _____ / _____ / _____

CCR was distributed by Email *(Email MSDH a copy)* Date Emailed: _____ / _____ / 2019

As a URL _____ *(Provide Direct URL)*

As an attachment

As text within the body of the email message

CCR was published in local newspaper. *(Attach copy of published CCR or proof of publication)*

Name of Newspaper: Monroe County Shopper - mail proof of publication when available

Date Published: 6 / 05 / 19

CCR was posted in public places. *(Attach list of locations)* ^{copy at City of Amory water office} Date Posted: 5 / 22 / 2019

CCR was posted on a publicly accessible internet site at the following address: _____

(Provide Direct URL)

CERTIFICATION

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the Mississippi State Department of Health, Bureau of Public Water Supply

Buff Bio water treatment supt.
Name/Title (Board President, Mayor, Owner, Admin. Contact, etc.)

5-16-19
Date

Submission options (Select one method ONLY)

Mail: (U.S. Postal Service)
MSDH, Bureau of Public Water Supply
P.O. Box 1700
Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800

****Not a preferred method due to poor clarity****

CCR Deadline to MSDH & Customers by July 1, 2019!

Copy of 2018 Annual Drinking Water Quality Report

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791). Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water source is from 6 wells drawing from the Gordo Aquifer.

Source water assessment and its availability

Our source water assessment has been completed. Our wells were ranked LOWER in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662-256-5633.

Source water assessment and its availability

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). Our source water assessment has been completed. Our wells were ranked LOWER in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662-256-5633.

How can I get involved?

We want our valued customers to be informed about their water utility. If you want additional information, contact our utility office at 256-5633 to schedule a meeting with the water utility staff. Our Board of Alderman meets on the first and third Tuesday of each month, 6:00 PM in the Board Room at City Hall at 109 Front Street.

Description of Water Treatment Process

Your water is treated in a "treatment train" (a series of processes applied in a sequence) that includes coagulation, flocculation, sedimentation, filtration, and disinfection. Coagulation removes dirt and other particles suspended in the source water by adding chemicals (coagulants) to form tiny sticky particles called "floc," which attract the dirt particles. Flocculation (the formation of larger flocs from smaller flocs) is achieved using gentle, constant mixing. The heavy particles settle naturally out of the water in a sedimentation basin. The clear water then moves to the filtration process where the water passes through sand, gravel, charcoal or other filters that remove even smaller particles. A small amount of chlorine or other disinfection method is used to kill bacteria and

other microorganisms (viruses, cysts, etc.) that may be in the water before water is stored and distributed to homes and businesses in the community.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Other Information

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", MS0480002 is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 11. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 92%

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Amory Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure

is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Amory Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	1.8	1.07	2.6	2018	No	Water additive used to control microbes MRDL Range: 1.07 MG/L to 2.60 MG/L
Haloacetic Acids (HAAs) (ppb)	NA	60	4	NA	NA	2016	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	9.54	NA	NA	2016	No	By-product of drinking water disinfection
Inorganic Contaminants								
Barium (ppm)	2	2	.0108	NA	NA	2016	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	1.27	.6	1.3	2016	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	0	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits	
Inorganic Contaminants								

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
Lead - action level at consumer taps (ppb)	0	15	0	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Violation	Typical Source
1,1,1-Trichloroethane (ppb)	200	200	ND	No	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane (ppb)	3	5	ND	No	Discharge from industrial chemical factories
1,1-Dichloroethylene (ppb)	7	7	ND	No	Discharge from industrial chemical factories
1,2,4-Trichlorobenzene (ppb)	70	70	ND	No	Discharge from textile-finishing factories
1,2-Dichloroethane (ppb)	0	5	ND	No	Discharge from industrial chemical factories
1,2-Dichloropropane (ppb)	0	5	ND	No	Discharge from industrial chemical factories
Benzene (ppb)	0	5	ND	No	Discharge from factories; Leaching from gas storage tanks and landfills
Carbon Tetrachloride (ppb)	0	5	ND	No	Discharge from chemical plants and other industrial activities
Chlorobenzene (monochlorobenzene) (ppb)	100	100	ND	No	Discharge from chemical and agricultural chemical factories
Cyanide (ppb)	200	200	ND	No	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories
Dichloromethane (ppb)	0	5	ND	No	Discharge from pharmaceutical and chemical factories
Ethylbenzene (ppb)	700	700	ND	No	Discharge from petroleum refineries
Nitrate [measured as Nitrogen] (ppm)	10	10	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	ND	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Styrene (ppb)	100	100	ND	No	Discharge from rubber and plastic factories; Leaching from landfills
Tetrachloroethylene (ppb)	0	5	ND	No	Discharge from factories and dry cleaners
Toluene (ppm)	1	1	ND	No	Discharge from petroleum factories
Trichloroethylene (ppb)	0	5	ND	No	Discharge from metal degreasing sites and other factories
Vinyl Chloride (ppb)	0	2	ND	No	Leaching from PVC piping; Discharge from plastics factories
Xylenes (ppm)	10	10	ND	No	Discharge from petroleum factories; Discharge from chemical factories
cis-1,2-Dichloroethylene (ppb)	70	70	ND	No	Discharge from industrial chemical factories
o-Dichlorobenzene (ppb)	600	600	ND	No	Discharge from industrial chemical factories
p-Dichlorobenzene (ppb)	75	75	ND	No	Discharge from industrial chemical factories

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Your Water	Violation	Typical Source
trans-1,2-Dichloroethylene (ppb)	100	100	ND	No	Discharge from industrial chemical factories

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPI: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Buddy Brown
Address: P O Box 266
Armory, MS 38821
Phone: 662-256-5633

Copy of 2018 Annual Drinking Water Quality Report City Of Amory Water Department

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers regarding their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791). Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water sources from 6 wells coming from the Gordon Aquifer

Source water assessment and its variability

Our source water assessment has been completed. Our wells were ranked LOWER in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662-256-5633.

Source water assessment and its variability

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of certain materials does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). Drinking water, including bottled water, may occasionally be expected to contain small amounts of some contaminants. The presence of contaminants does not necessarily indicate a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). Our source water assessment has been completed. Our wells were ranked LOWER in terms of susceptibility to contamination. For a copy of the report, please contact our office at 662-256-5633.

How can I get involved?

We want our valued customers to be informed about their water utility. If you want additional information, contact our utility office at 256-5633 to schedule a meeting with the water utility staff. Our Office of Government Affairs is on the first and third Tuesday of each month, 6:30 PM in the Board Room at City Hall at 100 Front Street.

Description of Water Treatment Process

Your water is treated in a "treatment train" (a series of processes applied in a sequence) that includes coagulation, flocculation, sedimentation, filtration, and disinfection. Coagulation removes dirt and other particles suspended in the source water by adding chemicals (usually alum) to an "iridescent" water called "floc", which allows the dirt particles to clump together. Flocculation (the formation of larger flocs from smaller ones) is achieved using gentle, constant mixing. The heavy particles settle naturally out of the water in a sedimentation basin. The clear water then moves to the filtration process where the water passes through sand, gravel, charcoal, and other filters that remove even smaller particles. A small amount of chlorine or other disinfection method is used to kill bacteria and other microorganisms (viruses, cysts, etc.) that may be in the water before water is stored and distributed to homes and businesses in the community.

Water Conservation Tips

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 1100

Contaminants	MCLG or MCL (MCLG: MGD/L)	Detected in Your Water	Range		Sample Date	Violation	Typical Source
			Low	High			
Disinfectants & Disinfection By-Products							
(There is continuing evidence that addition of disinfectants is necessary for control of microbial contaminants)							
Chlorine Residual (ppm)	4	1.8	1.07	2.6	2018	No	Water additive used to control microbes (VRDL Range: 1.07 MG/L to 2.60 MG/L)
Halocetic Acids (PAA5) (ppb)	NA	4	NA	NA	2016	No	By-product of drinking water chlorination
Trihalomethanes (THMs) (ppb)	NA	80	NA	NA	2016	No	By-product of drinking water disinfection
Inorganic Contaminants							
Barium (ppm)	2	0.108	NA	NA	2016	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	2	1.27	6	1.3	2016	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Contaminants Exceeds							
# Samples Exceeding AL							
Your Sample Date							
MCLG AL							
Inorganic Contaminants							
Copper - action level (ppm)	1.3	1.3	0	2013	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Contaminants Exceeds							
# Samples Exceeding AL							
Your Sample Date							
MCLG AL							
Contaminants							
Lead - action level at consumer taps (ppb)	0	14	0	2018	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Undetected Contaminants							
The following contaminants were monitored for, but not detected, in your water.							
Contaminants							
MCLG or MCL (MCLG: MGD/L)	Year	Water	Violation	Typical Source			
1,1,1-Trichloroethane (ppb)	200	ND	No	Discharge from metal degreasing sites and other facilities			
1,1,2,2-Tetrachloroethane (ppb)	3	ND	No	Discharge from industrial chemical factories			
1,1-Dichloroethylene (ppb)	7	ND	No	Discharge from industrial chemical factories			
1,2-Dichloroethane (ppb)	70	ND	No	Discharge from textile-finishing factories			
1,2-Dichlorobenzene (ppb)	0	ND	No	Discharge from industrial chemical factories			
1,2-Dichloroethane (ppb)	0	ND	No	Discharge from industrial chemical factories			
Barium (ppb)	0	ND	No	Discharge from industrial chemical factories			
Carbon Tetrachloride (ppb)	0	ND	No	Discharge from chemical plants and other industrial			

Contaminant	Unit	5	ND	No	Discharge from pharmaceutical and chemical facilities
Ethylbenzene (ppb)	700	ND	No	Discharge from petroleum refineries	
Nitrate (measured as Nitrogen) (ppm)	10	ND	No	Runoff from fertilizers; Leaching from septic tanks, cesspools, or animal deposits	
Nitrite (measured as Nitrogen) (ppm)	1	ND	No	Runoff from fertilizers; Leaching from septic tanks, cesspools, or animal deposits	
Synthetic (ppb)	100	ND	No	Discharge from rubber and plastic industries; Leaching from landfills	
Tetrahydrofuran (ppb)	0	ND	No	Discharge from factories and dry cleaners	
Toluene (ppm)	1	ND	No	Discharge from petroleum factories	
Trichloroethylene (ppb)	0	ND	No	Discharge from metal degreasing sites and other factories	
Vinyl Chloride (ppb)	0	ND	No	Leaching from PVC piping; Discharge from plastics factories	
Xylenes (ppm)	10	ND	No	Discharge from petroleum factories	
1,2-Dichloroethylene (ppb)	70	ND	No	Discharge from industrial chemical factories	
o-Dichlorobenzene (ppb)	600	ND	No	Discharge from industrial chemical facilities	
p-Dichlorobenzene (ppb)	75	ND	No	Discharge from industrial chemical factories	
Contaminants	MCLG or MRL/C	Your MCL or MRL/C	Water Violation	Typical Source	
trans-1,2-Dichloroethylene (ppb)	100	ND	No	Discharge from industrial chemical factories	

Unit Descriptions	Definition
ppm	parts per million, or milligrams per liter (mg/L)
ppb	parts per billion, or micrograms per liter (µg/L)
NA	Not applicable
ND	Not detected
NR	Monitoring not required, but recommended.

Term	Definition
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Violates	Violates and Exemptions: State or EPA permission to (3) monitor MCL, or a treatment technique under certain conditions.
Exemptions	
MRL/C	Maximum Residual Disinfection Level: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRL/Cs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRL	Maximum Residual Disinfectant Level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MSR	Monitored Not Regulated
MPL	State Assigned Maximum Permissible Level

For more information please contact:
 Contact Name: Biddy Brown
 Address: P O Box 266
 Ansony, MS 38321
 Phone: 662-256-5633

- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cool parts of the day to reduce evaporation.
- Test your kitchen water consumption to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit www.epa.gov/watersense for more information.

Source Water Protection Tips

- Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:
- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
 - Pick up after your pets.
 - If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
 - Dispose of chemicals properly; take used motor oil to a recycling center.
 - Volunteer in your community; take a watershed or watershed protection organization in your community and volunteer to help. If you are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
 - Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to Rivers" or "Protect Your Waters." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Other Information

To comply with the "Regulation Governing the Distribution of Community Water Supplies", MS0460002 is required to report certain results pertaining to the condition of our water system. 18 number of months in the previous calendar year in which average turbidity sample results were within the optimal range of 0.6-2.2 ppm was 11. The percentage of turbidity samples collected in the previous calendar year that were within the optimal range of 0.6-2.2 ppm was 32%.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Ansony Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing in your home. After your water has been sitting or stored overnight, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the State Drinking Water Hotline or at <http://www.epa.gov/lead>. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Ansony Water Department is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the State Drinking Water Hotline or at <http://www.epa.gov/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful to our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

ACCOUNT NUMBER:	205353-104846
CUSTOMER NAME: SERVICE ADDRESS:	AMORY WATER DEPT . TRUE TEMPER WATER TANK
METER READING DATE:	May 23 2019
DAYS BILLED:	30

This bill is now due and payable. Service may be discontinued without further notice.



Amory Water & Electric
129 Main Street North * P.O. Box 266
Amory, MS 38821
Phone: 662-256-5633
After Hours: 662-256-3931

To pay by phone dial: 844-200-2036, please have your 12 digit account number available

SERVICE	PRESENT READING	PREVIOUS READING	KWH USED	AMOUNT
ELECTRIC (KILOWATT HOURS)	5917	5898	19	21.48
TOTAL CURRENT CHARGES				21.48
BALANCE FORWARD (PAST DUE)				0.00

AMOUNT FROM PREVIOUS BILL	LATE CHARGES ADDED	PAYMENTS & ADJUSTMENTS	OTHER DEBITS/CREDITS	BALANCE FORWARD (PAST DUE)	CURRENT CHARGES	NET AMOUNT DUE
26.41	0.00	26.41-	0.00	0.00	21.48	21.48

We now offer automated phone and online payment options. See cityofamoryms.com for further information or call 662-256-5633 during normal business hours Monday thru Friday 8:00 AM - 5:00 PM. After hours numbers are 662-256-3931 or 662-646-0024. Copy of CCR Annual Water Report available upon request.

205353-104846

COMPARE YOUR USAGE

PERIOD	DAYS	ELECT. KWH USED	AVG. KWH. PER DAY	WATER GAL.S. USED	AVG. GAL. PER DAY
CURRENT	30	19	1	N/A	N/A
LAST MONTH	31	66	2	N/A	N/A
YEAR AGO	30	20	1	N/A	N/A

PLEASE DETACH AND RETURN BOTTOM PORTION IF PAYING BY MAIL



Amory Water & Electric
129 Main Street North * P.O. Box 266
Amory, MS 38821

RETURN SERVICE REQUESTED

C: 07
R: 212

CUSTOMER ACCOUNT NO:	205353-104846
PAST DUE AMOUNT:	0.00
CURRENT MONTH'S CHARGE:	21.48
NET AMOUNT DUE:	21.48
PAST DUE AFTER:	JUN 23 2019
PENALTY AMOUNT:	0.00
AMOUNT DUE AFTER DUE DATE:	21.48

Please update your contact information on the back of this stub.

This bill is now due and payable. Service may be discontinued without further notice.

000019



PL : 19
AMORY WATER DEPT
TRUE TEMPER WATER TANK
AMORY MS 38821



AMORY WATER & ELECTRIC DEPARTMENT
PO BOX 266
AMORY MS 38821-0266

